

MONTGOMERY-GIBBS, CA, USA

WMO: 722903

Lat: 32.816N

Lon: 117.139W

Elev: 417

StdP: 14.48

Time Zone: -8.00 (NAP)

Period: 98-19

WBAN: 03131

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	40.8	43.1	11.5	10.0	63.8	16.6	12.9	63.1	18.8	58.7	16.7	58.5	1.6	110	0.365

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.6	90.8	65.6	87.2	64.8	83.9	65.0	71.4	83.0	70.2	80.8	69.0	78.8	8.7	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.8	103.6	76.5	66.3	98.2	75.2	65.2	94.8	74.1	35.5	83.0	34.3	80.9	33.4	79.2	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.8	12.9	11.9	DB	36.5	99.5	1.9	4.4	35.2	102.7	34.1	105.3	33.0	107.8	31.7	111.0	(4)
(5)			WB	31.1	73.7	2.0	1.8	29.7	75.0	28.5	76.1	27.4	77.1	25.9	78.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	63.9	56.9	56.7	58.9	60.9	63.5	66.9	71.6	73.1	72.0	67.5	61.7	56.3	(6)
(7)		DBStd	7.61	5.28	4.99	4.72	4.93	4.09	3.78	4.07	4.02	5.07	5.28	5.33	4.67	(7)
(8)		HDD50	10	4	3	0	0	0	0	0	0	0	0	0	3	(8)
(9)		HDD65	1359	256	238	199	141	75	18	1	0	1	30	128	272	(9)
(10)		CDD50	5076	219	189	276	328	419	508	670	716	659	542	351	199	(10)
(11)		CDD65	950	6	5	10	19	29	76	206	251	210	107	28	3	(11)
(12)		CDH74	5841	107	101	146	238	233	288	907	1330	1301	816	318	56	(12)
(13)		CDH80	1798	12	19	37	78	87	75	217	374	477	315	101	6	(13)
(14)	Wind	WSAvg	5.1	4.3	5.0	5.3	6.0	6.0	5.7	5.4	5.3	5.3	4.7	4.2	4.2	(14)
(15)	Precipitation	PrecAvg	10.6	2.0	2.0	2.0	0.9	0.2	0.1	0.0	0.0	0.2	0.4	1.3	1.4	(15)
(16)		PrecMax	28.1	8.9	11.8	7.7	3.9	1.3	0.7	0.5	1.4	1.3	2.6	5.7	4.7	(16)
(17)		PrecMin	2.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	5.9	2.1	2.4	2.0	1.0	0.3	0.2	0.1	0.2	0.3	0.6	1.4	1.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.8	82.9	85.1	88.2	89.7	88.1	90.3	92.5	96.6	94.4	88.5	80.4	(19)
(20)			MCWB	55.6	55.9	59.1	57.4	58.9	67.2	69.1	69.3	68.3	62.8	58.4	54.0	(20)
(21)		2%	DB	77.0	76.9	77.8	80.6	80.5	80.8	85.0	87.9	90.0	88.0	82.4	74.2	(21)
(22)			MCWB	53.7	54.2	56.3	57.1	60.3	66.4	69.2	69.0	68.3	60.1	57.0	52.9	(22)
(23)		5%	DB	72.6	71.9	72.5	74.7	73.7	76.6	81.9	83.8	85.3	82.5	76.8	70.4	(23)
(24)			MCWB	52.9	53.8	55.6	56.9	61.1	64.8	68.3	69.0	67.7	60.5	55.6	52.4	(24)
(25)		10%	DB	67.8	66.3	68.1	70.0	70.3	73.5	79.0	81.0	81.4	77.8	72.3	65.9	(25)
(26)			MCWB	51.9	53.0	55.9	57.4	60.1	63.6	67.5	68.0	66.7	61.1	55.3	52.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.1	60.5	62.2	63.1	65.7	69.0	72.5	73.1	73.4	70.0	63.0	61.0	(27)
(28)			MCD B	70.0	68.8	75.4	76.8	78.0	82.6	84.1	86.2	88.7	79.1	71.8	68.0	(28)
(29)		2%	WB	58.4	58.3	60.2	60.7	63.5	67.0	70.7	71.2	71.5	67.2	61.4	59.0	(29)
(30)			MCD B	66.2	67.4	71.0	72.6	74.2	78.8	81.3	82.8	83.6	77.3	71.3	65.0	(30)
(31)		5%	WB	56.9	56.8	58.8	59.4	62.0	65.4	69.3	69.9	70.0	65.3	60.1	57.3	(31)
(32)			MCD B	64.0	65.3	67.7	69.4	71.3	75.2	79.4	80.4	80.0	74.8	68.9	62.9	(32)
(33)		10%	WB	55.4	55.4	57.2	58.1	60.5	64.2	68.1	68.8	68.5	63.9	58.9	55.8	(33)
(34)			MCD B	62.7	63.2	64.5	66.5	68.0	72.9	77.2	78.5	77.6	71.9	67.1	61.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	19.7	18.1	16.6	15.7	12.7	12.7	13.6	14.6	15.6	17.3	19.3	19.2	(35)
(36)			MCDBR	27.8	28.1	26.2	26.5	21.2	18.2	17.6	19.2	22.4	27.9	27.9	27.0	(36)
(37)			MCWBR	12.6	12.7	11.6	11.4	9.0	7.0	6.6	7.1	8.0	11.9	12.6	13.5	(37)
(38)		5% WB	MCDBR	18.6	19.7	19.1	19.1	16.9	17.0	16.2	17.1	18.6	19.3	19.5	17.4	(38)
(39)			MCWBR	10.2	10.3	9.4	8.9	7.5	6.9	6.4	6.6	7.2	8.7	10.1	9.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.311	0.322	0.334	0.345	0.364	0.364	0.392	0.393	0.359	0.365	0.319	0.322	(40)	
(41)		taud	2.556	2.541	2.489	2.464	2.430	2.436	2.435	2.414	2.488	2.440	2.562	2.552	(41)	
(42)		Ebn at Noon	290	297	300	299	292	291	282	281	288	277	284	279	(42)	
(43)		Edh at Noon	26	29	33	35	37	36	36	36	33	32	26	25	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1049	1324	1740	2099	2210	2307	2251	2166	1872	1461	1141	950	(44)	
(45)		RadStd	65	113	96	111	161	141	145	91	98	104	74	67	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.98	N/A	N/A	+3.20	N/A	N/A	N/A	-364	+729	+347
(47) Regional (41 neighbors)		+1.19	N/A	-2.90	+1.35	N/A	N/A	N/A	-193	+423	+223

Nomenclature: See separate page