

MONTGOMERY-GIBBS, CA, USA

WMO: 722903

Lat: 32.816N

Lon: 117.139W

Elev: 127

StdP: 99.81

Time Zone: -8.00 (NAP)

Period: 98-19

WBAN: 03131

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	4.9	6.2	-11.4	1.4	17.6	-8.6	1.8	17.3	8.4	14.8	7.5	14.7	0.7	110	0.365

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.1	32.7	18.7	30.7	18.2	28.8	18.4	21.9	28.3	21.2	27.1	20.6	26.0	3.9	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.9	14.8	24.7	19.0	14.0	24.0	18.5	13.5	23.4	64.6	28.4	62.0	27.2	59.7	26.2	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.0	5.8	5.3	2.5	37.5	1.0	2.5	1.8	39.3	1.2	40.7	0.6	42.1	-0.2	43.9		
			-0.5	23.2	1.1	1.0	-1.3	23.9	-1.9	24.5	-2.6	25.1	-3.4	25.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.7	13.9	13.7	14.9	16.1	17.5	19.4	22.0	22.8	22.2	19.7	16.5	13.5	(6)
	DBStd	4.23	2.93	2.77	2.62	2.74	2.27	2.10	2.26	2.23	2.82	2.93	2.96	2.59	(7)
	HDD10.0	6	2	2	0	0	0	0	0	0	0	0	0	2	(8)
	HDD18.3	755	142	132	111	78	42	10	1	0	1	17	71	151	(9)
	CDD10.0	2820	122	105	153	182	233	282	372	398	366	301	195	111	(10)
	CDD18.3	528	3	3	6	11	16	42	114	139	117	59	16	2	(11)
	CDH23.3	3245	59	56	81	132	129	160	504	739	723	453	177	31	(12)
(13)	CDH26.7	999	7	11	21	43	48	42	121	208	265	175	56	3	(13)
(14)	Wind	WSAvg	2.3	1.9	2.2	2.4	2.7	2.7	2.5	2.4	2.4	2.1	1.9	1.9	(14)
(15) Precipitation	PrecAvg	269	51	51	50	23	5	2	1	1	5	9	34	35	(15)
	PrecMax	714	225	300	196	98	32	19	12	36	32	67	144	119	(16)
	PrecMin	62	0	0	0	0	0	0	0	0	0	0	0	1	(17)
	PrecStd	150	54	61	50	26	7	4	2	6	7	15	35	31	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.7	28.3	29.5	31.2	32.1	31.2	32.4	33.6	35.9	34.7	31.4	26.9	(19)
		MCWB	13.1	13.3	15.1	14.1	14.9	19.5	20.6	20.7	20.2	17.1	14.6	12.2	(20)
	2%	DB	25.0	25.0	25.5	27.0	26.9	27.1	29.5	31.1	32.2	31.1	28.0	23.4	(21)
		MCWB	12.1	12.4	13.5	13.9	15.7	19.1	20.7	20.5	20.2	15.6	13.9	11.6	(22)
	5%	DB	22.6	22.1	22.5	23.7	23.2	24.8	27.7	28.8	29.6	28.0	24.9	21.3	(23)
		MCWB	11.6	12.1	13.1	13.8	16.2	18.2	20.1	20.6	19.8	15.8	13.1	11.3	(24)
	10%	DB	19.9	19.1	20.0	21.1	21.3	23.0	26.1	27.2	27.4	25.4	22.4	18.9	(25)
		MCWB	11.1	11.7	13.3	14.1	15.6	17.6	19.7	20.0	19.3	16.2	12.9	11.5	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.6	15.8	16.8	17.3	18.7	20.6	22.5	22.9	23.0	21.1	17.2	16.1	(27)
		MCDB	21.1	20.5	24.1	24.9	25.5	28.1	28.9	30.1	31.5	26.2	22.1	20.0	(28)
	2%	WB	14.7	14.6	15.7	15.9	17.5	19.4	21.5	21.8	21.9	19.6	16.3	15.0	(29)
		MCDB	19.0	19.7	21.7	22.6	23.5	26.0	27.4	28.2	28.7	25.2	21.8	18.3	(30)
	5%	WB	13.8	13.8	14.9	15.2	16.7	18.6	20.7	21.1	21.1	18.5	15.6	14.1	(31)
		MCDB	17.8	18.5	19.8	20.8	21.8	24.0	26.4	26.9	26.7	23.8	20.5	17.2	(32)
	10%	WB	13.0	13.0	14.0	14.5	15.8	17.9	20.1	20.5	20.3	17.7	15.0	13.2	(33)
		MCDB	17.1	17.3	18.0	19.2	20.0	22.7	25.1	25.9	25.4	22.2	19.5	16.5	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	10.9	10.0	9.2	8.7	7.1	7.0	7.5	8.1	8.7	9.6	10.7	10.7	(35)
		MCDBR	15.5	15.6	14.6	14.7	11.8	10.1	9.8	10.6	12.5	15.5	15.5	15.0	(36)
	5% WB	MCWBR	7.0	7.0	6.5	6.3	5.0	3.9	3.7	3.9	4.5	6.6	7.0	7.5	(37)
		MCWBR	10.3	11.0	10.6	10.6	9.4	9.5	9.0	9.5	10.3	10.7	10.8	9.6	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.311	0.322	0.334	0.345	0.364	0.364	0.392	0.393	0.359	0.365	0.319	0.322	(40)
		taud	2.556	2.541	2.489	2.464	2.430	2.436	2.435	2.414	2.488	2.440	2.562	2.552	(41)
	Ebn at Noon	Ebn at Noon	913	937	945	943	921	917	889	886	907	873	896	879	(42)
		Edh at Noon	82	91	104	111	116	115	115	115	103	100	81	78	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	3.31	4.17	5.48	6.62	6.97	7.27	7.10	6.83	5.90	4.61	3.60	2.99	(44)
	RadStd	RadStd	0.20	0.35	0.30	0.35	0.51	0.45	0.46	0.29	0.31	0.33	0.23	0.21	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (41 neighbors)	+1.10	N/A	N/A	+1.78	N/A	N/A	N/A	-202	+405	+193
		+0.66	N/A	-1.61	+0.75	N/A	N/A	N/A	-107	+235	+124

Nomenclature: See separate page