

NORTH ISLAND NAS, CA, USA

WMO: 722906

Lat: 32.700N

Lon: 117.200W

Elev: 26

StdP: 14.68

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 93112

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	44.9	46.3	21.1	15.9	65.0	26.5	20.5	63.8	24.4	59.1	20.8	58.9	2.2	90	0.366

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.8	85.1	63.8	81.5	65.1	79.1	65.8	71.4	77.9	70.3	76.7	69.3	75.5	9.0	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.5	108.5	74.9	67.9	102.8	74.2	66.5	97.6	73.3	35.2	78.5	34.3	76.7	33.3	75.9	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.7	16.5	14.6	DB	40.3	93.6	2.0	5.4	38.9	97.5	37.8	100.7	36.7	103.8	35.2	107.7
			WB	35.0	73.7	2.3	2.2	33.4	75.3	32.0	76.6	30.7	77.9	29.0	79.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.2	58.1	58.5	60.2	61.8	64.2	66.6	70.1	71.7	71.2	67.5	62.4	57.7
	DBStd	6.26	4.47	4.07	4.02	4.06	3.58	2.98	3.10	3.10	3.97	3.95	4.65	3.79
	HDD50	2	1	0	0	0	0	0	0	0	0	0	0	1
	HDD65	1093	218	188	159	111	56	15	1	0	1	14	103	227
	CDD50	5187	253	237	317	355	440	497	623	674	635	543	372	241
	CDD65	801	5	5	11	17	30	61	158	209	186	92	25	2
	CDH74	2473	71	51	80	126	119	59	270	515	605	380	173	24
	CDH80	513	9	7	17	42	51	9	15	62	127	119	53	2
(14) Wind	WSAvg	6.3	5.4	6.5	6.6	7.3	7.1	6.9	6.7	6.8	6.7	5.7	5.2	5.3
(15) Precipitation	PrecAvg	8.7	1.7	1.6	1.6	0.7	0.2	0.0	0.0	0.0	0.2	0.3	1.2	1.3
	PrecMax	19.9	6.1	6.9	6.3	2.9	1.3	0.7	0.1	0.3	1.4	2.0	5.7	5.6
	PrecMin	2.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2
	PrecStd	3.9	1.7	1.7	1.6	0.8	0.3	0.1	0.0	0.0	0.4	0.4	1.3	1.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.9	80.2	82.2	85.5	87.0	79.3	82.2	85.1	89.0	89.8	86.6	77.5
		MCWB	57.4	56.7	57.6	59.2	59.0	67.4	69.9	69.6	70.1	61.7	58.7	53.8
	2%	DB	75.1	73.7	74.6	76.5	74.9	75.1	79.2	81.2	83.1	82.8	78.8	71.7
		MCWB	55.4	55.1	56.7	57.9	62.6	65.0	68.8	69.6	68.9	60.6	57.9	54.1
	5%	DB	70.0	68.5	70.1	71.5	71.4	73.1	77.0	78.9	79.7	77.5	73.0	67.8
		MCWB	54.9	55.6	57.2	58.8	61.8	63.9	67.9	68.9	69.1	62.8	57.6	55.4
	10%	DB	65.7	65.0	66.5	68.0	69.0	71.4	75.1	76.6	77.1	73.8	69.7	64.9
		MCWB	55.0	55.4	57.0	58.2	60.7	63.3	67.0	67.9	68.1	63.5	58.5	55.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	62.9	61.7	62.2	63.3	66.6	69.1	72.2	72.2	73.3	70.6	64.8	62.4
		MCDB	66.7	66.8	69.4	70.7	73.2	75.2	78.5	79.2	81.8	76.5	70.1	65.9
	2%	WB	60.3	59.6	60.5	61.7	64.4	66.9	70.1	70.9	71.8	68.0	63.2	60.4
		MCDB	64.3	65.6	67.4	69.3	70.2	73.0	76.3	77.6	78.6	74.2	68.4	64.5
	5%	WB	58.9	58.5	59.4	60.4	63.1	65.4	69.0	69.9	70.7	66.3	62.0	59.2
		MCDB	63.7	64.2	65.8	67.5	68.6	71.1	75.0	76.5	77.0	72.3	67.6	63.5
	10%	WB	57.5	57.4	58.4	59.4	61.9	64.1	68.0	69.0	69.4	64.9	60.8	57.8
		MCDB	62.5	62.9	64.6	66.1	67.3	69.7	73.7	75.3	75.5	70.7	66.7	62.5
(35) Mean Daily Temperature Range	5% DB	MDBR	15.4	13.7	11.9	11.2	8.8	7.9	8.3	8.8	10.0	12.4	14.8	15.5
		MCDBR	23.9	21.4	19.4	19.2	13.4	10.5	10.7	11.4	14.4	21.6	22.7	21.4
		MCWBR	10.5	9.8	8.9	8.6	6.2	4.9	4.5	4.7	5.8	9.6	10.6	11.1
	5% WB	MCDBR	14.1	13.7	12.9	13.8	11.3	10.7	10.0	10.6	12.6	14.1	15.1	13.3
		MCWBR	9.1	8.0	7.2	7.3	6.3	5.3	4.7	4.8	5.3	7.4	9.0	9.1
(40) Clear-Sky Solar Irradiance	taub		0.316	0.327	0.340	0.351	0.371	0.370	0.399	0.397	0.364	0.370	0.324	0.327
	taud		2.554	2.536	2.483	2.456	2.421	2.426	2.429	2.413	2.482	2.443	2.559	2.551
	Ebn at Noon		288	295	298	297	290	289	280	280	286	276	283	277
	Edh at Noon		26	29	33	36	37	37	36	36	33	32	26	25
(44) All-Sky Solar Radiation	RadAvg		1048	1324	1728	2081	2166	2240	2206	2136	1850	1447	1135	949
	RadStd		63	109	98	117	168	147	153	97	106	107	78	67

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.06	N/A	N/A	+1.93	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (38 neighbors)		+1.15	N/A	-2.86	+1.37	N/A	N/A	N/A	-189	+414	+214

Nomenclature: See separate page