

CAMP PENDLETON MCAS, CA, USA

WMO: 722926

Lat: 33.300N

Lon: 117.350W

Elev: 75

StdP: 14.66

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 03154

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	31.9	34.6	10.5	9.4	63.0	16.8	12.9	60.5	18.9	61.4	16.4	60.4	0.6	30	0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.0	91.3	65.0	87.5	65.0	84.0	65.2	71.6	82.9	70.3	81.1	69.2	79.4	8.8	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.0	103.1	76.0	66.3	97.2	75.4	65.2	93.3	74.6	35.4	82.8	34.3	81.2	33.3	79.5	87.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.0	12.7	11.7	DB	27.2	101.0	3.0	3.0	25.0	103.1	23.3	104.9	21.6	106.6	19.4	108.7	(4)
(5)			WB	25.1	75.1	3.1	3.6	22.8	77.7	21.0	79.8	19.2	81.9	17.0	84.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.4	54.2	54.2	56.7	58.5	62.4	66.0	69.7	70.7	69.4	64.0	58.0	53.1
	DBStd	7.62	5.25	4.91	4.40	4.39	3.73	3.26	3.58	3.95	4.85	4.58	4.90	4.84
	HDD50	60	16	14	3	1	0	0	0	0	0	0	3	23
	HDD65	1904	336	303	260	200	98	24	4	6	11	75	218	369
	CDD50	4238	147	133	210	257	384	479	611	641	582	433	241	120
	CDD65	607	2	2	2	6	17	53	150	182	143	42	7	1
	CDH74	5829	154	108	176	280	261	294	850	1289	1235	766	354	62
	CDH80	1856	30	26	57	104	108	69	177	372	463	316	127	7
Wind	WSAvg	4.0	3.3	3.7	4.0	4.5	4.7	4.6	4.6	4.4	4.1	3.8	3.2	3.2
Precipitation	PrecAvg	11.7	2.1	2.8	1.7	0.8	0.3	0.1	0.2	0.0	0.2	0.6	0.9	1.7
	PrecMax	23.6	9.4	11.3	6.9	2.4	1.4	0.6	2.3	0.4	1.5	5.6	2.7	9.1
	PrecMin	4.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	5.2	2.4	2.4	1.7	0.7	0.4	0.2	0.5	0.1	0.3	1.1	0.8	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.0	84.1	87.2	90.3	91.0	87.8	88.7	92.6	98.2	95.3	90.4	80.5
		MCWB	56.6	57.9	59.0	60.5	60.2	67.7	70.4	67.7	68.0	63.4	59.4	55.5
	2%	DB	78.5	77.0	78.7	81.8	80.8	80.4	84.2	87.6	90.1	88.6	83.8	74.9
		MCWB	55.4	55.6	57.5	59.1	63.3	67.0	69.5	69.3	68.9	60.8	57.6	53.9
	5%	DB	73.3	71.3	72.7	74.8	74.5	76.9	81.3	83.8	85.0	82.1	77.2	70.5
		MCWB	54.2	54.9	57.4	58.3	63.1	65.5	68.8	68.8	67.6	61.3	56.3	54.1
	10%	DB	67.6	66.3	68.0	69.9	71.2	74.3	78.8	80.9	81.1	76.9	72.2	66.2
		MCWB	53.9	54.9	57.4	58.7	61.8	64.5	67.8	68.4	67.6	62.1	56.5	53.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.9	62.1	64.5	64.5	67.8	69.5	73.1	73.1	73.6	70.2	63.8	62.1
		MCDB	71.8	74.2	73.4	76.8	77.7	82.1	82.9	87.3	86.6	79.5	74.5	69.3
	2%	WB	59.6	59.5	61.4	62.2	65.4	67.8	71.1	71.1	71.4	67.4	62.1	59.6
		MCDB	68.2	67.8	72.0	73.9	75.7	79.2	81.2	82.8	83.8	77.6	72.9	66.1
	5%	WB	58.0	57.9	59.5	60.3	63.5	66.3	69.7	69.9	69.8	65.6	60.4	58.0
		MCDB	65.8	65.6	68.3	70.4	72.6	76.2	79.3	80.8	80.8	75.5	70.6	64.4
	10%	WB	56.5	56.5	58.2	59.0	62.0	64.9	68.4	68.9	68.4	64.0	59.1	56.2
		MCDB	64.1	64.0	65.9	67.9	69.8	73.4	77.4	79.0	78.7	72.8	68.5	62.8
Mean Daily Temperature Range	5% DB	MDBR	26.8	23.8	22.3	22.2	17.8	16.8	18.1	20.0	22.3	25.7	28.7	27.4
		MCDBR	38.0	35.8	34.5	36.3	27.6	23.3	23.0	26.3	30.7	39.4	39.7	36.0
		MCWBR	19.4	19.0	18.5	18.1	14.7	12.1	11.0	12.3	14.3	19.0	19.8	20.4
	5% WB	MCDBR	25.1	24.1	24.6	25.4	21.9	21.3	21.0	22.1	24.6	25.7	28.0	24.2
		MCWBR	15.6	15.1	15.0	14.4	12.6	11.4	10.2	11.0	12.7	14.8	17.2	16.3
Clear-Sky Solar Irradiance	taub	0.309	0.319	0.338	0.352	0.370	0.368	0.396	0.389	0.361	0.355	0.316	0.318	
	taud	2.567	2.552	2.482	2.449	2.427	2.440	2.434	2.433	2.498	2.485	2.581	2.574	
	Ebn at Noon	290	298	298	297	291	290	281	282	287	280	285	280	
	Edh at Noon	25	29	33	36	37	36	36	36	32	30	25	24	
All-Sky Solar Radiation	RadAvg	1033	1308	1737	2095	2230	2364	2337	2233	1899	1454	1134	934	
	RadStd	66	124	91	109	151	146	123	62	78	101	68	68	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (49 neighbors)	+1.12	N/A	-3.04	+1.22	N/A	N/A	N/A	-193	+394	+202

Nomenclature: See separate page