

CAMP PENDLETON MCAS, CA, USA

WMO: 722926

Lat: 33.300N

Lon: 117.350W

Elev: 23

StdP: 101.05

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 03154

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	0.0	1.4	-12.0	1.3	17.2	-8.5	1.8	15.9	8.4	16.4	7.3	15.8	0.3	30	0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.1	32.9	18.3	30.8	18.3	28.9	18.4	22.0	28.3	21.3	27.3	20.6	26.3	3.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.0	14.7	24.4	19.1	13.9	24.1	18.4	13.3	23.7	64.4	28.2	61.8	27.3	59.5	26.4	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.7	5.7	5.2	DB	-2.7	38.3	1.7	1.7	-3.9	39.5	-4.9	40.5	-5.8	41.4	-7.0	42.6	(4)
(5)			WB	-3.8	23.9	1.7	2.0	-5.1	25.4	-6.1	26.6	-7.1	27.7	-8.4	29.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.4	12.3	12.4	13.7	14.7	16.9	18.9	20.9	21.5	20.8	17.8	14.4	11.7	(6)	
	DBStd	4.23	2.92	2.73	2.44	2.44	2.07	1.81	1.99	2.19	2.69	2.54	2.72	2.69	(7)	
	HDD10.0	33	9	8	2	1	0	0	0	0	0	0	2	13	(8)	
	HDD18.3	1058	187	168	144	111	54	13	2	3	6	42	121	205	(9)	
	CDD10.0	2354	82	74	117	143	213	266	339	356	323	241	134	67	(10)	
	CDD18.3	337	1	1	1	3	9	29	83	101	79	23	4	1	(11)	
	CDH23.3	3238	86	60	98	156	145	163	472	716	686	426	197	34	(12)	
(13)	CDH26.7	1031	17	14	32	58	60	38	98	207	257	176	71	4	(13)	
(14)	Wind	WSAvg	1.8	1.5	1.6	1.8	2.0	2.1	2.1	2.0	1.8	1.7	1.4	1.4	(14)	
(15) Precipitation	PrecAvg	297	54	72	43	21	7	2	4	1	5	14	24	44	(15)	
	PrecMax	600	238	287	175	61	36	16	59	11	39	141	69	230	(16)	
	PrecMin	118	1	0	0	0	0	0	0	0	0	0	0	0	(17)	
	PrecStd	133	60	62	42	17	9	4	12	2	8	29	21	46	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.9	28.9	30.7	32.4	32.8	31.0	31.5	33.7	36.8	35.2	32.5	26.9	(19)	
		MCWB	13.7	14.4	15.0	15.8	15.7	19.8	21.4	19.8	20.0	17.4	15.2	13.1	(20)	
	2%	DB	25.8	25.0	26.0	27.7	27.1	26.9	29.0	30.9	32.3	31.4	28.8	23.8	(21)	
		MCWB	13.0	13.1	14.2	15.0	17.4	19.4	20.8	20.7	20.5	16.0	14.2	12.2	(22)	
	5%	DB	22.9	21.8	22.6	23.8	23.6	24.9	27.4	28.8	29.5	27.8	25.1	21.4	(23)	
		MCWB	12.3	12.7	14.1	14.6	17.3	18.6	20.4	20.4	19.8	16.3	13.5	12.3	(24)	
	10%	DB	19.8	19.0	20.0	21.1	21.8	23.5	26.0	27.2	27.3	24.9	22.3	19.0	(25)	
		MCWB	12.2	12.7	14.1	14.9	16.5	18.0	19.9	20.2	19.8	16.7	13.6	11.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.6	16.7	18.0	18.1	19.9	20.8	22.8	22.8	23.1	21.2	17.6	16.7	(27)	
		MCDB	22.1	23.4	23.0	24.9	25.4	27.9	28.3	30.7	30.3	26.4	23.6	20.7	(28)	
	2%	WB	15.3	15.3	16.3	16.8	18.6	19.9	21.7	21.7	21.9	19.7	16.7	15.3	(29)	
		MCDB	20.1	19.9	22.2	23.3	24.3	26.2	27.3	28.2	28.8	25.4	22.7	18.9	(30)	
	5%	WB	14.5	14.4	15.3	15.7	17.5	19.0	20.9	21.1	21.0	18.7	15.8	14.4	(31)	
		MCDB	18.8	18.7	20.2	21.3	22.6	24.5	26.3	27.1	27.1	24.2	21.5	18.0	(32)	
	10%	WB	13.6	13.6	14.5	15.0	16.7	18.3	20.2	20.5	20.2	17.8	15.1	13.4	(33)	
		MCDB	17.8	17.8	18.8	19.9	21.0	23.0	25.2	26.1	26.0	22.7	20.3	17.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	14.9	13.2	12.4	12.4	9.9	9.3	10.1	11.1	12.4	14.3	16.0	15.2	(35)	
		MCDBR	21.1	19.9	19.2	20.2	15.3	12.9	12.8	14.6	17.1	21.9	22.0	20.0	(36)	
	5% WB	MCWBR	10.8	10.6	10.3	10.1	8.1	6.7	6.1	6.9	7.9	10.6	11.0	11.3	(37)	
		MCWBR	13.9	13.4	13.7	14.1	12.2	11.8	11.7	12.3	13.7	14.3	15.6	13.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.309	0.319	0.338	0.352	0.370	0.368	0.396	0.389	0.361	0.355	0.316	0.318	(40)	
		taud	2.567	2.552	2.482	2.449	2.427	2.440	2.434	2.433	2.498	2.485	2.581	2.574	(41)	
	Ebn at Noon		914	938	940	935	916	913	885	889	904	883	898	882	(42)	
		Edh at Noon	80	90	104	112	116	114	115	113	101	95	79	76	(43)	
(44) All-Sky Solar Radiation	RadAvg		3.25	4.12	5.48	6.61	7.03	7.45	7.37	7.04	5.99	4.58	3.58	2.94	(44)	
	RadStd		0.21	0.39	0.29	0.34	0.48	0.46	0.39	0.20	0.25	0.32	0.21	0.21	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (49 neighbors)	+0.62	N/A	-1.69	+0.68	N/A	N/A	N/A	-107	+219	+112	(47)

Nomenclature: See separate page