

LOS ANGELES INTL, CA, USA

WMO: 722950

Lat: 33.938N

Lon: 118.389W

Elev: 97

StdP: 14.64

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23174

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	45.0	47.0	12.2	10.3	62.0	17.5	13.4	61.2	25.6	57.5	22.4	56.6	4.2	80	0.408

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.3	84.7	63.3	81.3	64.2	78.6	64.3	70.5	78.2	69.3	76.3	68.2	75.0	8.6	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.6	101.8	74.6	66.4	97.7	73.5	65.4	94.0	72.6	34.5	78.2	33.4	76.7	32.5	74.9	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.3	17.6	16.0	40.4	94.3	2.0	4.3	38.9	97.4	37.7	99.9	36.6	102.3	35.1	105.4		
(5)			33.7	72.1	2.4	2.0	32.0	73.5	30.5	74.7	29.2	75.8	27.4	77.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.4	57.9	57.6	59.1	60.6	63.2	66.1	69.3	70.2	69.8	66.8	62.1	57.6
	DBStd	6.28	4.89	4.73	4.12	4.35	3.52	2.67	3.07	3.35	4.13	4.92	5.08	4.20
	HDD50	4	2	1	0	0	0	0	0	0	0	0	0	1
	HDD65	1256	227	215	191	147	77	15	2	1	3	29	116	233
	CDD50	4894	248	213	283	318	409	483	599	628	593	521	363	236
	CDD65	672	8	7	9	15	21	48	136	164	146	86	29	3
	CDH74	2127	61	57	59	93	86	65	235	387	462	419	178	25
	CDH80	453	8	12	10	25	27	9	26	48	95	139	52	2
(14) Wind	WSAvg	7.3	6.2	7.4	7.8	8.6	8.2	7.8	7.9	7.6	7.2	6.6	6.2	6.2
(15) Precipitation	PrecAvg	12.1	2.6	2.8	1.8	0.7	0.1	0.1	0.0	0.0	0.2	0.4	1.3	1.9
	PrecMax	29.5	12.7	13.3	6.4	4.5	0.9	1.0	0.4	1.3	1.9	3.8	7.5	8.8
	PrecMin	3.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	5.6	2.8	3.0	1.7	0.9	0.2	0.2	0.1	0.2	0.4	0.6	1.5	1.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.7	81.4	80.9	83.4	83.9	80.6	83.3	84.7	87.9	91.0	86.5	77.6
		MCWB	55.2	57.0	57.1	58.3	60.2	66.4	70.1	70.0	67.0	61.5	59.0	53.6
	2%	DB	74.5	73.3	73.7	75.6	74.3	75.2	78.9	80.6	82.3	83.5	78.8	72.0
		MCWB	53.7	54.3	55.1	56.7	62.7	65.1	68.7	69.0	67.7	60.3	56.1	53.3
	5%	DB	70.2	68.5	69.0	70.6	71.1	72.8	76.4	78.0	78.9	78.2	73.9	68.1
		MCWB	52.8	54.0	55.6	57.2	62.2	64.3	67.6	68.0	67.3	61.1	55.8	52.8
	10%	DB	66.0	64.4	65.5	67.1	68.5	71.1	74.4	75.8	76.1	73.9	69.9	64.8
		MCWB	52.7	53.9	56.1	57.2	60.7	63.3	66.6	67.1	66.7	61.8	56.2	53.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.3	61.3	62.0	63.3	67.9	68.1	71.5	71.7	72.2	69.5	64.3	61.6
		MCDB	66.5	68.9	68.9	72.2	74.3	77.5	79.8	80.9	81.5	77.2	70.8	64.8
	2%	WB	59.4	59.4	60.1	61.0	64.8	66.2	69.8	70.3	70.2	67.2	62.3	59.7
		MCDB	63.8	64.3	66.2	68.6	70.8	73.8	77.1	78.1	77.7	74.5	68.1	63.1
	5%	WB	58.0	58.2	59.0	59.6	63.3	65.0	68.5	69.1	68.9	65.5	61.1	58.5
		MCDB	62.2	62.7	64.4	66.2	68.9	71.8	75.0	76.1	75.9	72.0	66.7	62.1
	10%	WB	56.8	57.0	57.9	58.4	61.9	64.0	67.4	68.0	67.6	64.1	60.0	57.2
		MCDB	61.1	61.4	62.6	64.6	67.1	70.2	73.3	74.5	74.4	70.1	65.5	61.1
(35) Mean Daily Temperature Range	5% DB	MDBR	15.1	13.7	12.5	12.3	10.5	9.7	9.9	10.3	11.0	12.9	14.9	14.8
		MCDBR	22.9	21.9	19.8	18.9	14.2	11.8	11.8	12.8	15.4	21.8	22.6	20.9
	5% WB	MCWBR	11.4	10.9	10.0	8.8	6.8	5.3	5.1	5.4	6.6	10.0	11.7	11.8
		MCWBR	14.4	14.3	13.1	14.1	12.1	11.6	11.4	12.2	12.8	14.7	15.4	13.6
(40) Clear-Sky Solar Irradiance	taub		0.335	0.349	0.372	0.377	0.382	0.398	0.400	0.380	0.367	0.371	0.322	0.323
		taud	2.501	2.476	2.385	2.378	2.393	2.352	2.412	2.447	2.478	2.439	2.577	2.573
	Ebn at Noon		278	285	286	289	287	281	279	284	284	273	281	276
		Edh at Noon	27	31	36	38	38	40	37	35	33	31	25	24
(44) All-Sky Solar Radiation	RadAvg		998	1280	1712	2096	2260	2349	2353	2240	1891	1435	1111	905
	RadStd		73	127	98	110	158	146	129	77	80	108	69	69

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.72	N/A	-2.88	N/A	N/A	N/A	N/A	+250	N/A
(47) Regional (52 neighbors)		+1.15	N/A	-2.97	+1.31	N/A	N/A	N/A	+405	+194

Nomenclature: See separate page