

LOS ALAMITOS AAF, CA, USA

WMO: 722975

Lat: 33.790N

Lon: 118.052W

Elev: 35

StdP: 14.68

Time Zone: -8.00 (NAP)

Period: 08-19

WBAN: 53141

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	38.9	41.3	9.5	9.0	69.6	17.3	13.2	66.2	21.1	62.7	18.5	59.4	2.1	20	0.372

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.6	92.1	66.1	88.5	65.9	85.5	65.8	72.4	83.1	71.2	80.9	70.1	79.3	9.3	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.5	108.6	74.7	68.3	104.0	74.4	67.1	99.7	74.0	36.0	82.8	35.0	81.1	34.0	79.6	76.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.8	14.4	12.5	DB	34.3	102.3	1.7	4.2	33.1	105.3	32.1	107.7	31.2	110.1	30.0	113.2	(4)
(5)			WB	31.2	74.2	1.6	1.8	30.1	75.5	29.2	76.6	28.3	77.6	27.2	78.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	64.1	57.0	56.4	59.4	62.0	64.2	67.7	71.8	72.9	72.6	67.8	61.5	55.6	(6)
(7)		DBStd	7.50	4.56	5.26	4.41	4.29	3.63	3.11	3.59	3.83	4.86	4.81	4.82	4.28	(7)
(8)		HDD50	16	4	7	0	0	0	0	0	0	0	0	0	5	(8)
(9)		HDD65	1292	253	245	184	111	56	5	0	0	1	21	124	292	(9)
(10)		CDD50	5167	219	187	290	360	439	530	674	710	679	553	347	179	(10)
(11)		CDD65	970	3	5	9	21	30	85	210	245	230	110	21	1	(11)
(12)		CDH74	7083	120	121	187	344	266	333	1102	1492	1658	1028	378	54	(12)
(13)		CDH80	2363	22	34	60	117	118	85	268	451	659	419	122	8	(13)
(14)	Wind	WSAvg	4.9	3.9	4.8	5.1	5.9	6.2	5.8	5.6	5.1	4.7	4.3	3.8	4.1	(14)
(15)	Precipitation	PrecAvg	12.4	2.8	3.2	1.8	0.7	0.3	0.1	0.0	0.1	0.5	0.9	2.1	(15)	
(16)		PrecMax	24.9	12.8	13.0	6.0	2.0	2.1	0.9	0.4	0.1	1.6	4.4	2.2	9.8	(16)
(17)		PrecMin	4.8	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	6.0	3.2	3.0	1.7	0.6	0.5	0.2	0.1	0.0	0.3	0.9	0.7	2.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	83.6	85.5	87.4	90.8	92.9	88.7	90.6	92.4	98.5	97.4	90.1	80.4	(19)
(20)			MCWB	55.8	57.6	59.6	59.7	60.6	68.1	68.5	68.1	68.2	63.6	60.5	52.7	(20)
(21)		2%	DB	77.2	77.2	78.7	82.4	82.1	80.9	86.0	88.5	91.1	90.0	83.3	73.6	(21)
(22)			MCWB	55.2	56.1	57.4	58.4	60.6	66.9	68.9	68.9	69.4	62.9	57.8	54.7	(22)
(23)		5%	DB	73.3	71.4	73.7	77.3	74.7	77.4	82.6	85.1	87.2	84.3	77.9	68.9	(23)
(24)			MCWB	54.3	57.3	58.1	57.7	62.5	65.8	69.0	68.8	68.5	62.5	56.6	53.4	(24)
(25)		10%	DB	68.3	67.0	69.2	71.9	71.3	74.7	79.9	81.7	83.1	79.0	73.1	65.3	(25)
(26)			MCWB	54.9	56.8	57.9	58.4	61.1	64.8	68.4	68.5	68.7	62.7	57.0	54.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	62.2	65.2	65.2	65.2	66.5	70.2	72.8	73.5	74.7	72.6	65.4	64.0	(27)
(28)			MCD B	68.3	70.6	73.8	77.7	76.1	82.9	82.8	84.9	89.3	80.8	73.9	66.5	(28)
(29)		2%	WB	60.4	62.1	62.4	62.9	65.0	68.3	71.2	72.1	72.5	69.7	63.5	61.2	(29)
(30)			MCD B	65.0	67.5	71.0	73.3	74.5	78.7	81.6	82.2	84.0	78.5	71.2	64.9	(30)
(31)		5%	WB	59.2	60.2	60.9	61.4	63.5	66.8	70.1	71.0	71.1	68.0	62.1	59.5	(31)
(32)			MCD B	63.6	65.8	68.9	70.9	71.1	75.7	79.8	80.2	80.9	76.2	69.5	62.6	(32)
(33)		10%	WB	57.8	58.6	59.5	60.1	62.1	65.6	68.9	69.6	69.8	66.1	60.6	58.0	(33)
(34)			MCD B	63.3	64.0	66.3	68.2	69.3	73.4	77.8	78.1	78.9	73.6	67.7	61.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	22.6	19.7	19.0	19.3	15.2	14.4	15.8	17.6	19.6	21.0	23.0	20.5	(35)
(36)			MCD BR	31.7	29.1	29.3	31.5	23.5	20.7	21.0	23.9	27.3	32.4	32.7	29.1	(36)
(37)			MCWBR	15.1	14.7	13.6	11.8	9.2	8.0	7.5	7.9	8.9	12.0	14.2	15.0	(37)
(38)		5% WB	MCD BR	20.9	20.7	20.4	22.0	18.5	18.9	18.6	19.6	22.9	22.4	23.0	17.9	(38)
(39)			MCWBR	12.9	12.9	11.5	10.3	8.1	7.6	7.0	7.3	8.5	9.8	12.6	12.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.335	0.346	0.372	0.371	0.371	0.387	0.389	0.373	0.359	0.365	0.318	0.318	(40)	
(41)		taud	2.507	2.485	2.386	2.398	2.430	2.386	2.449	2.479	2.509	2.466	2.595	2.596	(41)	
(42)		Ebn at Noon	278	287	286	291	290	284	283	286	287	276	284	279	(42)	
(43)		Edh at Noon	27	30	36	37	37	38	36	34	32	31	24	23	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1010	1291	1725	2102	2256	2356	2351	2240	1893	1439	1118	914	(44)	
(45)		RadStd	71	125	93	107	154	146	127	71	79	106	68	68	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (52 neighbors)	+1.12	N/A	-2.93	+1.30	N/A	N/A	N/A	-198	+389	+187	(47)

Nomenclature: See separate page