

PITT-GREENVILLE, NC, USA

WMO: 723065

Lat: 35.633N

Lon: 77.383W

Elev: 25

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 13783

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.7	24.9	2.8	6.4	30.2	8.5	8.5	32.9	23.0	59.8	19.6	58.8	2.9	0	0.408

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.6	95.0	76.7	92.9	75.4	90.7	74.9	79.4	89.9	78.2	87.7	77.1	86.1	6.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.1	141.3	82.6	75.3	132.9	82.2	74.2	127.6	80.9	42.9	88.7	41.5	87.3	40.5	85.2	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	16.3	13.8	14.1	98.7	4.1	2.2	11.1	100.3	8.7	101.5	6.4	102.7	3.4	104.3
			11.3	81.5	5.1	2.0	7.7	82.9	4.7	84.1	1.8	85.2	-1.8	86.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.1	43.1	46.1	52.3	61.7	69.9	77.4	80.5	79.0	73.2	62.7	52.2	46.2
	DBStd	15.50	10.92	9.90	9.69	8.56	6.92	5.50	4.12	4.43	5.67	8.22	9.07	9.78
	HDD50	828	273	177	91	8	0	0	0	0	0	6	79	194
	HDD65	2960	683	535	408	165	35	2	0	0	7	142	395	588
	CDD50	5246	58	66	162	358	618	822	944	899	697	400	146	76
	CDD65	1904	3	4	14	65	188	374	479	434	254	72	12	5
	CDH74	18089	8	28	132	612	1709	3725	4994	4221	1995	570	76	19
	CDH80	7268	0	2	17	152	591	1629	2260	1808	673	129	7	0
(14) Wind	WSAvg	5.5	5.7	6.1	6.9	7.2	6.1	5.6	5.2	4.6	5.0	4.6	4.8	4.9
(15) Precipitation	PrecAvg	48.5	3.5	2.9	4.2	3.1	3.7	4.1	5.2	5.0	6.5	3.5	3.3	3.2
	PrecMax	63.7	6.5	6.9	6.5	5.2	7.7	11.8	9.4	12.1	27.9	9.4	8.8	7.6
	PrecMin	35.2	0.9	0.8	1.4	1.5	2.0	0.6	2.6	2.0	1.1	0.0	0.5	0.9
	PrecStd	8.0	1.7	1.5	1.4	1.3	1.5	2.4	1.5	2.5	5.9	2.2	2.1	1.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.4	78.8	82.1	88.2	92.9	97.9	98.9	98.8	92.7	88.3	81.0	77.0
		MCWB	63.4	64.1	64.7	67.0	71.9	75.0	77.8	77.9	73.9	72.6	67.2	66.0
	2%	DB	70.4	72.3	78.5	83.9	89.8	93.5	95.1	93.3	90.0	83.6	75.4	71.9
		MCWB	62.3	60.5	62.1	65.3	71.0	73.8	77.7	76.1	74.1	69.4	63.5	64.1
	5%	DB	64.4	67.9	73.1	81.2	86.2	91.1	92.9	91.1	87.5	80.8	72.4	67.5
		MCWB	58.0	59.0	59.5	64.6	69.7	74.5	76.3	75.9	72.8	68.0	63.2	62.7
	10%	DB	61.1	63.5	69.8	77.4	82.4	89.5	90.5	88.5	83.9	77.0	68.1	63.3
		MCWB	54.2	55.6	58.2	63.4	68.3	73.5	75.9	74.5	71.0	67.0	61.7	58.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.0	67.2	67.9	72.2	75.3	79.4	81.5	81.1	78.2	76.3	71.0	70.1
		MCDB	71.8	74.7	76.1	79.4	85.2	91.8	92.4	92.0	85.2	81.8	75.7	72.7
	2%	WB	63.3	64.2	65.3	69.4	73.4	77.5	79.8	79.3	76.7	73.4	67.9	65.9
		MCDB	67.4	69.0	73.1	77.8	83.1	88.7	90.9	88.9	84.4	79.4	72.7	70.1
	5%	WB	59.9	60.4	63.0	67.5	72.2	76.4	78.4	77.9	75.3	71.6	65.0	62.7
		MCDB	64.8	66.3	69.2	76.7	81.5	86.8	88.5	86.5	82.7	77.3	70.2	65.9
	10%	WB	55.7	55.8	60.4	65.4	70.8	75.2	77.3	76.7	73.9	69.2	62.0	58.6
		MCDB	59.9	62.5	68.0	74.5	79.3	84.7	86.5	84.8	80.5	74.7	67.3	63.2
(35) Mean Daily Temperature Range	5% DB	MDBR	19.3	21.0	22.4	22.8	20.8	19.8	18.6	18.6	18.8	21.8	22.3	19.9
		MCDBR	24.0	26.9	26.9	25.4	23.8	21.8	20.7	20.6	21.4	23.7	25.2	23.0
		MCWBR	17.6	17.5	14.7	11.7	9.4	7.8	7.8	7.4	8.8	11.9	15.3	16.6
	5% WB	MCDBR	21.9	24.3	22.1	21.2	19.7	19.6	18.7	18.2	16.6	18.1	20.0	20.6
		MCWBR	18.0	18.2	15.2	12.2	9.0	7.9	8.0	7.3	8.1	10.5	14.7	16.7
(40) Clear-Sky Solar Irradiance	taub		0.311	0.328	0.355	0.400	0.450	0.503	0.532	0.524	0.417	0.364	0.329	0.314
	taud		2.513	2.461	2.415	2.293	2.189	2.088	2.020	2.034	2.334	2.463	2.515	2.539
	Ebn at Noon		283	290	290	280	267	252	243	243	266	273	274	275
	Edh at Noon		26	30	35	41	47	51	55	53	37	30	26	24
(44) All-Sky Solar Radiation	RadAvg		813	1037	1363	1727	1905	2020	1927	1741	1438	1173	897	720
	RadStd		54	112	92	117	142	117	105	98	106	146	69	57

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	+1.71	N/A	N/A	N/A	N/A
(47) Regional (64 neighbors)	+0.79	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+281	+198

Nomenclature: See separate page