

PITT-GREENVILLE, NC, USA

WMO: 723065

Lat: 35.633N

Lon: 77.383W

Elev: 8

StdP: 101.23

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 13783

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -6.3	(c) -3.9	(d) -16.2	(e) 0.9	(f) -1.0	(g) -13.0	(h) 1.2	(i) 0.5	(j) 10.3	(k) 15.5	(l) 8.8	(m) 14.9	(n) 1.3	(o) 0	(p) 0.408

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	35.0	24.8	33.8	24.1	32.6	23.9	26.3	32.2	25.7	31.0	25.1	30.0	3.1	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.1	20.2	28.1	24.1	19.0	27.9	23.4	18.2	27.2	81.9	31.5	78.7	30.7	76.2	29.6	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.3	(b) 7.3	(c) 6.2	(e) -10.0	(f) 37.1	(g) 2.3	(h) 1.2	(i) -11.6	(j) 37.9	(k) -13.0	(l) 38.6	(m) -14.2	(n) 39.3	(o) -15.9	(p) 40.2		
(a) 8.3	(b) 7.3	(c) 6.2	(e) -11.5	(f) 27.5	(g) 2.8	(h) 1.1	(i) -13.5	(j) 28.3	(k) -15.2	(l) 28.9	(m) -16.8	(n) 29.5	(o) -18.8	(p) 30.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.7	6.1	7.8	11.3	16.5	21.1	25.2	26.9	26.1	22.9	17.1	11.2	7.9
	DBStd	8.61	6.07	5.50	5.38	4.76	3.84	3.05	2.29	2.46	3.15	4.57	5.04	5.43
	HDD10.0	460	152	98	51	4	0	0	0	0	0	3	44	108
	HDD18.3	1644	379	297	227	92	19	1	0	0	4	79	219	327
	CDD10.0	2914	32	37	90	199	343	457	524	499	387	222	81	42
	CDD18.3	1058	2	2	8	36	104	208	266	241	141	40	7	3
	CDH23.3	10049	4	16	73	340	949	2069	2774	2345	1108	317	42	11
	CDH26.7	4038	0	1	9	84	328	905	1256	1004	374	72	4	0
Wind	WSAvg	2.5	2.5	2.7	3.1	3.2	2.7	2.5	2.3	2.1	2.2	2.0	2.1	2.2
Precipitation	PrecAvg	1232	90	74	107	79	95	105	133	128	164	88	85	82
	PrecMax	1617	164	174	165	133	195	299	239	308	708	238	223	193
	PrecMin	893	23	21	35	37	51	15	66	52	29	0	13	23
	PrecStd	204	42	39	35	32	38	62	37	64	149	55	53	39
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.0	26.0	27.8	31.2	33.8	36.6	37.2	37.1	33.7	31.3	27.2	25.0
		MCWB	17.4	17.8	18.2	19.5	22.1	23.9	25.4	25.5	23.3	22.5	19.6	18.9
	2%	DB	21.3	22.4	25.8	28.9	32.1	34.1	35.0	34.1	32.2	28.6	24.1	22.2
		MCWB	16.8	15.8	16.7	18.5	21.7	23.2	25.4	24.5	23.4	20.8	17.5	17.8
	5%	DB	18.0	19.9	22.8	27.4	30.1	32.8	33.8	32.9	30.8	27.1	22.4	19.7
		MCWB	14.4	15.0	15.3	18.1	21.0	23.6	24.6	24.4	22.7	20.0	17.3	17.1
	10%	DB	16.2	17.5	21.0	25.2	28.0	32.0	32.5	31.4	28.8	25.0	20.0	17.4
		MCWB	12.3	13.1	14.6	17.4	20.2	23.1	24.4	23.6	21.7	19.4	16.5	14.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.5	19.5	19.9	22.3	24.1	26.3	27.5	27.3	25.7	24.6	21.7	21.2
		MCDB	22.1	23.7	24.5	26.3	29.5	33.2	33.6	33.3	29.5	27.7	24.3	22.6
	2%	WB	17.4	17.9	18.5	20.8	23.0	25.3	26.5	26.3	24.9	23.0	19.9	18.8
		MCDB	19.7	20.5	22.8	25.4	28.4	31.5	32.7	31.6	29.1	26.3	22.6	21.2
	5%	WB	15.5	15.8	17.2	19.7	22.4	24.7	25.8	25.5	24.0	22.0	18.3	17.1
		MCDB	18.2	19.1	20.7	24.9	27.5	30.5	31.4	30.3	28.2	25.2	21.2	18.8
	10%	WB	13.2	13.2	15.8	18.6	21.6	24.0	25.2	24.8	23.3	20.7	16.7	14.8
		MCDB	15.5	16.9	20.0	23.6	26.3	29.3	30.3	29.3	26.9	23.7	19.6	17.3
Mean Daily Temperature Range	5% DB	MDBR	10.7	11.7	12.4	12.7	11.5	11.0	10.3	10.3	10.4	12.1	12.4	11.1
		MCDBR	13.3	15.0	15.0	14.1	13.2	12.1	11.5	11.5	11.9	13.2	14.0	12.8
		MCWBR	9.8	9.7	8.1	6.5	5.2	4.3	4.3	4.1	4.9	6.6	8.5	9.2
	5% WB	MCDBR	12.2	13.5	12.3	11.8	10.9	10.9	10.4	10.1	9.2	10.1	11.1	11.4
		MCWBR	10.0	10.1	8.5	6.8	5.0	4.4	4.4	4.0	4.5	5.8	8.2	9.3
Clear-Sky Solar Irradiance	taub		0.311	0.328	0.355	0.400	0.450	0.503	0.532	0.524	0.417	0.364	0.329	0.314
	taud		2.513	2.461	2.415	2.293	2.189	2.088	2.020	2.034	2.334	2.463	2.515	2.539
	Ebn at Noon		893	914	914	884	841	794	767	765	839	862	863	866
	Edh at Noon		81	96	110	130	147	162	172	167	118	95	81	75
All-Sky Solar Radiation	RadAvg		2.56	3.27	4.30	5.45	6.00	6.37	6.07	5.49	4.53	3.70	2.83	2.27
	RadStd		0.17	0.35	0.29	0.37	0.45	0.37	0.33	0.31	0.33	0.46	0.22	0.18

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (64 neighbors)	+0.44	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+156	+110

Nomenclature: See separate page