

ORANGEBURG, SC, USA

WMO: 723115

Lat: 33.462N

Lon: 80.858W

Elev: 60

StdP: 100.61

Time Zone: -5.00 (NAE)

Period: 99-19

WBAN: 53854

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.9	-2.2	-14.0	1.1	1.2	-11.6	1.4	3.7	10.1	13.8	8.9	13.4	1.5	10	0.383

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	35.5	24.4	34.1	24.2	33.0	23.9	26.1	32.1	25.6	31.4	25.1	30.7	3.6	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.5	19.6	28.3	24.0	19.0	27.7	23.6	18.5	27.3	81.0	31.9	78.5	31.6	76.5	30.8	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.3	7.3	6.1	-6.9	37.2	2.0	1.4	-8.3	38.2	-9.5	39.0	-10.6	39.8	-12.1	40.8		
			-8.3	27.0	1.7	0.8	-9.5	27.6	-10.5	28.0	-11.5	28.5	-12.7	29.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.3	8.3	10.2	13.8	18.1	22.3	26.1	27.4	27.1	24.3	18.8	13.1	9.9
	DBStd	7.86	5.58	4.87	4.79	3.92	3.13	2.13	1.75	1.83	2.72	4.12	4.54	5.12
	HDD10.0	262	102	53	19	1	0	0	0	0	1	19	67	67
	HDD18.3	1229	313	231	153	51	7	0	0	0	1	45	164	265
	CDD10.0	3306	49	58	138	246	382	482	541	530	429	273	113	64
	CDD18.3	1231	2	3	13	45	131	232	282	272	181	59	9	3
	CDH23.3	11329	9	23	131	458	1211	2196	2823	2543	1424	440	60	13
	CDH26.7	4777	0	1	19	118	453	1010	1361	1153	554	104	4	0
(14) Wind	WSAvg	2.5	2.8	2.9	3.0	3.0	2.6	2.3	2.2	2.0	2.3	2.2	2.3	2.5
(15) Precipitation	PrecAvg	1211	110	97	111	76	95	127	146	134	100	76	66	80
	PrecMax	1815	222	201	258	273	249	276	353	344	304	441	259	170
	PrecMin	792	16	28	18	4	1	18	40	24	0	0	6	10
	PrecStd	219	49	44	58	52	61	58	77	72	64	77	49	37
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.7	26.2	28.8	31.3	34.9	36.7	37.2	36.6	34.4	31.2	27.3	25.1
		MCWB	17.9	18.1	17.8	19.7	22.3	23.9	24.8	25.5	22.7	22.9	19.7	19.3
	2%	DB	22.0	23.4	26.8	29.6	32.5	34.8	35.7	34.6	32.7	29.2	25.2	22.7
		MCWB	16.3	16.5	17.4	19.3	21.5	23.9	24.8	24.9	23.0	21.2	18.2	18.0
	5%	DB	19.7	21.3	24.6	27.9	31.1	33.2	34.1	33.4	31.5	27.6	23.0	20.7
		MCWB	15.1	14.9	16.2	18.7	21.1	23.6	24.6	24.6	22.7	20.2	16.9	17.1
	10%	DB	17.4	18.9	22.5	26.2	29.1	32.1	32.8	32.3	30.1	25.9	21.3	18.7
		MCWB	13.8	14.0	15.2	17.8	20.7	23.2	24.5	24.3	22.5	19.6	16.7	15.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.3	19.4	20.1	22.4	24.1	25.8	27.1	27.0	25.3	24.5	21.7	21.1
		MCDB	22.1	23.6	25.1	27.4	30.2	32.2	33.4	33.1	30.0	28.0	24.2	23.3
	2%	WB	18.0	18.1	18.9	21.3	23.1	25.2	26.2	26.2	24.7	23.5	20.3	19.4
		MCDB	20.9	21.8	23.7	26.3	28.7	31.7	32.4	32.0	29.2	26.8	22.7	21.5
	5%	WB	16.5	16.7	17.9	20.3	22.5	24.7	25.6	25.6	24.2	22.5	19.1	17.9
		MCDB	18.9	20.1	22.2	25.3	27.9	30.6	31.8	31.1	28.5	25.6	21.7	19.9
	10%	WB	14.6	14.9	16.8	19.3	21.8	24.1	25.1	25.1	23.6	21.3	17.6	16.1
		MCDB	16.9	18.0	20.8	24.0	27.0	29.6	31.0	30.2	27.6	24.3	20.5	18.6
(35) Mean Daily Temperature Range	5% DB	MDBR	11.4	12.0	12.6	13.0	12.2	10.9	10.6	10.0	10.3	11.7	12.5	11.3
		MCDBR	13.4	14.4	14.9	14.9	14.3	12.8	12.2	11.7	12.1	12.6	13.9	12.7
		MCWBR	8.5	8.6	7.0	6.2	5.0	4.1	3.8	3.6	4.1	5.7	7.9	8.7
	5% WB	MCDBR	11.0	12.6	12.3	11.8	11.3	10.8	10.9	10.4	9.7	9.3	10.3	10.8
		MCWBR	8.1	8.7	7.0	5.9	4.4	4.0	3.9	3.7	3.8	5.0	7.1	8.5
(40) Clear-Sky Solar Irradiance	taub		0.325	0.333	0.369	0.405	0.474	0.512	0.552	0.523	0.437	0.402	0.348	0.321
	taud		2.492	2.464	2.391	2.283	2.135	2.072	1.983	2.055	2.285	2.345	2.464	2.539
	Ebn at Noon		890	918	907	884	823	789	754	770	827	829	853	874
	Edh at Noon		86	98	114	133	156	165	180	165	126	109	88	78
(44) All-Sky Solar Radiation	RadAvg		2.83	3.46	4.54	5.73	6.18	6.36	6.12	5.54	4.77	4.04	3.11	2.49
	RadStd		0.15	0.35	0.34	0.39	0.46	0.44	0.41	0.29	0.41	0.48	0.23	0.22

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.59	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (54 neighbors)		+0.56	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+193	+135

Nomenclature: See separate page