

OCCONEE COUNTY AP, SC, USA

WMO: 723118

Lat: 34.672N

Lon: 82.886W

Elev: 891

StdP: 14.23

Time Zone: -5.00 (NAE)

Period: 01-19

WBAN: 53850

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.8	28.1	2.7	6.5	33.1	6.7	8.0	35.9	23.3	48.4	19.8	46.5	5.4	260	0.358

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.7	95.3	74.0	92.9	73.4	90.7	73.2	77.3	88.2	76.4	86.9	75.5	85.4	5.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.3	132.7	81.0	73.3	128.0	80.3	72.6	124.8	79.8	41.2	88.2	40.3	87.0	39.5	85.9	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.1	15.3	12.3	DB	17.9	97.8	4.1	4.2	14.9	100.8	12.5	103.3	10.2	105.7	7.3	108.8
			WB	14.6	79.0	3.7	1.5	12.0	80.1	9.8	81.0	7.7	81.9	5.1	83.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.4	44.4	47.6	55.2	63.2	70.8	78.1	80.5	79.9	74.8	64.0	53.9	47.6
	DBStd	14.59	9.17	8.38	8.68	7.09	6.07	4.37	3.64	3.88	5.22	7.27	7.67	8.10
	HDD50	605	224	133	49	4	0	0	0	0	0	3	46	146
	HDD65	2580	639	489	322	114	24	0	0	0	4	106	340	542
	CDD50	5498	49	66	208	401	644	843	946	926	745	436	163	71
	CDD65	1999	0	2	16	61	203	394	481	461	298	75	6	2
	CDH74	17703	2	5	142	567	1596	3660	4711	4247	2241	496	33	3
	CDH80	7092	0	0	24	117	494	1576	2127	1817	831	105	1	0
(14) Wind	WSAvg	4.8	5.6	5.8	5.8	5.5	4.6	4.3	4.1	3.7	4.2	4.5	4.3	5.0
(15) Precipitation	PrecAvg	53.9	5.2	4.9	5.7	4.1	4.1	4.2	4.5	4.8	3.9	3.9	4.0	4.6
	PrecMax	72.6	9.6	10.6	13.6	13.1	10.1	9.7	11.5	11.4	9.4	8.2	9.3	10.8
	PrecMin	35.9	0.6	0.7	1.0	0.8	0.2	0.3	0.9	0.4	0.2	0.0	1.0	0.6
	PrecStd	8.9	2.0	2.2	2.8	2.5	1.9	2.1	2.9	2.6	2.2	2.3	1.7	2.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.7	74.4	83.4	87.1	91.4	97.1	98.2	98.9	94.0	87.3	78.5	72.9
		MCWB	58.7	59.9	62.3	66.2	70.2	73.7	75.0	73.2	70.5	70.0	62.8	61.4
	2%	DB	66.1	69.8	78.1	83.3	88.2	94.3	95.0	94.5	91.1	82.7	73.5	68.4
		MCWB	56.2	56.7	60.2	64.2	68.9	73.3	75.0	73.8	71.1	67.6	60.2	60.2
	5%	DB	62.7	65.6	73.5	80.6	85.4	91.2	92.4	91.5	88.0	79.4	70.4	64.3
		MCWB	54.9	54.4	58.0	63.3	68.5	72.5	74.6	73.8	71.1	65.3	59.2	57.0
	10%	DB	58.6	61.8	70.0	77.1	82.4	88.4	90.1	89.0	85.0	76.1	66.9	60.7
		MCWB	51.2	52.1	57.0	61.2	67.7	72.1	74.3	73.8	70.4	64.3	57.2	54.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	62.8	64.2	65.2	69.8	73.6	77.3	78.4	78.3	75.6	75.5	69.4	66.4
		MCDB	67.5	69.9	75.7	81.1	83.9	89.8	90.4	89.0	85.2	80.1	71.3	69.7
	2%	WB	59.7	61.4	63.4	67.8	72.1	75.9	77.4	77.3	74.6	71.6	65.1	62.3
		MCDB	64.2	66.7	73.5	78.1	82.4	88.0	89.0	87.2	83.5	78.2	69.4	66.6
	5%	WB	56.4	57.7	61.5	65.9	70.9	74.9	76.6	76.3	73.4	69.4	62.6	59.0
		MCDB	60.9	63.3	70.0	75.3	80.8	86.4	87.7	85.7	81.6	75.3	67.1	62.9
	10%	WB	53.1	53.8	59.3	64.1	69.6	73.9	75.7	75.3	72.3	66.9	59.6	55.2
		MCDB	56.7	59.1	66.7	72.7	78.9	84.4	86.1	84.2	80.1	73.4	65.0	58.9
(35) Mean Daily Temperature Range	5% DB	MDBR	17.8	18.3	19.8	20.5	18.9	18.5	17.7	17.0	17.0	18.7	19.5	16.4
		MCDBR	21.0	22.2	24.2	24.5	22.4	22.0	20.9	20.7	21.1	21.3	23.1	19.4
		MCWBR	13.4	13.4	11.4	10.1	8.1	7.0	6.1	6.1	6.4	8.9	12.0	12.1
	5% WB	MCDBR	16.4	18.1	19.5	19.9	18.3	18.7	18.4	17.1	16.3	16.4	16.2	15.0
		MCWBR	12.5	13.6	11.3	9.6	7.9	7.2	6.5	6.2	6.3	9.0	11.7	11.6
(40) Clear-Sky Solar Irradiance	taub		0.311	0.321	0.357	0.395	0.457	0.482	0.526	0.520	0.419	0.381	0.337	0.309
	taud		2.511	2.482	2.409	2.301	2.158	2.129	2.030	2.030	2.297	2.383	2.464	2.548
	Ebn at Noon		285	294	290	283	265	257	245	244	266	268	272	279
	Edh at Noon		26	30	35	41	48	49	54	53	39	33	27	24
(44) All-Sky Solar Radiation	RadAvg		844	1038	1379	1724	1906	2006	1890	1747	1504	1252	939	723
	RadStd		50	123	93	119	144	146	125	89	138	142	92	72

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (44 neighbors)	+0.97	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+295	+205

Nomenclature: See separate page