

OCCONEE COUNTY AP, SC, USA

WMO: 723118

Lat: 34.672N

Lon: 82.886W

Elev: 272

StdP: 98.10

Time Zone: -5.00 (NAE)

Period: 01-19

WBAN: 53850

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -4.0	(c) -2.2	(d) -16.3	(e) 0.9	(f) 0.6	(g) -14.0	(h) 1.1	(i) 2.2	(j) 10.4	(k) 9.1	(l) 8.9	(m) 8.1	(n) 2.4	(o) 260	(p) 0.358

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	35.2	23.3	33.8	23.0	32.6	22.9	25.2	31.2	24.7	30.5	24.1	29.7	2.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.5	19.0	27.2	23.0	18.3	26.9	22.5	17.8	26.5	77.8	31.2	75.8	30.5	73.9	30.0	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.1	6.8	5.5	-7.9	36.5	2.3	2.4	-9.5	38.2	-10.8	39.6	-12.1	40.9	-13.7	42.7
			-9.7	26.1	2.0	0.9	-11.1	26.7	-12.3	27.2	-13.5	27.7	-15.0	28.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.5	6.9	8.7	12.9	17.4	21.5	25.6	27.0	26.6	23.8	17.8	12.2	8.7		
	DBStd	8.10	5.09	4.66	4.82	3.94	3.37	2.43	2.02	2.16	2.90	4.04	4.26	4.50		
	HDD10.0	336	124	74	27	2	0	0	0	0	2	26	81			
	HDD18.3	1433	355	272	179	63	13	0	0	0	59	189	301			
	CDD10.0	3054	27	37	116	223	358	468	526	514	414	242	91	39		
	CDD18.3	1111	0	1	9	34	113	219	267	256	166	42	3	1		
	CDH23.3	9835	1	3	79	315	887	2033	2617	2359	1245	276	18	2		
	CDH26.7	3940	0	0	13	65	274	876	1182	1009	462	58	1	0		
(14) Wind	WSAvg	2.1	2.5	2.6	2.6	2.5	2.1	1.9	1.8	1.6	1.9	2.0	1.9	2.2		
(15) Precipitation	PrecAvg	1370	131	124	145	103	104	107	114	121	98	99	102	118		
	PrecMax	1843	245	270	346	332	257	246	292	289	240	208	235	274		
	PrecMin	913	16	17	26	20	4	8	23	9	4	0	25	15		
	PrecStd	227	52	56	70	64	48	54	74	66	55	58	44	57		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.0	23.5	28.5	30.6	33.0	36.2	36.8	37.2	34.4	30.7	25.8	22.7		
		MCWB	14.8	15.5	16.8	19.0	21.2	23.2	23.9	22.9	21.4	21.1	17.1	16.3		
	2%	DB	19.0	21.0	25.6	28.5	31.2	34.6	35.0	34.7	32.8	28.2	23.1	20.2		
		MCWB	13.5	13.7	15.7	17.9	20.5	22.9	23.9	23.2	21.7	19.8	15.7	15.7		
	5%	DB	17.1	18.7	23.1	27.0	29.7	32.9	33.6	33.0	31.1	26.3	21.3	18.0		
		MCWB	12.7	12.4	14.5	17.4	20.3	22.5	23.7	23.2	21.7	18.5	15.1	13.9		
	10%	DB	14.8	16.5	21.1	25.1	28.0	31.3	32.3	31.7	29.4	24.5	19.4	16.0		
		MCWB	10.7	11.2	13.9	16.2	19.8	22.3	23.5	23.2	21.3	18.0	14.0	12.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.1	17.9	18.4	21.0	23.1	25.2	25.8	25.7	24.2	24.2	20.8	19.1		
		MCDB	19.7	21.1	24.3	27.3	28.9	32.1	32.5	31.6	29.5	26.7	21.9	21.0		
	2%	WB	15.4	16.3	17.4	19.9	22.3	24.4	25.2	25.1	23.6	22.0	18.4	16.8		
		MCDB	17.9	19.3	23.1	25.6	28.0	31.1	31.7	30.7	28.6	25.6	20.8	19.2		
	5%	WB	13.6	14.3	16.4	18.9	21.6	23.8	24.8	24.6	23.0	20.8	17.0	15.0		
		MCDB	16.0	17.4	21.1	24.1	27.1	30.2	30.9	29.8	27.6	24.1	19.5	17.2		
	10%	WB	11.7	12.1	15.1	17.8	20.9	23.3	24.3	24.1	22.4	19.4	15.3	12.9		
		MCDB	13.7	15.0	19.3	22.6	26.1	29.1	30.1	29.0	26.7	23.0	18.3	14.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.9	10.2	11.0	11.4	10.5	10.3	9.9	9.5	9.4	10.4	10.8	9.1		
		MCDBR	11.7	12.3	13.4	13.6	12.4	12.2	11.6	11.5	11.7	11.8	12.9	10.8		
	5% WB	MCWBR	7.4	7.5	6.3	5.6	4.5	3.9	3.4	3.4	3.5	5.0	6.6	6.7		
		MCWBR	9.1	10.1	10.8	11.1	10.2	10.4	10.2	9.5	9.1	9.1	9.0	8.3		
(40) Clear-Sky Solar Irradiance	taub		0.311	0.321	0.357	0.395	0.457	0.482	0.526	0.520	0.419	0.381	0.337	0.309		
	taud		2.511	2.482	2.409	2.301	2.158	2.129	2.030	2.030	2.297	2.383	2.464	2.548		
	Ebn at Noon		899	928	915	891	836	811	773	769	840	846	858	881		
	Edh at Noon		83	95	111	130	152	156	171	168	123	104	86	76		
(44) All-Sky Solar Radiation	RadAvg		2.66	3.27	4.35	5.43	6.01	6.32	5.96	5.51	4.74	3.95	2.96	2.28		
	RadStd		0.16	0.39	0.29	0.38	0.45	0.46	0.39	0.28	0.43	0.45	0.29	0.23		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (44 neighbors)	+0.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+164	+114

Nomenclature: See separate page