

FRISCO MITCHELL, NC, USA

WMO: 723139

Lat: 35.233N

Lon: 75.622W

Elev: 3

StdP: 101.28

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 93729

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.5	-0.7	-11.9	1.3	-0.2	-9.4	1.7	1.4	12.5	16.1	11.2	14.1	3.9	320	0.459

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.5	31.1	25.7	30.3	25.4	29.6	25.1	26.9	29.3	26.5	28.9	26.0	28.4	4.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	21.7	28.4	25.7	21.0	28.1	25.2	20.4	27.8	84.7	29.7	82.4	29.0	80.5	28.4	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.8	9.1	8.2	-5.4	32.7	2.5	1.6	-7.2	33.8	-8.6	34.8	-10.0	35.7	-11.8	36.9		
			-6.8	27.8	2.2	0.7	-8.4	28.3	-9.7	28.7	-10.9	29.1	-12.5	29.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.6	8.0	8.8	11.4	16.1	20.4	24.7	26.6	26.4	24.2	19.5	14.0	10.7
	DBStd	7.61	5.20	4.54	4.29	3.79	3.27	2.39	1.62	1.74	2.34	3.80	4.18	4.76
	HDD10.0	271	102	69	36	2	0	0	0	0	0	12	50	
	HDD18.3	1323	321	267	219	87	18	1	0	1	32	138	239	
	CDD10.0	3045	39	37	78	184	321	440	514	508	426	294	133	72
	CDD18.3	1055	1	1	2	19	81	191	256	250	176	67	9	3
	CDH23.3	8006	0	0	1	31	298	1434	2456	2352	1151	270	10	3
	CDH26.7	1727	0	0	0	1	26	269	608	606	192	24	0	2
Wind	WSAvg	4.2	4.3	4.4	4.6	4.8	4.4	4.1	4.0	3.6	4.0	3.9	3.9	4.2
Precipitation	PrecAvg	1457	148	109	113	86	99	112	134	157	139	123	114	119
	PrecMax	2307	316	246	284	252	297	320	304	355	508	333	364	274
	PrecMin	748	47	27	19	7	12	22	26	14	7	14	22	19
	PrecStd	277	65	49	67	52	70	64	71	94	89	80	74	55
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.5	21.4	22.5	26.0	28.8	31.3	32.1	32.0	30.9	28.9	24.6	22.7
		MCWB	18.3	18.0	18.5	21.2	23.4	25.2	26.0	26.2	25.1	24.4	21.3	20.6
	2%	DB	19.0	19.2	20.8	24.1	27.2	30.0	31.0	31.0	29.6	27.1	23.1	21.1
		MCWB	17.2	16.8	17.8	19.9	22.4	24.9	25.8	25.8	24.7	23.2	20.6	18.9
	5%	DB	17.7	17.7	19.5	22.8	26.1	29.1	30.2	30.3	28.6	25.9	21.8	19.8
		MCWB	15.8	15.6	16.7	19.2	21.8	24.5	25.5	25.5	24.3	22.6	19.2	17.8
	10%	DB	16.2	16.2	18.2	21.5	25.0	28.2	29.5	29.5	27.8	24.9	20.5	18.3
		MCWB	14.4	14.0	15.7	18.3	21.3	24.1	25.2	25.1	24.1	21.9	18.2	16.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.9	18.9	19.7	22.3	24.7	26.8	27.7	27.9	26.9	25.5	22.6	21.2
		MCDB	19.9	20.6	21.3	24.4	27.5	29.3	30.3	30.0	28.2	27.3	23.9	22.8
	2%	WB	17.6	17.5	18.5	21.1	23.6	25.8	26.9	27.1	26.0	24.5	21.3	19.4
		MCDB	18.8	18.9	20.1	23.1	26.0	28.5	29.4	29.5	28.0	26.3	22.6	20.6
	5%	WB	16.2	16.0	17.5	20.0	22.8	25.3	26.5	26.6	25.5	23.5	19.8	18.1
		MCDB	17.5	17.4	19.1	22.2	25.1	28.0	28.9	29.0	27.7	25.4	21.3	19.4
	10%	WB	14.6	14.2	16.1	18.9	22.0	24.9	26.0	26.1	24.9	22.4	18.5	16.7
		MCDB	16.0	15.9	18.0	21.0	24.2	27.4	28.4	28.5	27.1	24.3	20.1	18.2
Mean Daily Temperature Range	5% DB	MDBR	7.2	7.4	7.2	6.9	6.4	5.9	5.5	5.7	5.6	6.4	6.8	6.7
		MCDBR	8.7	8.4	8.2	7.3	6.9	6.5	6.0	6.0	6.1	6.4	7.4	7.6
		MCWBR	7.9	7.4	6.4	4.6	3.9	3.4	3.1	3.0	3.2	3.9	5.8	6.8
	5% WB	MCDBR	7.8	8.3	7.2	6.2	5.9	5.5	5.3	5.2	5.1	5.4	6.7	7.3
		MCWBR	7.7	7.8	6.4	4.7	3.7	3.2	3.2	3.0	3.3	4.3	6.2	7.1
Clear-Sky Solar Irradiance	taub	0.333	0.339	0.361	0.403	0.445	0.484	0.510	0.496	0.424	0.372	0.345	0.340	
	taud	2.529	2.510	2.467	2.355	2.277	2.217	2.155	2.188	2.393	2.514	2.540	2.530	
	Ebn at Noon	870	905	911	883	846	810	786	789	835	857	849	838	
	Edh at Noon	82	92	105	123	135	143	151	144	112	91	80	77	
All-Sky Solar Radiation	RadAvg	2.40	3.18	4.24	5.42	6.11	6.41	5.98	5.50	4.56	3.75	2.71	2.18	
	RadStd	0.16	0.33	0.34	0.42	0.42	0.32	0.35	0.36	0.28	0.35	0.19	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+153	+89
(47)	Regional (29 neighbors)	+0.42	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+162	+109

Nomenclature: See separate page