

MOORE COUNTY AP, NC, USA

WMO: 723143

Lat: 35.237N

Lon: 79.391W

Elev: 461

StdP: 14.45

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 03720

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.7	22.7	-2.1	5.0	29.6	3.0	6.5	32.2	20.3	58.2	18.5	56.9	2.4	20	0.407

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.3	95.2	75.4	92.7	74.4	90.5	73.9	78.1	89.7	77.1	88.2	76.1	86.3	7.3	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.1	133.8	82.1	73.7	127.8	81.2	73.0	124.6	80.7	41.8	89.7	40.7	88.2	39.8	86.5	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.7	15.6	12.9	10.4	100.4	4.8	5.5	7.0	104.4	4.2	107.6	1.5	110.7	-2.0	114.7
			9.5	79.4	4.9	1.5	6.0	80.5	3.1	81.4	0.4	82.2	-3.2	83.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.2	41.9	45.0	51.7	61.2	69.4	76.5	79.8	78.3	72.3	61.5	51.0	44.9
	DBStd	15.61	10.82	9.78	9.48	8.36	7.17	5.52	4.00	4.71	5.87	8.24	8.97	9.59
	HDD50	929	299	199	95	10	0	0	0	0	0	9	96	221
	HDD65	3150	718	564	423	170	42	3	0	0	11	166	427	626
	CDD50	5015	46	58	148	345	601	794	923	876	670	366	125	63
	CDD65	1764	1	3	11	56	178	347	458	411	232	58	6	3
	CDH74	16351	2	18	109	537	1650	3345	4488	3852	1840	466	37	7
	CDH80	6742	0	1	12	123	578	1482	2080	1702	657	105	2	0
Wind	WSAvg	5.6	5.7	6.0	6.6	7.4	6.1	5.6	5.2	4.6	5.1	4.8	5.0	5.1
Precipitation	PrecAvg	46.8	3.7	3.3	4.1	3.2	3.1	4.6	5.1	5.0	5.0	3.3	3.1	3.2
	PrecMax	62.3	6.7	6.4	7.3	6.1	7.2	12.5	8.8	10.0	14.8	9.1	8.4	6.8
	PrecMin	33.0	0.9	1.6	1.2	1.0	1.3	0.8	1.9	1.3	1.3	0.0	0.7	1.5
	PrecStd	6.5	1.8	1.4	1.6	1.3	1.4	2.8	2.2	1.9	3.2	2.4	2.0	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.4	76.9	81.5	87.7	93.2	97.4	98.7	99.0	92.8	87.6	78.8	74.5
		MCWB	61.5	63.6	62.8	66.4	71.5	74.2	76.5	75.7	71.9	73.5	65.2	64.5
	2%	DB	67.8	71.5	77.0	83.6	89.9	93.3	94.8	94.3	90.1	82.3	73.4	70.0
		MCWB	59.6	59.0	61.0	65.3	70.4	73.5	76.3	75.2	72.2	68.4	61.9	62.6
	5%	DB	63.7	66.0	72.6	80.8	86.3	90.8	92.4	91.1	87.6	79.2	70.5	65.6
		MCWB	57.1	56.6	58.0	63.1	69.4	73.2	75.4	74.8	72.1	66.5	61.0	60.6
	10%	DB	60.6	62.7	68.0	76.6	82.4	88.4	90.2	89.5	83.8	75.2	66.2	61.5
		MCWB	53.7	53.7	55.8	61.9	67.8	72.5	75.0	74.5	70.6	65.6	59.3	55.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.0	66.2	66.1	71.5	75.3	77.8	80.0	79.2	77.4	75.7	69.5	67.5
		MCDB	69.0	73.0	76.2	78.1	84.8	90.4	92.8	91.1	86.0	81.1	73.0	71.2
	2%	WB	61.8	62.6	63.4	68.4	73.1	76.4	78.3	78.0	75.6	73.3	65.9	64.1
		MCDB	66.6	67.9	71.6	77.6	83.3	88.4	90.4	89.3	84.3	79.6	70.9	67.6
	5%	WB	58.6	58.9	61.5	66.3	71.5	75.2	77.3	76.9	74.3	70.2	63.1	60.5
		MCDB	63.2	65.3	69.5	76.2	82.1	86.3	88.9	87.5	82.5	75.9	67.8	64.5
	10%	WB	54.2	54.4	58.9	64.1	70.1	74.1	76.3	75.7	72.8	67.5	60.0	56.5
		MCDB	58.9	60.3	66.4	73.3	79.4	84.5	86.9	85.0	80.3	73.9	66.0	61.1
Mean Daily Temperature Range	5% DB	MDBR	20.3	21.5	22.8	23.1	21.8	20.3	19.3	19.1	19.4	22.2	23.1	20.4
		MCDBR	24.0	26.0	26.9	26.1	24.5	23.5	21.8	22.0	23.3	24.7	25.5	22.6
		MCWBR	17.1	17.2	14.6	12.0	9.4	8.3	8.1	7.7	9.8	13.2	16.4	16.2
	5% WB	MCDBR	20.7	24.0	22.4	21.5	20.3	20.2	19.7	19.4	18.4	17.7	20.6	19.7
		MCWBR	16.8	18.1	15.2	11.8	8.7	8.0	8.0	7.4	8.6	10.6	15.6	16.5
Clear-Sky Solar Irradiance	taub	0.315	0.327	0.362	0.401	0.457	0.490	0.539	0.515	0.426	0.388	0.334	0.312	
	taud	2.500	2.458	2.395	2.283	2.169	2.113	1.998	2.054	2.297	2.371	2.485	2.541	
	Ebn at Noon	282	291	288	280	265	255	242	245	264	265	272	277	
	Edh at Noon	26	31	36	42	48	50	56	52	39	33	27	24	
All-Sky Solar Radiation	RadAvg	836	1045	1383	1734	1911	2023	1911	1735	1467	1199	917	724	
	RadStd	52	123	101	123	153	143	120	83	127	156	73	61	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (67 neighbors)	+0.79	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+277	+202	

Nomenclature: See separate page