

BACON COUNTY AP, GA, USA

WMO: 723160

Lat: 31.536N

Lon: 82.507W

Elev: 59

StdP: 100.62

Time Zone: -5.00 (NAE)

Period: 00-19

WBAN: 13870

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.7	-1.0	-11.8	1.4	2.6	-9.0	1.8	3.9	9.2	11.5	8.3	11.3	1.3	310	0.353

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	35.5	24.4	34.4	24.2	33.5	24.0	26.2	32.2	25.7	31.5	25.3	30.9	2.8	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.7	19.8	28.3	24.1	19.2	27.8	23.8	18.8	27.5	81.3	32.2	79.2	31.7	77.6	31.0	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.5	6.4	5.4	-5.7	37.2	1.9	1.8	-7.0	38.5	-8.1	39.5	-9.2	40.5	-10.6	41.8
			-6.9	27.1	1.8	0.7	-8.2	27.6	-9.3	28.0	-10.3	28.4	-11.6	28.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	19.7	10.3	12.3	15.5	19.3	23.4	26.7	27.8	27.7	25.4	20.3	14.9	11.9	(6)
(7)		DBStd	7.28	5.37	4.87	4.55	3.56	2.87	1.69	1.44	1.47	2.26	3.91	4.42	5.18	(7)
(8)		HDD10.0	149	64	28	9	1	0	0	0	0	0	1	9	39	(8)
(9)		HDD18.3	926	252	176	110	31	3	0	0	0	1	26	121	207	(9)
(10)		CDD10.0	3672	74	92	179	278	414	501	551	547	462	321	155	98	(10)
(11)		CDD18.3	1407	3	7	21	59	159	251	292	289	212	88	17	8	(11)
(12)		CDH23.3	13253	22	53	211	638	1590	2424	2934	2777	1773	672	122	36	(12)
(13)		CDH26.7	5733	1	4	36	179	670	1159	1432	1306	748	183	14	1	(13)
(14)	Wind	WSAvg	2.1	2.4	2.4	2.5	2.4	2.2	2.0	1.8	1.7	1.7	1.8	1.9	2.1	(14)
(15)	Precipitation	PrecAvg	1185	95	95	112	72	74	138	131	146	109	79	59	76	(15)
(16)		PrecMax	1554	358	240	263	198	173	223	237	246	374	253	166	193	(16)
(17)		PrecMin	875	13	16	4	6	12	46	20	67	20	6	1	8	(17)
(18)		PrecStd	202	68	52	67	46	41	50	55	40	67	65	46	45	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.9	27.4	29.3	32.0	35.2	36.5	36.4	36.8	34.9	32.3	28.2	26.3	(19)
(20)			MCWB	19.1	19.5	19.1	20.9	22.1	23.4	24.8	24.9	23.0	23.7	20.5	19.8	(20)
(21)		2%	DB	23.4	25.1	27.7	30.3	33.3	34.9	35.2	35.1	33.3	30.4	26.6	24.3	(21)
(22)			MCWB	17.8	18.0	18.6	20.1	21.6	23.9	24.7	25.0	23.4	22.2	19.6	18.8	(22)
(23)		5%	DB	21.2	22.9	25.9	28.8	32.0	33.7	34.2	33.9	32.2	28.8	24.6	22.3	(23)
(24)			MCWB	16.6	16.7	17.8	19.3	21.4	23.7	24.6	24.8	23.4	21.1	18.6	18.6	(24)
(25)		10%	DB	19.0	20.8	23.9	27.3	30.5	32.5	33.1	32.7	31.0	27.3	22.8	20.4	(25)
(26)			MCWB	15.6	15.6	16.6	18.4	21.1	23.6	24.5	24.7	23.3	20.5	18.0	17.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.3	20.6	21.4	22.9	24.4	26.3	26.9	26.9	25.8	25.0	23.5	21.9	(27)
(28)			MADB	23.5	24.7	25.6	28.4	30.1	32.7	32.8	33.2	30.8	29.4	25.8	23.8	(28)
(29)		2%	WB	19.0	19.5	20.2	21.9	23.6	25.6	26.2	26.2	25.2	24.0	21.9	20.5	(29)
(30)			MADB	21.7	23.2	24.7	27.2	29.1	31.7	32.4	32.0	30.2	27.6	23.7	22.3	(30)
(31)		5%	WB	17.9	18.3	19.2	21.0	22.9	25.1	25.7	25.7	24.7	23.2	20.6	19.3	(31)
(32)			MADB	20.4	21.8	23.5	26.1	28.3	30.9	31.7	31.3	29.3	26.6	23.3	21.5	(32)
(33)		10%	WB	16.5	16.9	18.1	20.1	22.3	24.5	25.2	25.4	24.2	22.3	19.0	17.9	(33)
(34)			MADB	19.1	19.7	22.2	24.8	27.7	29.9	31.0	30.8	28.5	25.5	21.9	20.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.2	12.4	13.1	13.7	13.0	11.2	11.0	10.5	10.7	12.2	13.2	11.8	(35)
(36)			MCDBR	13.4	13.8	14.9	15.2	14.5	13.0	12.3	12.1	12.4	12.9	13.8	12.3	(36)
(37)			MCWBR	8.3	7.9	6.9	6.1	4.8	4.1	3.8	3.7	4.3	5.7	7.5	7.7	(37)
(38)		5% WB	MCDDBR	11.3	11.5	11.9	12.3	11.6	10.8	10.8	10.5	9.9	9.9	10.0	10.3	(38)
(39)			MCWBR	8.0	7.5	6.6	5.8	4.4	4.0	3.8	3.8	3.8	4.8	6.5	7.4	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.327	0.333	0.371	0.389	0.431	0.478	0.511	0.504	0.425	0.380	0.348	0.332	(40)
(41)		taud		2.509	2.491	2.405	2.350	2.269	2.199	2.110	2.131	2.346	2.440	2.478	2.522	(41)
(42)		Ebn at Noon		900	927	910	902	863	817	789	789	845	863	866	874	(42)
(43)		Edh at Noon		87	97	114	125	137	146	159	154	120	101	89	82	(43)
(44)	All-Sky Solar Radiation	RadAvg		3.01	3.62	4.75	5.81	6.38	6.16	6.11	5.54	4.83	4.20	3.34	2.62	(44)
(45)		RadStd		0.18	0.40	0.44	0.43	0.36	0.41	0.38	0.36	0.39	0.40	0.23	0.24	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.74	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+217	+156
(47)	Regional (33 neighbors)	+0.53	+0.74	N/A	N/A	N/A	N/A	N/A	-79	+174	+122

Nomenclature: See separate page