

EDWARDS AFB NORTH, CA, USA

WMO: 723171

Lat: 34.988N

Lon: 117.865W

Elev: 696

StdP: 93.24

Time Zone: -8.00 (NAP)

Period: 05-19

WBAN: 53144

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) -6.8	(c) -4.7	(d) -23.2	(e) 0.5	(f) 2.8	(g) -20.5	(h) 0.7	(i) 5.3	(j) 14.4	(k) 10.3	(l) 12.7	(m) 10.6	(n) 0.7	(o) 350	(p) 0.572

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 17.9	(c) 40.7	(d) 18.0	(e) 39.3	(f) 17.5	(g) 38.0	(h) 17.0	(i) 20.1	(j) 34.7	(k) 19.3	(l) 34.7	(m) 18.5	(n) 34.6	(o) 5.4	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.2	11.7	26.8	13.0	10.2	26.7	11.4	9.1	25.3	60.3	34.2	57.5	35.1	54.7	34.4	23.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.8	11.7	10.6	-9.4	43.1	2.1	1.4	-10.9	44.1	-12.1	44.9	-13.2	45.7	-14.7	46.7		
			-11.8	21.4	2.8	0.8	-13.8	22.0	-15.4	22.4	-17.0	22.8	-19.0	23.4		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.0	6.7	9.1	12.1	15.6	19.9	25.7	29.2	28.0	23.4	17.1	11.0	6.2
	DBStd	8.55	3.09	3.56	3.46	3.70	3.81	3.67	2.40	2.25	3.49	3.33	3.56	3.46
	HDD10.0	340	107	54	19	2	0	0	0	0	0	1	31	127
	HDD18.3	1604	359	258	195	97	28	2	0	0	4	64	219	377
	CDD10.0	2911	6	30	83	170	308	469	596	557	402	219	61	9
	CDD18.3	1134	0	1	1	16	78	222	338	299	156	24	0	0
	CDH23.3	17530	0	14	98	438	1306	3338	4897	4345	2426	600	68	0
	CDH26.7	10352	0	1	13	151	633	2044	3143	2743	1398	219	7	0
(14) Wind	WSAvg	3.9	2.5	3.5	4.3	5.1	5.3	5.1	4.7	4.1	3.4	3.2	2.6	2.7
(15) Precipitation	PrecAvg	144	28	36	15	8	3	1	4	3	6	7	7	21
	PrecMax	331	149	152	58	26	24	12	22	11	33	51	27	91
	PrecMin	52	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	86	39	38	16	8	5	3	6	4	9	13	8	23
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.4	25.4	28.3	32.9	36.9	42.1	42.9	41.2	38.9	33.8	27.6	21.2
		MCWB	8.9	10.8	12.2	14.2	15.8	17.7	18.6	18.2	17.4	15.2	11.9	10.3
	2%	DB	18.3	22.9	26.0	30.6	34.6	39.7	41.3	39.7	37.4	31.3	25.5	17.8
		MCWB	7.7	9.8	11.4	13.0	14.8	16.8	18.5	17.6	16.7	14.2	10.9	9.2
	5%	DB	16.7	20.6	23.9	28.2	32.9	37.9	39.8	38.6	36.1	29.1	22.9	15.9
		MCWB	7.3	9.0	10.6	12.3	14.3	16.4	18.1	17.2	16.2	13.1	10.2	7.9
	10%	DB	14.6	18.0	21.5	25.8	30.5	36.1	38.3	37.4	34.3	27.0	20.3	13.7
		MCWB	7.1	8.4	9.8	11.5	13.6	16.0	17.4	17.0	15.4	12.4	8.9	7.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.5	13.0	13.4	15.7	17.0	19.4	21.2	20.7	20.1	17.6	13.1	12.3
		MCDB	16.2	17.6	23.7	28.6	33.8	37.5	35.8	33.4	33.8	27.1	22.4	17.1
	2%	WB	10.2	11.2	12.3	14.1	15.7	18.4	20.4	19.7	18.6	15.9	11.9	10.9
		MCDB	14.8	18.5	22.9	26.9	31.8	36.5	35.0	35.3	33.3	26.7	22.2	15.8
	5%	WB	9.1	10.1	11.5	13.0	15.0	17.5	19.7	18.8	17.2	14.7	10.9	9.6
		MCDB	13.6	18.0	21.8	25.4	30.6	35.2	34.5	35.3	32.7	25.3	20.7	13.8
	10%	WB	7.9	9.3	10.5	12.1	14.2	16.7	19.0	17.9	16.3	13.5	10.0	8.0
		MCDB	13.0	16.7	19.7	23.8	28.9	33.6	34.2	34.7	32.0	24.0	18.9	12.8
(35) Mean Daily Temperature Range	MDBR		15.8	16.0	16.3	17.1	17.3	18.9	17.9	19.0	19.8	18.6	18.2	14.9
	5% DB	MCDBR	19.8	21.4	21.3	21.6	21.1	21.2	20.1	20.5	21.5	22.1	22.0	17.8
		MCWBR	11.4	10.9	9.8	9.2	8.0	7.3	6.7	7.2	8.3	10.0	11.8	10.5
	5% WB	MCDBR	14.0	16.6	18.0	18.4	19.9	20.2	16.3	17.6	18.4	17.2	18.3	13.6
		MCWBR	8.9	8.6	8.6	8.1	7.5	7.0	5.9	7.0	7.4	7.6	9.8	8.6
(40) Clear-Sky Solar Irradiance	taub		0.273	0.283	0.296	0.319	0.334	0.330	0.352	0.340	0.324	0.302	0.277	0.275
	taud		2.544	2.533	2.485	2.423	2.402	2.426	2.410	2.422	2.461	2.511	2.556	2.551
	Ebn at Noon		948	972	980	965	948	947	923	932	936	935	935	922
	Edh at Noon		79	89	102	114	119	116	117	113	103	90	77	74
(44) All-Sky Solar Radiation	RadAvg		3.09	4.04	5.51	6.83	7.73	8.41	7.90	7.41	6.32	4.76	3.53	2.81
	RadStd		0.23	0.40	0.28	0.28	0.33	0.33	0.34	0.20	0.15	0.25	0.14	0.20

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (44 neighbors)	+0.61	N/A	-1.90	+0.61	N/A	N/A	N/A	-112	+218	+104

Nomenclature: See separate page