

BURLINGTON ALAMANCE, NC, USA

WMO: 723174

Lat: 36.047N

Lon: 79.477W

Elev: 617

StdP: 14.37

Time Zone: -5.00 (NAE)

Period: 01-19

WBAN: 93783

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 18.5	(c) 22.1	(d) -0.4	(e) 5.5	(f) 25.7	(g) 4.0	(h) 6.9	(i) 30.1	(j) 20.8	(k) 47.5	(l) 18.9	(m) 46.1	(n) 4.2	(o) 300	(p) 0.396

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 19.5	(c) 94.4	(d) 74.2	(e) 92.1	(f) 73.9	(g) 90.1	(h) 73.4	(i) 77.5	(j) 88.8	(k) 76.5	(l) 87.1	(m) 75.5	(n) 85.3	(o) 7.3	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.4	131.5	81.6	73.3	126.8	80.8	72.5	123.3	79.9	41.2	88.9	40.2	87.3	39.2	85.7	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
18.1	15.8	12.9	10.5	98.0	4.9	2.9	6.9	100.1	4.0	101.8	1.3	103.4	-2.3	105.5
			8.9	78.8	4.4	1.2	5.7	79.7	3.1	80.4	0.6	81.1	-2.6	82.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.2	40.0	43.1	50.8	60.4	68.3	75.9	79.0	77.7	71.7	60.5	50.0	43.8
	DBStd	15.74	10.30	9.49	9.58	8.15	7.07	4.90	3.95	4.41	5.84	8.08	8.34	8.91
	HDD50	1050	340	236	110	13	0	0	0	0	12	101	238	
	HDD65	3384	774	615	449	181	53	1	0	0	14	185	453	659
	CDD50	4769	31	43	135	326	566	776	900	858	650	337	101	46
	CDD65	1631	0	2	9	44	155	328	435	393	214	46	3	2
	CDH74	15045	3	13	97	514	1390	3101	4225	3575	1679	412	33	3
	CDH80	6099	0	1	9	117	442	1319	1942	1554	614	99	2	0
(14) Wind	WSAvg	5.2	5.9	6.2	6.5	6.5	5.3	4.6	4.1	3.7	4.3	4.7	4.9	5.2
(15) Precipitation	PrecAvg	44.6	3.4	2.7	4.3	3.6	3.3	4.2	4.5	4.1	4.4	3.3	3.1	3.4
	PrecMax	64.8	7.5	6.0	8.7	7.1	8.3	12.2	7.3	8.7	13.6	9.2	9.1	6.6
	PrecMin	32.1	0.9	1.2	1.1	0.9	0.9	1.4	1.3	1.1	0.4	0.0	0.2	1.1
	PrecStd	7.1	1.6	1.1	1.9	1.7	1.9	2.5	1.7	1.9	3.3	2.6	2.1	1.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.1	75.6	81.2	87.3	91.4	95.8	97.8	97.7	93.6	87.8	79.0	73.0
		MCWB	60.4	63.2	61.3	65.2	71.4	74.3	75.6	73.3	70.6	72.3	64.2	62.7
	2%	DB	66.2	70.1	76.7	83.3	87.8	92.8	94.5	93.4	90.1	82.4	73.1	68.0
		MCWB	57.9	58.6	60.0	64.7	70.0	73.5	75.1	74.4	71.3	67.9	60.2	61.2
	5%	DB	62.5	65.4	72.6	80.5	85.0	90.2	92.0	90.8	87.0	78.7	69.7	63.8
		MCWB	55.4	55.8	57.6	62.7	69.1	73.1	74.9	74.0	70.9	65.6	60.4	57.7
	10%	DB	57.3	60.3	67.8	76.3	81.9	87.6	89.8	88.3	83.5	74.8	65.7	59.6
		MCWB	49.9	50.0	55.4	61.4	67.9	72.0	74.3	73.5	69.9	65.1	57.5	52.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.9	65.5	65.2	70.3	74.2	77.3	79.0	78.7	76.6	75.4	68.0	66.2
		MCDB	67.4	72.1	75.0	79.2	83.9	90.2	91.4	89.7	85.1	78.7	71.9	69.5
	2%	WB	59.9	61.7	62.7	67.7	72.5	76.0	77.8	77.4	74.9	72.2	65.0	62.4
		MCDB	65.0	67.9	72.1	77.4	83.3	87.9	89.8	87.9	83.3	78.5	69.8	66.3
	5%	WB	56.4	57.0	60.5	65.6	71.1	74.9	76.8	76.2	73.4	69.3	62.4	59.1
		MCDB	61.8	63.5	68.9	75.6	81.7	86.0	88.1	85.9	81.0	75.1	67.5	63.1
	10%	WB	51.2	51.5	58.1	63.7	69.5	73.7	75.7	75.1	72.1	66.5	58.6	53.8
		MCDB	56.2	57.9	66.0	73.0	78.6	84.0	86.2	84.1	78.9	73.0	64.8	57.9
(35) Mean Daily Temperature Range	5% DB	MDBR	20.1	21.3	22.4	23.2	21.0	20.3	19.5	19.1	19.4	21.9	23.1	20.1
		MCDBR	25.2	26.1	26.7	27.8	24.4	23.4	22.7	22.9	24.5	25.6	26.9	24.0
		MCWBR	17.8	17.0	14.0	12.0	9.8	8.1	7.4	7.5	9.0	12.6	16.4	17.2
	5% WB	MCDBR	21.9	23.9	22.9	22.3	20.2	20.2	19.7	19.0	18.3	18.9	20.7	20.1
		MCWBR	17.7	18.1	14.0	10.9	8.7	8.1	7.3	7.4	7.9	10.9	15.4	16.5
(40) Clear-Sky Solar Irradiance	taub		0.307	0.324	0.356	0.397	0.442	0.486	0.528	0.518	0.416	0.376	0.325	0.310
	taud		2.509	2.456	2.406	2.292	2.199	2.117	2.020	2.030	2.311	2.401	2.505	2.534
	Ebn at Noon		284	291	289	281	269	256	244	244	266	268	274	275
	Edh at Noon		26	30	35	41	46	50	55	53	38	32	26	24
(44) All-Sky Solar Radiation	RadAvg		808	1021	1352	1693	1874	2013	1882	1716	1429	1165	886	692
	RadStd		53	124	94	129	153	148	124	86	131	149	69	59

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+1.67	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (62 neighbors)	+0.76	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+259	+180

Nomenclature: See separate page