

ANDERSON, SC, USA

WMO: 723190

Lat: 34.498N

Lon: 82.710W

Elev: 232

StdP: 98.57

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 93846

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.6	-3.4	-15.2	1.0	-0.2	-12.8	1.3	1.2	10.4	7.4	9.2	7.8	1.9	270	0.407

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	35.0	23.4	33.8	23.1	32.5	23.0	25.2	31.3	24.7	30.4	24.1	29.6	3.7	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.5	18.9	27.0	23.0	18.2	26.5	22.6	17.8	26.3	77.7	31.4	75.6	30.4	73.7	29.9	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.6	7.7	6.8	DB	-9.7	36.8	2.2	1.9	-11.3	38.2	-12.6	39.3	-13.9	40.3	-15.5	41.7	
			WB	-10.7	26.2	2.0	0.9	-12.1	26.8	-13.3	27.3	-14.4	27.8	-15.8	28.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.7	6.1	8.1	12.0	16.5	21.0	25.0	26.6	26.2	23.0	17.0	11.1	7.6
	DBStd	8.21	5.11	4.71	4.68	3.88	3.32	2.44	1.91	2.06	3.01	4.01	4.26	4.64
	HDD10.0	406	143	84	34	3	0	0	0	0	0	2	36	104
	HDD18.3	1588	379	286	201	79	16	1	0	0	4	72	218	332
	CDD10.0	2861	22	32	96	197	340	449	514	502	389	219	71	30
	CDD18.3	1001	0	1	4	24	97	199	256	243	143	31	2	1
	CDH23.3	9186	1	3	53	270	867	1863	2504	2248	1123	238	14	1
CDH26.7	3772	0	0	6	53	274	808	1156	1003	424	47	1	0	
Wind	WSAvg	2.7	3.0	3.1	3.3	3.1	2.7	2.5	2.3	2.2	2.4	2.4	2.4	2.7
Precipitation	PrecAvg	1221	115	96	140	96	112	89	112	87	105	80	83	104
	PrecMax	1722	184	173	278	239	222	228	261	178	298	191	130	260
	PrecMin	821	14	17	47	10	24	14	27	18	9	2	34	16
	PrecStd	212	46	44	75	59	54	52	66	50	75	50	28	60
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.3	23.4	27.5	30.1	33.0	35.8	36.3	37.1	34.3	30.3	25.3	22.4
		MCWB	15.8	15.8	16.8	19.3	21.6	23.2	23.6	23.1	21.7	21.6	17.6	16.6
	2%	DB	18.7	20.7	24.8	28.2	31.2	34.0	34.8	34.9	32.6	27.7	22.7	19.9
		MCWB	14.1	14.1	15.8	18.3	21.1	22.9	23.8	23.5	21.8	19.6	16.0	15.9
	5%	DB	16.9	18.5	22.6	26.7	29.8	32.6	33.6	33.0	31.1	26.1	21.0	17.5
		MCWB	13.2	13.0	14.6	17.4	20.7	22.7	23.7	23.3	21.7	18.5	15.3	13.9
	10%	DB	14.4	16.3	20.5	24.6	27.9	31.2	32.3	31.7	29.1	24.0	18.8	15.4
		MCWB	10.9	11.5	13.5	16.4	19.8	22.3	23.5	23.1	21.2	17.9	14.6	12.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.8	18.2	18.9	21.3	23.8	25.5	25.9	25.7	24.5	23.2	20.4	19.1
		MCDB	19.4	21.2	23.4	27.3	29.5	32.2	32.5	32.1	29.8	27.1	21.9	20.5
	2%	WB	15.8	16.5	17.5	20.1	22.7	24.6	25.2	25.1	23.7	21.8	18.4	16.9
		MCDB	17.7	19.1	22.2	25.5	28.3	30.9	31.5	30.8	28.7	25.4	20.8	18.7
	5%	WB	13.8	14.6	16.4	19.0	21.8	23.9	24.8	24.5	23.0	20.6	17.0	15.0
		MCDB	16.0	17.2	20.5	23.7	27.2	29.8	30.7	29.9	27.5	23.8	19.2	17.0
	10%	WB	11.7	12.6	15.1	17.9	21.0	23.3	24.2	24.0	22.4	19.4	15.4	12.7
		MCDB	13.6	15.0	18.9	22.3	25.9	28.7	29.8	29.1	26.5	22.6	18.1	14.6
Mean Daily Temperature Range	5% DB	MDBR	10.8	11.1	12.2	12.8	11.9	11.1	10.6	10.3	10.5	11.7	12.0	10.4
		MCDBR	12.8	13.6	14.9	15.2	13.8	13.2	12.5	12.6	13.1	13.4	14.3	12.5
		MCWBR	8.8	8.5	7.7	6.7	5.3	4.2	3.8	3.7	4.3	6.2	8.0	8.3
	5% WB	MCDBR	10.5	10.8	12.3	12.0	11.3	11.1	10.9	10.3	10.0	10.1	10.2	10.1
		MCWBR	8.5	8.1	7.6	6.3	4.9	4.2	3.9	3.6	4.2	5.7	7.7	7.8
Clear-Sky Solar Irradiance	taub	0.313	0.322	0.358	0.395	0.457	0.484	0.528	0.519	0.421	0.383	0.339	0.309	
	taud	2.508	2.480	2.407	2.298	2.161	2.132	2.029	2.039	2.294	2.380	2.459	2.547	
	Ebn at Noon	898	927	914	891	836	811	772	771	838	844	856	882	
	Edh at Noon	83	95	111	130	151	156	171	167	123	104	87	76	
All-Sky Solar Radiation	RadAvg	2.69	3.31	4.40	5.50	6.09	6.42	6.05	5.57	4.78	3.98	2.99	2.31	
	RadStd	0.15	0.39	0.30	0.38	0.47	0.46	0.39	0.28	0.43	0.46	0.29	0.23	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.57	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+155	+99
(47)	Regional (48 neighbors)	+0.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+166	+115

Nomenclature: See separate page