

BRUNSWICK 23 S, GA, USA

WMO: 723210

Lat: 30.8078N

Lon: 81.4596W

Elev: 8

StdP: 101.23

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 63856

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.5	1.4	-7.4	2.0	4.3	-4.9	2.5	4.9	5.2	8.7	4.7	9.3	1.1	N/A	0.295

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.3	33.4	25.2	32.2	25.4	31.2	25.3	26.8	30.9	26.4	30.5	26.0	30.0	2.1	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.7	20.9	29.3	25.2	20.4	28.9	24.9	20.0	28.6	83.7	31.0	82.1	30.7	80.5	30.1	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.5	3.9	3.4	DB	-3.6	35.8	1.3	1.1	-4.5	36.6	-5.3	37.3	-6.0	37.9	-7.0	38.7	(4)
			WB	-4.9	27.6	1.9	0.5	-6.3	27.9	-7.4	28.2	-8.4	28.4	-9.8	28.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	20.1	11.4	13.0	15.5	19.4	23.2	26.4	27.3	27.3	25.8	21.5	16.0	13.8	(6)
		DBStd	6.67	5.01	4.70	4.34	3.20	2.50	1.69	1.40	1.35	1.70	3.71	4.14	4.61	(7)
		HDD10.0	97	45	22	8	0	0	0	0	0	0	4	17		(8)
		HDD18.3	764	217	157	106	26	2	0	0	0	16	91	151		(9)
		CDD10.0	3779	89	106	179	281	409	492	536	537	473	355	186	136	(10)
		CDD18.3	1405	3	7	18	57	152	242	278	279	223	113	22	11	(11)
		CDH23.3	11934	7	30	86	249	981	2200	2774	2804	1997	723	63	21	(12)
		CDH26.7	3548	0	2	14	40	195	700	993	964	533	104	3	0	(13)
(14)	Wind	WSAvg	1.5	1.6	1.6	1.8	1.8	1.5	1.4	1.4	1.5	1.4	1.4	1.4	1.4	(14)
(15)	Precipitation	PrecAvg	1263	83	75	95	64	54	157	129	150	177	149	45	73	(15)
(16)		PrecMax	1709	230	244	210	143	132	288	266	442	343	343	107	260	(16)
(17)		PrecMin	792	8	20	12	14	14	38	62	64	78	7	4	17	(17)
(18)		PrecStd	257	57	55	58	38	33	69	61	80	79	104	27	65	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	24.5	26.5	28.8	30.5	33.0	34.8	34.9	34.9	32.7	30.4	26.9	25.7		(19)
(20)		0.4% MCWB	19.6	19.4	19.0	20.7	23.1	25.2	25.4	25.4	25.0	24.3	22.0	21.4		(20)
(21)		2% DB	21.8	24.0	25.6	27.6	30.5	32.9	33.2	32.9	31.0	29.0	25.2	23.5		(21)
(22)		2% MCWB	17.6	19.0	18.8	20.8	22.2	25.1	25.6	25.6	25.0	23.7	21.0	20.3		(22)
(23)		5% DB	20.2	21.7	23.6	25.8	28.6	31.2	31.9	31.6	30.2	27.9	23.7	21.8		(23)
(24)		5% MCWB	17.0	17.9	18.3	20.6	22.8	25.0	25.7	26.0	24.7	23.2	20.5	19.2		(24)
(25)		10% DB	18.6	19.9	21.8	24.6	27.4	30.1	30.8	30.7	29.5	26.8	22.4	20.3		(25)
(26)		10% MCWB	16.2	16.9	17.5	20.0	22.5	24.8	25.6	25.9	24.4	22.7	19.6	18.3		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	20.5	21.0	21.0	23.5	25.0	26.9	27.3	27.4	26.5	25.9	23.9	22.2		(27)
(28)		0.4% MCDB	23.0	24.7	24.8	26.3	29.4	31.3	31.7	31.3	30.1	28.2	26.1	24.5		(28)
(29)		2% WB	18.9	20.0	20.2	22.6	24.2	26.3	26.8	26.9	25.9	25.0	22.8	21.0		(29)
(30)		2% MCDB	21.1	23.1	23.9	25.4	27.8	30.7	31.2	30.8	29.6	27.5	24.3	22.9		(30)
(31)		5% WB	17.7	18.8	19.4	21.9	23.7	25.7	26.3	26.5	25.5	24.3	21.5	20.0		(31)
(32)		5% MCDB	19.4	21.4	22.8	24.6	27.1	29.9	30.7	30.4	29.1	26.9	23.1	21.5		(32)
(33)		10% WB	16.5	17.7	18.6	21.0	23.2	25.3	25.9	26.1	25.1	23.6	20.2	18.9		(33)
(34)		10% MCDB	17.9	19.7	21.4	23.8	26.5	29.3	30.0	29.8	28.6	26.2	22.2	20.4		(34)
(35)	Mean Daily Temperature Range	MDBR	9.9	10.1	9.9	9.3	8.3	7.9	7.8	7.3	7.1	8.6	9.7	9.5		(35)
(36)		5% DB MCDBR	10.6	11.1	11.5	10.2	9.9	9.6	9.0	8.6	8.1	8.3	9.9	9.8		(36)
(37)		5% WB MCWBR	7.2	6.4	5.8	4.8	4.3	4.2	4.0	3.7	3.8	4.4	5.9	6.6		(37)
(38)		5% WB MCDBR	9.3	9.2	9.3	7.8	7.5	8.5	8.4	7.8	7.3	6.8	7.5	8.9		(38)
(39)	Clear-Sky Solar Irradiance	taub	0.338	0.347	0.373	0.399	0.441	0.488	0.512	0.496	0.429	0.400	0.360	0.348		(40)
(41)		taud	2.532	2.510	2.452	2.371	2.288	2.214	2.155	2.203	2.388	2.432	2.498	2.529		(41)
(42)		Ebn at Noon	893	916	911	894	854	810	789	798	844	846	859	861		(42)
(43)		Edh at Noon	87	96	109	123	134	144	152	144	115	103	89	83		(43)
(44)	All-Sky Solar Radiation	RadAvg	3.06	3.68	4.84	5.96	6.43	6.09	6.08	5.59	4.75	4.18	3.36	2.74		(44)
(45)		RadStd	0.20	0.42	0.45	0.37	0.37	0.42	0.38	0.35	0.40	0.38	0.20	0.23		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (30 neighbors)		+0.47	+0.76	N/A	N/A	N/A	N/A	-17	-69	+162	+117

Nomenclature: See separate page