

DYERSBURG, TN, USA

WMO: 723347

Lat: 36.000N

Lon: 89.409W

Elev: 300

StdP: 14.54

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 03809

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.5	19.0	2.5	6.3	17.3	6.9	7.9	21.1	21.2	44.7	19.4	42.6	7.3	0	0.417

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.1	95.3	77.3	92.9	76.4	90.9	75.7	79.9	91.4	78.5	89.8	77.4	88.3	6.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.7	140.9	86.5	75.1	133.3	85.1	73.5	126.0	83.6	43.6	91.3	42.1	90.3	41.0	88.1	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	16.6	14.7	9.8	99.2	4.3	5.0	6.7	102.9	4.2	105.8	1.8	108.6	-1.4	112.3
			7.9	81.2	4.4	2.0	4.8	82.7	2.2	83.9	-0.3	85.0	-3.5	86.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.3	38.7	42.1	50.7	60.6	69.7	77.5	79.8	79.5	72.2	61.2	49.1	41.2
	DBStd	17.08	11.53	10.76	10.30	8.66	7.23	5.06	4.43	4.33	6.46	8.57	9.37	9.88
	HDD50	1226	383	263	118	16	0	0	0	0	0	10	130	306
	HDD65	3550	816	641	456	183	41	1	0	0	16	177	481	738
	CDD50	4982	33	43	139	333	612	826	922	915	667	357	102	33
	CDD65	1832	1	1	11	51	188	377	457	450	233	59	4	0
	CDH74	17721	0	1	67	395	1528	3765	4742	4590	2055	553	25	0
	CDH80	7413	0	0	6	74	470	1636	2137	2152	800	137	1	0
(14) Wind	WSAvg	6.2	7.6	7.8	8.0	7.5	6.3	5.2	4.4	4.3	4.7	5.3	6.5	7.1
(15) Precipitation	PrecAvg	54.0	4.6	4.3	5.2	4.8	5.6	4.6	4.1	3.2	3.3	4.4	4.6	5.5
	PrecMax	67.8	8.5	10.2	10.5	9.5	13.3	7.5	10.8	6.5	9.3	9.2	11.0	13.9
	PrecMin	41.6	2.0	1.6	1.2	0.9	0.5	1.6	1.4	0.7	0.2	0.6	1.0	1.5
	PrecStd	7.2	1.5	2.2	2.2	2.0	2.9	1.5	2.5	1.9	2.2	2.4	2.5	3.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.9	72.3	80.9	84.5	90.5	97.0	98.6	99.5	94.0	88.4	77.9	70.0
		MCWB	62.5	62.4	65.1	67.3	73.5	76.1	78.5	77.8	74.2	72.8	64.5	62.1
	2%	DB	65.7	67.9	75.0	81.8	88.0	93.0	94.6	96.7	90.9	83.7	72.6	64.2
		MCWB	60.5	60.0	61.8	65.8	72.0	75.1	78.2	77.8	74.4	69.2	60.7	58.1
	5%	DB	61.4	63.8	71.9	79.1	84.5	91.0	91.5	92.8	88.4	80.8	69.7	61.0
		MCWB	55.3	55.8	60.0	64.2	70.4	74.6	77.1	76.7	73.4	65.5	60.0	55.1
	10%	DB	56.6	60.3	67.4	75.0	82.1	89.6	90.3	90.4	84.3	76.2	64.1	56.6
		MCWB	51.1	53.0	57.0	62.3	68.8	74.1	76.8	75.7	71.1	63.7	56.3	50.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.5	65.0	66.8	71.2	76.3	79.9	82.0	81.8	77.7	75.0	66.6	63.7
		MCDB	67.2	69.7	77.0	81.9	85.9	90.9	91.8	94.1	89.2	86.4	74.0	67.5
	2%	WB	60.7	61.5	63.8	68.3	74.6	78.2	80.3	79.5	76.3	71.4	63.8	59.6
		MCDB	64.9	67.1	73.4	78.5	84.2	89.5	91.0	92.3	87.5	79.1	69.5	63.5
	5%	WB	57.0	57.8	61.2	66.2	72.5	76.9	79.0	78.2	74.9	68.7	60.9	56.0
		MCDB	61.4	63.1	69.8	76.0	82.1	87.8	89.9	90.3	85.2	76.1	67.3	60.2
	10%	WB	51.4	53.3	58.2	64.0	70.6	75.4	77.7	77.0	73.1	66.1	57.6	51.3
		MCDB	55.8	59.2	66.0	73.0	80.1	85.4	88.0	88.2	81.8	73.9	64.2	56.1
(35) Mean Daily Temperature Range	5% DB	MDBR	15.5	16.2	18.2	19.5	18.4	18.5	18.1	19.6	20.9	22.1	18.6	15.4
		MCDBR	19.5	21.8	22.2	22.6	20.9	21.2	20.2	22.7	23.8	25.6	24.1	19.6
		MCWBR	16.0	16.4	14.1	12.1	9.7	8.8	8.9	9.8	10.5	13.2	16.2	15.9
	5% WB	MCDBR	17.4	19.3	19.6	18.8	18.3	18.8	18.4	20.4	20.1	20.6	20.0	17.8
		MCWBR	15.5	16.3	14.2	11.7	9.5	8.9	8.6	9.6	9.6	11.8	15.9	16.0
(40) Clear-Sky Solar Irradiance	taub		0.316	0.329	0.366	0.397	0.435	0.449	0.484	0.483	0.416	0.358	0.327	0.315
	taud		2.481	2.433	2.363	2.278	2.234	2.197	2.135	2.123	2.302	2.445	2.482	2.490
	Ebn at Noon		280	289	286	281	271	266	255	253	266	274	273	272
	Edh at Noon		26	31	36	42	44	46	49	48	38	30	26	25
(44) All-Sky Solar Radiation	RadAvg		741	910	1263	1639	1843	2050	1986	1819	1534	1184	827	631
	RadStd		64	121	108	108	134	128	103	100	97	138	83	58

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page