

DYERSBURG, TN, USA

WMO: 723347

Lat: 36.000N

Lon: 89.409W

Elev: 91

StdP: 100.23

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 03809

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.1	-7.2	-16.4	0.9	-8.2	-13.9	1.1	-6.0	9.5	7.1	8.7	5.9	3.3	0	0.417

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	35.2	25.2	33.8	24.6	32.7	24.3	26.6	33.0	25.8	32.1	25.2	31.3	3.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.9	20.1	30.3	24.0	19.0	29.5	23.0	18.0	28.7	83.5	33.0	80.0	32.4	77.5	31.2	29.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.4	6.6	-12.3	37.4	2.4	2.8	-14.0	39.4	-15.5	41.0	-16.8	42.6	-18.5	44.6		
(5)			-13.4	27.3	2.5	1.1	-15.1	28.2	-16.6	28.8	-17.9	29.5	-19.7	30.3	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.7	3.7	5.6	10.4	15.9	21.0	25.3	26.5	26.4	22.3	16.2	9.5	5.1	(6)	(7)
	DBStd	9.49	6.40	5.98	5.72	4.81	4.02	2.81	2.46	2.41	3.59	4.76	5.21	5.49	(7)	(8)
	HDD10.0	681	213	146	66	9	0	0	0	0	0	6	72	170	(8)	(9)
	HDD18.3	1972	453	356	253	102	23	1	0	0	9	98	267	410	(9)	(10)
	CDD10.0	2768	18	24	77	185	340	459	512	508	371	198	57	18	(10)	(11)
	CDD18.3	1018	1	1	6	28	104	209	254	250	129	33	2	0	(11)	(12)
	CDH23.3	9845	0	1	37	219	849	2092	2634	2550	1142	307	14	0	(12)	(13)
	CDH26.7	4118	0	0	3	41	261	909	1187	1196	444	76	1	0	(13)	(14)
(14) Wind	WSAvg	2.8	3.4	3.5	3.6	3.3	2.8	2.3	2.0	1.9	2.1	2.4	2.9	3.2	(14)	(15)
(15) Precipitation	PrecAvg	1372	117	109	133	122	143	116	103	81	84	111	116	139	(15)	(16)
	PrecMax	1723	216	258	266	241	339	190	275	166	236	234	279	352	(16)	(17)
	PrecMin	1057	52	41	31	24	12	41	35	18	5	14	26	39	(17)	(18)
	PrecStd	184	38	57	57	50	74	37	63	47	57	60	63	75	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.1	22.4	27.2	29.2	32.5	36.1	37.0	37.5	34.4	31.4	25.5	21.1	(19)	(20)
		MCWB	17.0	16.9	18.4	19.6	23.0	24.5	25.8	25.5	23.4	22.6	18.0	16.7	(20)	(21)
	2%	DB	18.7	19.9	23.9	27.6	31.1	33.9	34.8	36.0	32.7	28.7	22.5	17.9	(21)	(22)
		MCWB	15.8	15.6	16.6	18.8	22.2	23.9	25.7	25.4	23.6	20.7	15.9	14.5	(22)	(23)
	5%	DB	16.3	17.7	22.2	26.2	29.2	32.8	33.1	33.8	31.3	27.1	20.9	16.1	(23)	(24)
		MCWB	13.0	13.2	15.5	17.9	21.3	23.7	25.1	24.8	23.0	18.6	15.5	12.8	(24)	(25)
	10%	DB	13.7	15.7	19.6	23.9	27.8	32.0	32.4	32.5	29.0	24.6	17.9	13.7	(25)	(26)
		MCWB	10.6	11.7	13.9	16.9	20.4	23.4	24.9	24.3	21.7	17.6	13.5	10.5	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.5	18.3	19.4	21.8	24.6	26.6	27.8	27.7	25.4	23.9	19.2	17.6	(27)	(28)
		MCDB	19.6	20.9	25.0	27.7	30.0	32.7	33.2	34.5	31.8	30.2	23.4	19.7	(28)	(29)
	2%	WB	15.9	16.4	17.7	20.2	23.7	25.6	26.8	26.4	24.6	21.9	17.7	15.3	(29)	(30)
		MCDB	18.3	19.5	23.0	25.8	29.0	32.0	32.8	33.5	30.8	26.2	20.8	17.5	(30)	(31)
	5%	WB	13.9	14.3	16.2	19.0	22.5	24.9	26.1	25.7	23.8	20.4	16.1	13.3	(31)	(32)
		MCDB	16.3	17.3	21.0	24.5	27.8	31.0	32.2	32.4	29.6	24.5	19.6	15.7	(32)	(33)
	10%	WB	10.8	11.8	14.5	17.8	21.5	24.1	25.4	25.0	22.8	18.9	14.2	10.7	(33)	(34)
		MCDB	13.2	15.1	18.9	22.8	26.7	29.7	31.1	31.2	27.7	23.3	17.9	13.4	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.6	9.0	10.1	10.9	10.2	10.3	10.0	10.9	11.6	12.3	10.3	8.5	(35)	(36)
		MCDBR	10.8	12.1	12.3	12.5	11.6	11.8	11.2	12.6	13.2	14.2	13.4	10.9	(36)	(37)
	5% WB	MCWBR	8.9	9.1	7.8	6.7	5.4	4.9	5.0	5.5	5.8	7.3	9.0	8.9	(37)	(38)
		MCWBR	9.7	10.7	10.9	10.4	10.2	10.4	10.2	11.3	11.2	11.4	11.1	9.9	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.316	0.329	0.366	0.397	0.435	0.449	0.484	0.483	0.416	0.358	0.327	0.315	(39)	(40)
		taud	2.481	2.433	2.363	2.278	2.234	2.197	2.135	2.123	2.302	2.445	2.482	2.490	(40)	(41)
	Ebn at Noon		883	910	901	886	854	838	805	798	838	865	861	858	(41)	(42)
		Edh at Noon	83	98	115	132	140	145	154	152	121	96	83	78	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		2.34	2.87	3.98	5.17	5.81	6.46	6.26	5.73	4.84	3.73	2.61	1.99	(43)	(44)
	RadStd		0.20	0.38	0.34	0.34	0.42	0.40	0.33	0.32	0.31	0.43	0.26	0.18	(44)	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page