

NORTH LITTLE ROCK, AR, USA

WMO: 723400

Lat: 34.8350N

Lon: 92.2594W

Elev: 568

StdP: 14.40

Time Zone: -6.00 (NAC)

Period: 86-06

WBAN: 03952

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.5	23.3	5.3	7.4	25.4	9.8	9.3	26.3	21.4	55.7	19.3	48.3	8.4	340	0.425

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.3	95.4	76.6	93.0	76.3	90.9	75.6	79.1	90.2	78.1	88.8	77.2	87.6	8.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.0	138.9	84.7	75.0	134.1	83.9	74.0	129.6	83.1	42.9	90.2	41.8	88.5	40.8	87.7	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.5	16.5	14.7	DB	13.2	98.6	5.7	4.0	9.1	101.5	5.8	103.8	2.6	106.1	-1.5	109.0
			WB	11.1	81.1	5.4	2.3	7.3	82.8	4.1	84.1	1.1	85.4	-2.8	87.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.7	41.0	44.1	52.8	62.6	70.0	77.6	81.3	80.1	72.8	62.5	52.1	41.9	(6)
	DBStd	16.36	9.67	10.13	9.25	8.03	6.41	4.28	4.16	5.19	7.00	7.87	9.54	9.54	(7)
	HDD50	989	309	213	80	8	0	0	0	0	0	7	89	283	(8)
	HDD65	3158	745	586	388	136	29	0	0	0	20	141	397	716	(9)
	CDD50	5245	30	48	166	387	620	827	970	934	685	396	151	31	(10)
	CDD65	1937	1	1	9	64	183	377	505	469	255	64	9	0	(11)
	CDH74	19097	0	2	46	463	1350	3532	5798	5320	2197	367	22	0	(12)
	CDH80	7554	0	0	2	71	311	1315	2642	2427	736	50	0	0	(13)
(14) Wind	WSAvg	7.5	8.1	8.6	8.9	8.4	7.3	6.6	6.6	6.2	7.0	6.8	7.8	7.9	(14)
(15) Precipitation	PrecAvg	49.5	3.3	3.7	4.9	5.2	5.0	3.7	3.4	3.3	3.4	3.9	4.9	4.9	(15)
	PrecMax	74.4	8.7	13.4	12.2	14.2	12.8	7.8	8.0	14.4	10.2	16.6	14.6	16.5	(16)
	PrecMin	26.6	0.0	0.9	0.7	0.0	0.0	0.0	0.2	0.0	0.3	0.0	0.0	0.0	(17)
	PrecStd	9.6	1.9	2.2	2.3	3.1	2.9	2.4	1.9	2.6	2.3	3.5	3.5	3.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.1	71.8	78.3	85.0	87.4	93.3	99.0	99.4	95.8	84.2	77.1	67.2	(19)
		MCWB	64.7	60.4	62.6	65.4	72.1	75.6	76.9	76.3	75.2	70.9	65.9	61.6	(20)
	2%	DB	65.8	67.1	74.7	81.9	85.5	90.9	95.4	95.6	90.1	81.0	73.2	63.7	(21)
		MCWB	60.5	57.9	60.7	66.6	72.0	73.8	76.7	76.9	73.6	68.1	64.1	59.2	(22)
	5%	DB	60.9	63.0	71.7	79.1	83.6	89.0	93.1	93.0	87.0	78.1	70.1	60.3	(23)
		MCWB	53.4	56.1	59.7	65.7	70.7	74.1	76.5	76.6	72.8	66.8	62.4	55.3	(24)
	10%	DB	57.0	59.7	68.7	76.2	81.5	86.9	91.0	90.8	84.5	75.0	66.9	56.7	(25)
		MCWB	50.2	51.8	57.6	64.2	69.8	73.6	76.1	76.1	71.5	65.2	60.0	51.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.4	62.6	67.7	72.2	76.7	79.2	81.0	81.1	77.3	73.7	68.9	63.6	(27)
		MCDB	69.1	67.4	76.4	80.6	83.1	90.8	91.4	91.1	87.9	80.7	74.2	65.6	(28)
	2%	WB	62.7	60.1	64.2	70.0	74.7	77.4	79.3	79.2	75.9	71.1	66.5	60.3	(29)
		MCDB	65.6	64.7	71.3	78.2	82.1	87.1	90.4	90.2	85.7	77.2	71.1	63.4	(30)
	5%	WB	55.8	56.9	62.0	68.0	73.1	76.4	78.2	78.1	74.7	68.9	64.1	56.6	(31)
		MCDB	59.1	61.8	69.2	75.8	81.2	85.5	89.0	89.1	83.9	75.0	68.8	59.5	(32)
	10%	WB	50.2	53.2	59.0	66.1	71.7	75.2	77.3	77.1	73.4	66.8	60.9	52.3	(33)
		MCDB	55.7	58.2	66.4	73.8	79.1	83.7	87.8	87.9	81.9	73.2	65.6	55.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	12.8	13.9	15.9	16.9	15.1	14.8	15.3	16.3	15.9	16.4	13.9	12.9	(35)
		MCDBR	17.1	18.3	19.5	19.7	17.1	17.6	18.2	19.4	18.8	19.6	18.5	16.4	(36)
	5% WB	MCWBR	13.9	13.0	12.1	9.6	7.1	6.7	5.5	6.0	6.6	9.8	12.8	14.2	(37)
		MCWBR	15.8	16.0	17.2	16.0	14.8	15.2	16.7	17.4	15.2	15.0	15.9	15.2	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.316	0.323	0.355	0.393	0.420	0.447	0.480	0.476	0.404	0.353	0.329	0.311	(40)
		taud	2.507	2.481	2.420	2.311	2.295	2.234	2.187	2.177	2.362	2.482	2.504	2.531	(41)
	Ebn at Noon	Ebn at Noon	283	293	291	283	275	267	257	256	271	278	275	278	(42)
		Edh at Noon	26	30	35	41	42	44	46	46	36	30	26	24	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	789	943	1308	1647	1802	2039	1970	1814	1557	1206	861	694	(44)
	RadStd	RadStd	70	132	111	114	141	156	111	131	121	163	96	76	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(46)
(47)	Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page