

NORTH LITTLE ROCK, AR, USA

WMO: 723400

Lat: 34.8350N

Lon: 92.2594W

Elev: 173

StdP: 99.26

Time Zone: -6.00 (NAC)

Period: 86-06

WBAN: 03952

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.5	-4.8	-14.8	1.1	-3.7	-12.3	1.3	-3.2	9.6	13.2	8.6	9.1	3.8	340	0.425

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.5	35.2	24.8	33.9	24.6	32.7	24.2	26.2	32.4	25.6	31.6	25.1	30.9	3.6	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.5	19.8	29.3	23.9	19.2	28.8	23.3	18.5	28.4	81.9	32.3	79.3	31.4	76.9	31.0	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.3	7.4	6.6	-10.5	37.0	3.2	2.2	-12.7	38.6	-14.6	39.9	-16.3	41.2	-18.6	42.8
			-11.6	27.3	3.0	1.3	-13.7	28.2	-15.5	29.0	-17.2	29.7	-19.3	30.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.5	5.0	6.7	11.5	17.0	21.1	25.3	27.4	26.7	22.7	17.0	11.1	5.5	(6)
(7)		DBStd	9.09	5.37	5.63	5.14	4.46	3.56	2.38	2.31	2.88	3.89	4.37	5.30	5.30	(7)
(8)		HDD10.0	549	172	118	44	4	0	0	0	0	0	4	49	157	(8)
(9)		HDD18.3	1754	414	326	216	76	16	0	0	0	11	78	221	398	(9)
(10)		CDD10.0	2914	17	27	92	215	344	459	539	519	381	220	84	17	(10)
(11)		CDD18.3	1076	1	1	5	36	102	209	281	261	142	36	5	0	(11)
(12)		CDH23.3	10609	0	1	26	257	750	1962	3221	2956	1221	204	12	0	(12)
(13)		CDH26.7	4197	0	0	1	39	173	731	1468	1348	409	28	0	0	(13)
(14)	Wind	WSAvg	3.4	3.6	3.8	4.0	3.8	3.2	2.9	3.0	2.8	3.1	3.0	3.5	3.5	(14)
(15)	Precipitation	PrecAvg	1258	83	94	125	131	128	93	86	84	86	99	125	125	(15)
(16)		PrecMax	1890	222	340	311	361	324	199	202	367	258	421	370	419	(16)
(17)		PrecMin	676	0	23	19	0	0	0	4	0	7	0	0	0	(17)
(18)		PrecStd	245	49	57	58	78	73	60	47	66	59	89	88	83	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.2	22.1	25.7	29.4	30.8	34.0	37.2	37.5	35.4	29.0	25.1	19.6	(19)
MCWB			18.1	15.8	17.0	18.5	22.3	24.2	25.0	24.6	24.0	21.6	18.8	16.4	(20)	
2%		DB	18.8	19.5	23.7	27.7	29.7	32.7	35.2	35.3	32.3	27.2	22.9	17.6	(21)	
		MCWB	15.8	14.4	16.0	19.2	22.2	23.2	24.8	24.9	23.1	20.0	17.9	15.1	(22)	
5%		DB	16.0	17.2	22.1	26.2	28.7	31.7	34.0	33.9	30.5	25.6	21.2	15.7	(23)	
		MCWB	11.9	13.4	15.4	18.7	21.5	23.4	24.7	24.8	22.7	19.3	16.9	13.0	(24)	
10%		DB	13.9	15.4	20.4	24.6	27.5	30.5	32.8	32.7	29.1	23.9	19.4	13.7	(25)	
		MCWB	10.1	11.0	14.2	17.9	21.0	23.1	24.5	24.5	22.0	18.5	15.5	10.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.5	17.0	19.8	22.3	24.9	26.2	27.2	27.3	25.1	23.2	20.5	17.5	(27)
MCD B			20.6	19.7	24.7	27.0	28.4	32.7	33.0	32.9	31.1	27.1	23.5	18.7	(28)	
2%		WB	17.1	15.6	17.9	21.1	23.7	25.2	26.3	26.2	24.4	21.7	19.2	15.7	(29)	
		MCD B	18.7	18.1	21.8	25.7	27.8	30.6	32.4	32.4	29.8	25.1	21.7	17.4	(30)	
5%		WB	13.2	13.8	16.7	20.0	22.8	24.6	25.7	25.6	23.7	20.5	17.8	13.7	(31)	
		MCD B	15.1	16.6	20.7	24.3	27.3	29.7	31.7	31.7	28.8	23.9	20.4	15.3	(32)	
10%		WB	10.1	11.8	15.0	18.9	22.1	24.0	25.1	25.0	23.0	19.4	16.1	11.3	(33)	
		MCD B	13.2	14.6	19.1	23.2	26.2	28.7	31.0	31.1	27.7	22.9	18.7	13.2	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.1	7.7	8.8	9.4	8.4	8.2	8.5	9.0	8.8	9.1	7.7	7.2	(35)
MCD BR			9.5	10.2	10.8	11.0	9.5	9.8	10.1	10.8	10.4	10.9	10.3	9.1	(36)	
MCWBR			7.7	7.2	6.7	5.4	3.9	3.7	3.0	3.3	3.7	5.5	7.1	7.9	(37)	
5% WB		MCD BR	8.8	8.9	9.5	8.9	8.2	8.5	9.3	9.7	8.5	8.4	8.8	8.4	(38)	
		MCWBR	8.6	7.6	7.0	5.2	4.2	3.9	3.5	3.8	3.7	4.9	7.5	8.2	(39)	
																(39)
(40)	Clear-Sky Solar Irradiance	taub	0.316	0.323	0.355	0.393	0.420	0.447	0.480	0.476	0.404	0.353	0.329	0.311	(40)	
taud		2.507	2.481	2.420	2.311	2.295	2.234	2.187	2.177	2.362	2.482	2.504	2.531	(41)		
Ebn at Noon		892	925	917	893	868	841	810	807	854	877	868	877	(42)		
Edh at Noon		83	95	110	128	132	140	146	145	115	94	83	77	(43)		
(44)	All-Sky Solar Radiation	RadAvg	2.49	2.97	4.12	5.19	5.68	6.43	6.21	5.72	4.91	3.80	2.71	2.19	(44)	
(45)		RadStd	0.22	0.42	0.35	0.36	0.45	0.49	0.35	0.41	0.38	0.51	0.30	0.24	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page