

LITTLE ROCK CLINTON, AR, USA

WMO: 723403

Lat: 34.727N

Lon: 92.239W

Elev: 258

StdP: 14.56

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13963

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.1	24.0	5.0	7.2	26.5	9.6	9.1	28.2	23.8	45.2	20.8	48.9	8.0	50	0.440

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.4	98.5	77.0	95.6	77.1	93.3	76.7	80.2	91.8	79.3	90.7	78.3	89.2	8.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.2	143.1	85.2	76.3	138.4	84.5	75.3	133.8	83.7	43.8	91.7	42.8	90.7	41.9	89.4	84.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
19.7	17.6	15.9	13.8	101.9	3.6	4.4	11.2	105.0	9.1	107.6	7.0	110.0	4.4	113.2	
			DB												
			WB	11.9	82.0	3.4	1.4	9.4	83.0	7.4	83.8	5.5	84.6	3.0	85.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	63.3	42.2	45.9	54.1	63.1	71.5	79.5	82.6	82.3	75.6	64.2	52.8	44.4
	DBStd	16.43	10.43	10.13	9.59	7.67	6.50	4.59	4.36	4.58	6.16	7.98	8.63	9.39
	HDD50	837	285	181	67	6	1	0	0	0	0	3	67	227
	HDD65	2881	708	536	356	123	22	0	0	0	5	115	375	641
	CDD50	5675	44	67	194	397	666	884	1011	1000	768	441	151	52
	CDD65	2249	2	2	18	65	223	434	546	535	324	89	9	2
	CDH74	23227	3	14	134	527	1848	4551	6309	6030	3005	748	54	4
	CDH80	10485	0	0	13	97	596	2081	3148	3040	1292	215	3	0
Wind	WSAvg	7.1	8.0	8.2	8.6	8.5	7.3	6.4	6.0	5.7	5.8	6.1	7.0	7.4
Precipitation	PrecAvg	50.4	3.9	3.7	5.3	5.3	5.1	3.3	3.6	2.8	3.3	4.5	4.6	5.1
	PrecMax	81.6	8.5	8.3	12.4	11.9	13.4	7.4	9.4	6.8	8.3	15.4	12.0	11.5
	PrecMin	36.3	0.4	1.3	2.1	1.7	1.1	1.0	0.7	0.2	0.6	0.5	1.0	0.7
	PrecStd	10.1	1.9	1.5	2.5	2.8	2.6	1.7	2.0	1.7	1.9	3.1	2.9	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.2	76.1	81.9	85.8	91.2	97.9	101.7	102.9	98.0	89.0	79.8	73.3
		MCWB	63.2	63.8	64.8	69.3	73.5	76.1	77.4	77.0	74.6	70.6	67.1	64.8
	2%	DB	68.3	71.5	78.0	82.9	88.5	94.8	98.1	99.0	93.7	85.6	74.9	68.3
		MCWB	61.0	61.5	63.7	67.1	72.5	76.6	77.8	77.1	75.0	70.1	64.1	61.8
	5%	DB	64.2	67.3	73.7	80.0	86.2	92.3	95.2	95.8	90.7	82.0	71.1	64.3
		MCWB	58.0	58.9	61.3	65.9	71.7	75.8	77.9	77.0	74.1	67.9	63.2	58.8
	10%	DB	59.4	63.1	69.8	76.9	83.5	90.1	92.9	93.0	87.7	78.2	67.3	59.8
		MCWB	52.4	55.5	59.5	64.6	71.1	75.2	77.6	76.5	72.6	66.5	59.3	53.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.9	66.9	68.5	73.4	77.8	80.3	81.5	81.3	78.5	75.5	70.2	67.1
		MCDB	71.0	72.8	77.7	80.8	86.0	91.4	92.9	93.3	90.7	83.5	75.1	70.9
	2%	WB	63.5	64.4	66.2	70.7	75.6	78.8	80.4	80.1	77.1	73.2	67.3	63.9
		MCDB	67.5	69.2	74.5	78.8	83.8	89.8	91.8	92.1	88.3	81.1	72.5	67.5
	5%	WB	59.4	61.0	64.0	69.0	74.2	77.8	79.4	79.1	76.0	71.1	64.6	59.8
		MCDB	62.9	65.8	71.1	76.5	82.6	88.4	90.9	90.7	86.0	77.7	69.5	63.7
	10%	WB	53.6	56.6	61.6	67.1	72.8	76.8	78.5	78.0	74.8	69.0	61.4	55.2
		MCDB	57.8	61.2	68.5	74.2	80.9	86.7	89.3	89.0	83.8	75.1	66.4	58.4
Mean Daily Temperature Range	5% DB	MDBR	18.0	18.7	19.8	20.7	19.1	18.4	18.4	19.3	20.1	21.1	19.4	17.3
		MCDBR	24.1	25.3	24.6	23.6	21.5	20.5	21.0	22.7	22.9	24.8	23.4	22.3
		MCWBR	17.1	16.8	13.7	11.4	8.6	7.1	6.2	6.5	7.7	11.2	14.9	16.2
	5% WB	MCDBR	19.8	21.3	20.7	19.0	18.3	18.1	18.8	19.8	19.2	19.3	19.5	19.8
	MCWBR	16.7	16.7	13.8	11.5	9.0	7.6	6.9	7.1	7.3	10.8	15.2	16.3	
Clear-Sky Solar Irradiance	taub	0.321	0.329	0.361	0.400	0.429	0.455	0.490	0.485	0.412	0.359	0.335	0.316	
	taud	2.500	2.471	2.410	2.297	2.280	2.221	2.166	2.158	2.348	2.472	2.494	2.523	
	Ebn at Noon	281	291	289	281	273	265	255	253	269	276	273	276	
	Edh at Noon	27	30	35	41	43	45	47	47	37	30	27	25	
All-Sky Solar Radiation	RadAvg	791	944	1310	1650	1807	2041	1974	1817	1560	1210	864	697	
	RadStd	70	134	114	113	141	157	110	133	120	164	96	76	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (25 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page