

LITTLE ROCK AFB, AR, USA

WMO: 723405

Lat: 34.917N

Lon: 92.150W

Elev: 311

StdP: 14.53

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 03930

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.6	21.7	5.1	7.2	24.5	10.2	9.4	26.4	21.8	50.5	19.5	48.5	4.8	20	0.418

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.1	99.6	77.2	96.7	77.7	94.1	77.4	81.3	91.8	80.3	90.7	79.2	89.5	8.4	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.0	152.5	84.9	77.5	144.7	84.4	76.8	141.1	83.9	45.1	91.8	44.0	90.6	42.8	89.5	86.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.4	16.1	13.7		DB	9.3	102.1	4.7	4.0	5.9	104.9	3.2	107.3	0.6	109.5	-2.8	112.4
				WB	8.7	83.5	4.2	1.1	5.6	84.3	3.1	85.0	0.8	85.6	-2.3	86.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.3	40.6	45.5	53.2	62.5	70.5	79.2	82.4	81.4	74.0	63.5	50.4	43.1	(6)
	DBStd	16.80	10.57	10.62	9.76	8.10	6.70	4.93	4.76	4.94	6.18	8.06	8.75	9.74	(7)
	HDD50	972	327	194	78	7	1	0	0	0	0	4	99	262	(8)
	HDD65	3117	758	549	381	140	30	0	0	0	7	127	444	681	(9)
	CDD50	5456	35	68	178	382	635	877	1005	974	720	424	111	47	(10)
	CDD65	2125	1	3	16	64	199	428	540	509	277	81	6	1	(11)
	CDH74	23127	3	19	148	600	1819	4716	6417	5764	2726	873	40	2	(12)
	CDH80	10859	0	0	21	121	596	2280	3379	2996	1189	272	5	0	(13)
(14) Wind	WSAvg	5.8	6.5	6.8	7.2	7.1	5.9	5.6	5.1	4.7	4.8	5.2	5.6	5.9	(14)
(15) Precipitation	PrecAvg	50.0	3.6	3.5	5.1	5.2	5.3	3.2	3.5	3.1	3.2	4.3	4.9	4.8	(15)
	PrecMax	75.7	7.9	8.4	10.7	11.3	12.6	7.2	9.1	7.2	8.2	14.8	12.6	9.1	(16)
	PrecMin	36.7	0.2	1.2	1.6	1.5	1.1	1.0	0.7	0.2	0.4	0.4	1.1	0.6	(17)
	PrecStd	9.6	1.9	1.5	2.4	2.6	2.5	1.8	2.0	1.9	1.9	3.0	3.1	2.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.9	77.0	82.4	87.0	91.4	99.9	103.9	104.2	98.7	90.2	79.3	72.5	(19)
		MCWB	62.4	65.0	65.1	69.1	73.3	77.0	77.9	76.8	75.8	70.6	66.5	64.4	(20)
	2%	DB	67.7	72.3	78.5	83.5	88.7	96.0	99.4	99.8	93.6	86.5	73.7	68.2	(21)
		MCWB	60.5	62.1	63.9	67.5	72.7	77.3	78.2	76.8	74.9	69.6	64.0	62.3	(22)
	5%	DB	63.4	68.2	73.6	80.9	86.2	93.3	96.5	96.6	90.6	82.9	70.1	64.0	(23)
		MCWB	56.7	59.8	61.2	66.3	72.0	76.6	78.7	77.3	74.1	68.0	62.4	58.9	(24)
	10%	DB	58.9	63.8	69.8	77.5	83.5	90.9	93.6	93.2	87.2	79.3	66.1	59.4	(25)
		MCWB	52.4	56.6	59.0	64.9	71.2	76.2	78.3	77.5	72.1	66.6	59.1	54.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.7	67.9	69.2	73.6	78.2	81.3	83.1	82.8	79.5	75.5	70.5	67.7	(27)
		MCDB	71.3	73.4	79.7	81.7	85.1	91.9	92.7	92.5	90.8	84.0	75.1	69.8	(28)
	2%	WB	62.5	65.5	66.7	71.2	75.8	79.7	81.4	81.4	77.8	73.4	67.4	64.1	(29)
		MCDB	66.0	70.6	74.8	79.5	83.9	90.2	92.3	91.3	88.0	80.6	71.0	67.2	(30)
	5%	WB	58.8	62.2	64.2	69.4	74.4	78.6	80.4	80.3	76.5	71.4	64.0	59.9	(31)
		MCDB	62.0	66.0	70.4	76.8	82.4	88.8	91.4	89.9	85.8	78.4	68.5	63.1	(32)
	10%	WB	52.9	57.7	61.3	67.5	73.0	77.6	79.3	79.1	75.1	69.1	60.0	55.2	(33)
		MCDB	57.1	61.9	67.6	74.5	80.6	87.7	90.3	88.4	83.4	76.1	64.7	58.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	20.1	20.9	21.6	22.8	20.9	20.3	20.1	21.0	22.6	24.7	21.8	18.7	(35)
		MCDBR	26.8	26.9	27.0	25.3	23.9	23.0	22.9	25.3	26.1	28.8	26.0	23.9	(36)
	5% WB	MCWBR	19.1	18.4	15.6	12.6	9.9	7.9	6.9	7.5	9.4	13.6	16.9	18.2	(37)
		MCWBR	20.3	21.8	21.9	19.8	19.5	19.8	20.6	20.4	21.0	22.2	19.9	20.3	(38)
(40) Clear-Sky Solar Irradiance	taub		0.320	0.327	0.360	0.398	0.428	0.455	0.488	0.482	0.411	0.358	0.333	0.314	(40)
		taud	2.495	2.469	2.406	2.298	2.277	2.214	2.166	2.161	2.347	2.471	2.496	2.519	(41)
	Ebn at Noon		281	292	289	282	273	265	255	254	269	277	273	276	(42)
		Edh at Noon	27	30	35	41	43	45	47	47	37	30	26	25	(43)
(44) All-Sky Solar Radiation	RadAvg		787	945	1309	1649	1806	2045	1972	1818	1557	1204	859	692	(44)
	RadStd		69	132	110	115	140	153	110	130	120	161	95	75	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page