

LITTLE ROCK AFB, AR, USA

WMO: 723405

Lat: 34.917N

Lon: 92.150W

Elev: 95

StdP: 100.19

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 03930

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -8.0	(c) -5.7	(d) -14.9	(e) 1.0	(f) -4.2	(g) -12.1	(h) 1.3	(i) -3.1	(j) 9.8	(k) 10.3	(l) 8.7	(m) 9.2	(n) 2.1	(o) 20	(p) 0.418

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	37.5	25.1	36.0	25.4	34.5	25.2	27.4	33.2	26.8	32.6	26.2	31.9	3.7	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.1	21.8	29.4	25.3	20.7	29.1	24.9	20.2	28.9	87.0	33.2	84.4	32.5	81.8	31.9	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.2	(b) 7.2	(c) 6.1	(e) -12.6	(f) 38.9	(g) 2.6	(h) 2.2	(i) -14.5	(j) 40.5	(k) -16.0	(l) 41.8	(m) -17.5	(n) 43.0	(o) -19.4	(p) 44.6		
(a) 8.2	(b) 7.2	(c) 6.1	(e) -13.0	(f) 28.6	(g) 2.3	(h) 0.6	(i) -14.7	(j) 29.0	(k) -16.0	(l) 29.4	(m) -17.4	(n) 29.8	(o) -19.1	(p) 30.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.8	4.8	7.5	11.8	16.9	21.4	26.2	28.0	27.5	23.3	17.5	10.2	6.1	(6)
(7)		DBStd	9.33	5.87	5.90	5.42	4.50	3.72	2.74	2.64	2.74	3.44	4.48	4.86	5.41	(7)
(8)		HDD10.0	540	182	108	43	4	1	0	0	0	0	2	55	146	(8)
(9)		HDD18.3	1732	421	305	212	78	17	0	0	0	4	71	247	378	(9)
(10)		CDD10.0	3031	19	38	99	212	353	487	558	541	400	236	62	26	(10)
(11)		CDD18.3	1181	1	2	9	36	111	238	300	283	154	45	3	1	(11)
(12)		CDH23.3	12848	2	11	82	333	1011	2620	3565	3202	1514	485	22	1	(12)
(13)		CDH26.7	6033	0	0	12	67	331	1267	1877	1664	661	151	3	0	(13)
(14)	Wind	WSAvg	2.6	2.9	3.0	3.2	3.2	2.6	2.5	2.3	2.1	2.1	2.3	2.5	2.6	(14)
(15)	Precipitation	PrecAvg	1271	91	89	129	132	135	82	90	78	82	110	125	123	(15)
(16)		PrecMax	1923	201	213	272	286	319	182	231	183	208	377	320	230	(16)
(17)		PrecMin	932	5	31	41	37	27	26	18	6	9	11	27	14	(17)
(18)		PrecStd	245	48	37	60	65	64	46	50	47	49	77	79	53	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.7	25.0	28.0	30.6	33.0	37.7	39.9	40.1	37.1	32.3	26.3	22.5	(19)
(20)			MCWB	16.9	18.3	18.4	20.6	23.0	25.0	25.5	24.9	24.4	21.4	19.2	18.0	(20)
(21)		2%	DB	19.8	22.4	25.9	28.6	31.5	35.6	37.5	37.7	34.2	30.3	23.2	20.1	(21)
(22)			MCWB	15.8	16.7	17.7	19.7	22.6	25.2	25.7	24.9	23.8	20.9	17.8	16.8	(22)
(23)		5%	DB	17.4	20.1	23.1	27.2	30.1	34.0	35.9	35.9	32.5	28.3	21.2	17.8	(23)
(24)			MCWB	13.7	15.4	16.2	19.1	22.2	24.8	25.9	25.2	23.4	20.0	16.9	14.9	(24)
(25)		10%	DB	15.0	17.7	21.0	25.3	28.6	32.7	34.2	34.0	30.7	26.3	18.9	15.2	(25)
(26)			MCWB	11.3	13.7	15.0	18.3	21.8	24.6	25.7	25.3	22.3	19.2	15.1	12.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.7	20.0	20.7	23.1	25.7	27.4	28.4	28.2	26.4	24.2	21.4	19.8	(27)
(28)			MCD B	21.8	23.0	26.5	27.6	29.5	33.3	33.7	33.6	32.6	28.9	24.0	21.0	(28)
(29)		2%	WB	16.9	18.6	19.3	21.8	24.3	26.5	27.4	27.4	25.5	23.0	19.7	17.8	(29)
(30)			MCD B	18.9	21.5	23.8	26.4	28.8	32.4	33.5	33.0	31.1	27.0	21.7	19.6	(30)
(31)		5%	WB	14.9	16.8	17.9	20.8	23.6	25.9	26.9	26.8	24.7	21.9	17.8	15.5	(31)
(32)			MCD B	16.7	18.9	21.3	24.9	28.0	31.6	33.0	32.2	29.9	25.8	20.3	17.3	(32)
(33)		10%	WB	11.6	14.3	16.3	19.7	22.8	25.4	26.3	26.2	23.9	20.6	15.5	12.9	(33)
(34)			MCD B	14.0	16.6	19.8	23.6	27.0	30.9	32.4	31.3	28.6	24.5	18.2	14.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.2	11.6	12.0	12.6	11.6	11.3	11.2	11.7	12.6	13.7	12.1	10.4	(35)
(36)			MCDBR	14.9	14.9	15.0	14.0	13.3	12.8	12.7	14.0	14.5	16.0	14.5	13.3	(36)
(37)			MCWBR	10.6	10.2	8.7	7.0	5.5	4.4	3.8	4.1	5.2	7.6	9.4	10.1	(37)
(38)		5% WB	MCD BR	11.3	12.1	12.2	11.0	10.8	11.0	11.4	11.3	11.7	12.3	11.1	11.3	(38)
(39)			MCWBR	9.9	9.7	8.6	6.6	5.4	4.5	4.4	4.5	4.7	7.1	8.8	10.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.320	0.327	0.360	0.398	0.428	0.455	0.488	0.482	0.411	0.358	0.333	0.314	(40)	
(41)		taud	2.495	2.469	2.406	2.298	2.277	2.214	2.166	2.161	2.347	2.471	2.496	2.519	(41)	
(42)		Ebn at Noon	886	919	912	888	861	834	804	801	848	872	862	870	(42)	
(43)		Edh at Noon	84	96	111	130	135	143	149	147	117	95	83	78	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.48	2.98	4.13	5.20	5.69	6.45	6.22	5.73	4.91	3.80	2.71	2.18	(44)	
(45)		RadStd	0.22	0.42	0.35	0.36	0.44	0.48	0.35	0.41	0.38	0.51	0.30	0.24	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (26 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page