

JONESBORO, AR, USA

WMO: 723407

Lat: 35.831N

Lon: 90.646W

Elev: 80

StdP: 100.37

Time Zone: -6.00 (NAC)

Period: 96-19

WBAN: 03953

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.4	-6.3	-15.1	1.0	-6.4	-12.7	1.3	-4.7	11.5	14.2	10.6	10.9	3.1	50	0.465

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	36.0	24.9	34.6	24.7	33.5	24.5	26.9	32.5	26.3	32.1	25.7	31.2	4.2	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.5	20.9	29.7	24.8	20.0	29.1	24.1	19.1	28.6	84.8	32.5	81.9	32.1	79.4	31.4	32.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	8.7	7.8	DB	-11.6	37.8	2.4	1.8	-13.3	39.1	-14.7	40.1	-16.1	41.2	-17.9	42.5	(4)
(5)			WB	-12.5	28.1	2.2	1.1	-14.1	28.9	-15.4	29.6	-16.6	30.2	-18.2	31.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.1	3.7	5.8	10.4	16.1	21.2	26.0	27.3	26.7	23.2	16.7	10.0	5.2	(6)	
	DBStd	9.58	6.03	5.62	5.43	4.54	3.97	2.83	2.48	2.57	3.47	4.68	4.94	5.33	(7)	
	HDD10.0	650	211	140	61	7	0	0	0	0	0	4	60	168	(8)	
	HDD18.3	1923	453	351	251	94	20	0	0	0	5	87	253	409	(9)	
	CDD10.0	2868	16	23	74	189	346	481	537	517	396	213	59	18	(10)	
	CDD18.3	1099	0	1	5	27	108	231	278	259	151	38	2	0	(11)	
	CDH23.3	11233	0	1	31	204	942	2506	3105	2704	1367	354	18	0	(12)	
	CDH26.7	4947	0	0	2	32	317	1185	1462	1269	576	103	1	0	(13)	
(14) Wind	WSAvg	3.4	3.9	4.1	4.1	4.2	3.5	3.1	2.8	2.7	2.7	3.0	3.4	3.6	(14)	
(15) Precipitation	PrecAvg	1182	83	91	120	127	128	82	70	79	93	83	119	108	(15)	
	PrecMax	1661	210	232	300	289	254	185	152	216	262	398	248	254	(16)	
	PrecMin	739	18	8	8	46	14	11	2	0	10	1	31	14	(17)	
	PrecStd	213	57	58	70	68	60	48	38	59	73	76	60	61	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.0	22.5	26.5	29.1	33.6	36.7	37.6	37.6	35.9	31.8	26.0	21.1	(19)	
		MCWB	17.3	18.0	18.4	20.0	23.0	24.3	25.3	25.5	23.4	22.8	18.3	17.8	(20)	
	2%	DB	18.0	19.8	23.9	27.5	31.7	35.1	35.6	35.9	33.8	29.4	22.6	18.0	(21)	
		MCWB	15.7	16.6	17.9	19.5	22.2	24.3	25.5	25.2	23.6	20.8	16.9	15.7	(22)	
	5%	DB	16.1	17.5	21.5	26.0	30.0	33.8	34.1	34.0	32.2	27.4	20.5	16.1	(23)	
		MCWB	13.3	14.3	16.2	18.6	21.5	24.0	25.4	25.0	23.3	19.0	16.1	13.8	(24)	
	10%	DB	13.0	15.1	19.1	23.9	28.2	32.5	32.9	32.6	30.2	25.0	17.9	13.5	(25)	
		MCWB	10.5	12.1	14.8	17.8	21.0	23.6	25.3	24.7	22.4	18.2	14.4	11.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.1	19.0	20.0	22.3	25.1	27.0	27.9	27.6	26.1	24.4	20.6	18.6	(27)	
		MCDB	19.7	21.2	24.5	26.8	30.2	32.3	33.1	33.2	31.6	29.5	23.3	20.6	(28)	
	2%	WB	16.6	16.9	18.5	20.9	23.9	25.9	27.1	26.8	25.2	22.5	18.5	16.6	(29)	
		MCDB	18.0	18.9	22.9	25.4	28.8	31.9	32.6	32.8	31.0	27.0	21.4	17.9	(30)	
	5%	WB	13.9	15.0	17.1	19.9	22.9	25.2	26.5	26.1	24.3	21.1	16.9	14.1	(31)	
		MCDB	15.3	17.2	20.8	24.1	27.9	31.3	32.1	32.1	29.6	24.8	19.5	15.6	(32)	
	10%	WB	10.8	12.5	15.6	18.9	22.1	24.6	25.9	25.5	23.5	19.9	15.1	11.7	(33)	
		MCDB	12.6	14.5	18.7	22.8	26.8	30.5	31.2	30.9	28.4	23.5	17.6	13.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.8	9.2	10.3	11.0	11.0	11.0	9.9	10.4	11.6	12.0	10.3	8.6	(35)	
		MCDBR	11.2	12.1	12.6	12.6	12.6	12.6	11.2	12.1	13.6	14.6	13.3	11.1	(36)	
	5% WB	MCWBR	9.1	9.2	7.9	6.6	5.1	4.3	3.8	4.4	5.2	6.9	8.5	9.0	(37)	
		MCWBR	10.0	11.2	11.2	10.3	10.4	10.9	10.0	10.5	11.4	11.9	10.9	9.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.318	0.325	0.362	0.406	0.444	0.464	0.488	0.479	0.416	0.355	0.327	0.312	(40)	
		taud	2.475	2.454	2.380	2.249	2.207	2.159	2.133	2.134	2.304	2.460	2.493	2.507	(41)	
	Ebn at Noon		881	916	906	878	846	826	802	802	838	870	863	865	(42)	
		Edh at Noon	84	96	113	136	144	151	154	151	121	95	82	77	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.39	2.95	4.07	5.19	5.80	6.57	6.30	5.78	4.88	3.74	2.62	2.05	(44)	
	RadStd		0.21	0.39	0.34	0.35	0.42	0.41	0.30	0.36	0.35	0.44	0.28	0.22	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (26 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page