

MT IDA, AR, USA

WMO: 723435

Lat: 34.547N

Lon: 93.578W

Elev: 214

StdP: 98.78

Time Zone: -6.00 (NAC)

Period: 99-19

WBAN: 53921

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.5	-5.5	-14.2	1.1	-2.3	-12.2	1.3	-0.7	7.0	7.2	5.8	9.4	0.6	320	0.357

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.7	36.5	23.9	35.0	24.0	33.5	23.8	26.1	31.9	25.5	31.6	25.0	31.0	2.0	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.6	20.1	28.3	23.9	19.3	27.9	23.3	18.6	27.4	81.9	32.0	79.3	31.7	77.1	31.1	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
5.5	4.8	4.2		-12.3	38.5	2.2	2.3	-13.9	40.1	-15.2	41.5	-16.4	42.8	-18.0	44.4
			DB	-12.4	27.2	2.3	1.0	-14.1	28.0	-15.5	28.6	-16.8	29.2	-18.5	29.9
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.5	5.4	7.1	11.8	16.4	20.5	25.1	26.9	26.9	22.9	16.6	10.8	6.6	(6)
(7)		DBStd	8.88	5.74	5.75	5.25	4.42	3.71	2.45	2.49	2.66	3.63	4.83	5.19	5.25	(7)
(8)		HDD10.0	519	167	115	41	5	1	0	0	0	0	6	51	135	(8)
(9)		HDD18.3	1732	403	314	211	87	22	0	0	0	6	92	231	366	(9)
(10)		CDD10.0	2882	23	36	97	197	327	453	524	522	387	211	76	28	(10)
(11)		CDD18.3	1052	1	1	8	29	91	203	266	264	144	38	6	1	(11)
(12)		CDH23.3	10647	3	5	53	234	744	2054	2847	2872	1447	357	29	2	(12)
(13)		CDH26.7	4732	0	0	4	29	182	872	1431	1492	625	94	3	0	(13)
(14)	Wind	WSAvg	1.2	1.5	1.5	1.7	1.7	1.3	1.0	0.8	0.8	1.0	1.3	1.4	(14)	
(15)	Precipitation	PrecAvg	1379	112	98	126	132	156	107	95	74	114	123	116	127	(15)
(16)		PrecMax	1940	207	214	291	283	384	216	221	281	322	290	294	205	(16)
(17)		PrecMin	851	23	42	38	54	51	20	21	16	0	0	28	10	(17)
(18)		PrecStd	263	48	45	57	54	77	58	51	53	68	80	75	54	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.7	24.0	27.2	29.1	31.9	35.9	38.0	38.9	36.2	31.6	26.7	22.8	(19)
(20)			MCWB	15.7	15.8	17.4	19.2	22.2	23.7	24.0	24.2	22.9	21.0	19.1	17.6	(20)
(21)		2%	DB	20.4	21.6	24.8	27.4	30.1	33.9	36.3	37.2	34.0	29.1	23.7	20.9	(21)
(22)			MCWB	15.1	16.5	16.6	18.7	21.7	24.0	24.4	23.8	22.9	20.9	17.5	17.5	(22)
(23)		5%	DB	18.4	19.5	22.8	26.1	28.7	32.5	34.6	35.3	32.3	27.3	22.1	18.5	(23)
(24)			MCWB	14.3	14.9	15.8	18.2	21.4	23.6	24.4	24.1	22.4	19.7	17.1	14.8	(24)
(25)		10%	DB	16.1	17.5	21.2	24.4	27.4	31.2	32.9	33.6	30.5	25.1	20.0	16.2	(25)
(26)			MCWB	11.1	13.1	15.2	17.6	21.0	23.4	24.4	23.8	22.2	18.9	15.6	11.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.6	19.0	19.4	22.0	24.4	26.3	26.8	26.9	25.4	23.8	21.1	19.2	(27)
(28)			MCD B	22.2	21.8	24.2	26.4	29.1	32.1	32.1	32.2	30.7	28.3	23.9	21.6	(28)
(29)		2%	WB	17.1	17.8	18.5	20.8	23.5	25.5	26.0	26.1	24.6	22.6	19.4	17.7	(29)
(30)			MCD B	19.4	20.2	22.7	25.1	27.9	31.2	32.1	31.8	30.0	26.7	22.6	19.8	(30)
(31)		5%	WB	15.1	15.9	17.4	20.0	22.8	24.8	25.5	25.5	24.0	21.5	17.9	15.4	(31)
(32)			MCD B	17.5	18.7	21.4	24.3	27.0	30.2	31.8	31.5	29.3	25.1	20.7	17.9	(32)
(33)		10%	WB	11.4	13.8	16.1	19.1	21.9	24.2	25.1	24.9	23.3	20.3	16.2	12.7	(33)
(34)			MCD B	14.4	16.5	20.3	23.1	26.1	29.2	31.2	30.9	28.4	23.7	19.2	15.0	(34)
(35)	Mean Daily Temperature Range	MDBR		11.8	11.3	12.4	12.4	11.1	11.4	11.7	12.5	13.4	13.2	12.5	11.7	(35)
(36)		5% DB	MCD BR	14.3	13.7	13.7	13.6	12.5	13.2	13.7	15.1	15.2	14.8	13.6	13.9	(36)
(37)			MCWBR	9.8	9.4	7.6	6.7	5.7	4.9	4.0	4.5	5.3	7.1	8.1	10.0	(37)
(38)		5% WB	MCD BR	10.9	11.2	11.3	9.9	9.8	10.9	11.7	12.0	12.1	10.9	10.5	11.5	(38)
(39)			MCWBR	9.4	8.9	7.2	6.0	5.3	4.7	4.3	4.5	4.8	6.1	8.0	9.6	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.321	0.324	0.355	0.387	0.419	0.459	0.471	0.469	0.399	0.355	0.332	0.311	(40)
(41)		taud		2.496	2.488	2.426	2.339	2.310	2.225	2.229	2.218	2.387	2.489	2.508	2.536	(41)
(42)		Ebn at Noon		887	925	918	899	870	831	819	814	861	878	867	879	(42)
(43)		Edh at Noon		84	94	109	125	130	142	140	139	112	93	83	77	(43)
(44)	All-Sky Solar Radiation	RadAvg		2.53	2.94	4.09	5.12	5.56	6.27	6.17	5.70	4.89	3.77	2.69	2.20	(44)
(45)		RadStd		0.23	0.42	0.31	0.30	0.52	0.58	0.38	0.43	0.41	0.54	0.32	0.27	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47)	Regional (22 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page