

BAXTER COUNTY AP, AR, USAWMO: **723439**Lat: **36.369N**Lon: **92.470W**Elev: **928**StdP: **14.21**Time Zone: **-6.00 (NAC)**Period: **94-19**WBAN: **53918****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.0	17.3	-0.4	5.6	17.1	3.5	6.8	20.2	18.6	49.1	16.7	48.4	4.4	320	0.394

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.0	96.8	74.4	93.2	74.5	90.7	74.3	78.4	89.1	77.3	88.1	76.2	86.4	5.7	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.5	138.0	83.6	74.3	132.5	82.3	73.1	127.3	81.2	42.5	89.4	41.3	88.0	40.2	86.5	82.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.2	13.2	11.7	5.3	99.8	3.8	4.6	2.5	103.2	0.3	105.9	-1.9	108.5	-4.7	111.8		
			4.5	79.7	3.9	1.5	1.7	80.8	-0.5	81.6	-2.7	82.5	-5.5	83.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	59.1	37.2	41.1	49.8	59.4	67.1	75.3	79.2	78.8	71.0	60.1	49.3	39.9
	DBStd	17.03	11.34	11.08	10.31	8.44	7.13	5.15	4.77	5.13	6.92	8.43	9.25	9.97
	HDD50	1339	418	289	132	19	2	0	0	0	0	14	124	341
	HDD65	3764	861	671	482	205	64	2	0	0	25	199	475	780
	CDD50	4663	22	39	124	300	533	760	906	892	631	326	103	27
	CDD65	1613	0	1	9	36	130	313	441	427	206	46	4	0
	CDH74	15471	0	8	86	348	1033	2912	4513	4267	1866	403	34	1
	CDH80	6508	0	0	12	65	267	1161	2125	2058	724	94	2	0
Wind	WSAvg	4.7	5.6	5.8	6.2	6.1	4.6	3.8	3.2	3.3	3.4	4.0	5.0	5.3
Precipitation	PrecAvg	44.8	3.3	3.0	4.1	4.7	4.9	3.7	3.7	3.1	3.8	3.3	4.1	3.4
	PrecMax	58.1	6.0	6.1	13.6	16.1	10.0	6.9	8.3	6.9	10.2	11.0	12.5	9.0
	PrecMin	32.8	0.9	0.7	0.7	1.1	1.4	1.5	1.1	0.3	0.0	0.3	0.6	0.4
	PrecStd	7.9	1.4	1.5	2.6	3.0	2.0	1.5	1.7	1.8	2.6	2.4	3.1	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.5	74.9	81.3	85.6	89.8	95.4	100.1	101.6	95.5	87.0	78.9	70.2
		MCWB	58.2	58.5	61.3	66.1	70.4	74.8	73.9	73.1	72.2	70.3	63.3	59.6
	2%	DB	65.6	68.9	76.2	81.6	86.0	91.5	96.7	97.0	90.7	82.4	72.9	64.6
		MCWB	56.9	55.9	60.2	63.3	70.9	74.8	75.0	74.3	71.9	66.8	59.8	56.9
	5%	DB	60.8	64.1	71.8	78.5	83.0	89.5	93.0	93.4	88.0	78.9	69.4	60.7
		MCWB	52.1	54.1	57.6	62.1	69.6	74.1	75.4	74.2	71.3	64.9	59.0	53.4
	10%	DB	54.9	59.7	67.0	74.5	80.3	86.7	90.5	90.5	84.0	74.5	64.5	55.2
		MCWB	47.8	50.7	55.5	60.6	68.1	73.3	75.4	73.9	69.7	63.4	55.9	48.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	62.0	63.2	65.5	68.9	75.4	78.8	80.1	80.0	76.9	73.0	66.7	62.9
		MCDB	67.6	70.4	77.3	80.0	84.6	89.6	90.2	90.7	86.9	82.3	73.7	67.3
	2%	WB	58.8	59.8	62.5	67.0	73.1	77.2	78.5	78.1	75.0	70.7	63.1	58.9
		MCDB	64.4	66.0	72.4	76.9	82.3	87.9	89.2	89.0	84.4	78.4	69.7	64.0
	5%	WB	53.4	56.0	60.1	65.2	71.4	75.8	77.6	76.8	73.4	68.1	60.5	54.4
		MCDB	57.9	62.0	68.5	73.9	80.1	85.6	88.5	87.5	82.7	74.4	67.1	58.6
	10%	WB	48.0	50.9	57.3	63.2	69.6	74.6	76.5	75.4	72.0	65.6	57.4	50.5
		MCDB	53.6	59.0	65.1	71.1	77.5	83.8	86.8	85.5	80.8	72.3	63.4	54.7
Mean Daily Temperature Range	5% DB	MDBR	18.6	19.6	21.1	22.0	20.0	19.7	20.0	21.1	21.8	21.7	20.0	17.6
		MCDBR	26.3	27.4	27.2	26.6	22.6	22.6	23.9	25.1	25.5	25.7	26.4	23.2
		MCWBR	17.4	17.7	14.7	13.1	10.8	9.4	7.8	8.2	9.5	12.6	16.0	16.2
	5% WB	MCDBR	22.0	22.7	22.4	20.9	19.2	19.4	20.1	20.9	20.5	20.6	21.6	20.4
		MCWBR	17.3	17.5	14.1	12.1	10.3	9.2	8.1	8.2	8.4	11.6	15.6	16.6
Clear-Sky Solar Irradiance	taub	0.306	0.311	0.346	0.381	0.417	0.433	0.463	0.460	0.393	0.349	0.319	0.298	
	taud	2.501	2.479	2.419	2.325	2.284	2.255	2.227	2.207	2.379	2.486	2.521	2.537	
	Ebn at Noon	283	295	292	286	276	270	261	259	273	278	276	279	
	Edh at Noon	26	30	34	40	42	43	44	44	36	29	25	23	
All-Sky Solar Radiation	RadAvg	768	951	1289	1632	1793	2049	1969	1802	1541	1162	831	655	
	RadStd	65	117	83	104	158	138	114	117	121	141	92	83	