

BATESVILLE, AR, USAWMO: **723448**Lat: **35.726N**Lon: **91.647W**Elev: **463**StdP: **14.45**Time Zone: **-6.00 (NAC)**Period: **94-19**WBAN: **53934****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.1	19.8	0.8	5.8	21.7	6.5	7.8	26.0	19.4	52.1	17.5	51.3	4.3	320	0.406

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.8	97.4	76.3	94.6	76.0	91.8	75.5	79.6	91.5	78.3	90.2	77.4	89.1	7.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.8	137.1	85.9	75.0	133.3	85.0	73.4	126.3	83.1	43.3	91.8	42.2	90.4	41.1	89.0	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.8	14.6	12.4	9.1	100.7	4.1	3.9	6.1	103.5	3.7	105.7	1.4	107.9	-1.5	110.7		
			7.7	81.3	3.7	1.7	5.0	82.6	2.8	83.6	0.8	84.5	-2.0	85.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.9	39.5	43.3	51.5	60.9	69.2	77.3	80.8	80.1	72.7	61.8	50.6	42.1
	DBStd	16.81	10.95	10.56	10.25	8.26	7.16	5.28	4.88	5.20	6.81	8.39	9.17	9.73
	HDD50	1110	356	237	107	13	1	0	0	0	0	9	103	284
	HDD65	3378	791	608	433	172	44	1	0	0	16	162	439	712
	CDD50	5088	30	50	152	339	597	819	954	933	680	376	120	38
	CDD65	1885	1	2	13	49	175	370	489	469	246	64	6	1
	CDH74	19299	1	7	81	378	1442	3852	5486	5095	2360	559	37	1
	CDH80	8567	0	0	6	62	410	1706	2702	2553	984	141	3	0
Wind	WSAvg	5.3	6.0	6.2	6.6	6.7	5.3	4.6	4.3	4.1	4.1	4.7	5.5	5.6
Precipitation	PrecAvg	50.0	4.1	3.8	4.9	4.6	4.8	3.9	3.8	3.2	3.2	3.7	4.6	4.8
	PrecMax	69.6	8.4	7.2	10.6	11.3	10.2	11.3	7.4	6.7	8.7	12.0	12.3	10.1
	PrecMin	26.8	1.5	1.4	1.3	0.3	0.7	1.2	1.0	0.7	0.0	0.2	0.4	0.3
	PrecStd	10.3	1.6	1.7	2.2	2.4	2.4	2.1	1.7	1.7	2.1	2.6	3.3	2.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.4	74.7	80.9	84.3	90.4	97.5	100.2	101.7	97.2	88.3	79.2	70.4
		MCWB	61.2	62.1	64.1	68.2	72.9	76.0	76.3	75.8	73.4	70.5	64.8	62.9
	2%	DB	65.6	69.6	75.5	81.6	87.7	93.3	97.2	98.6	92.6	83.8	72.9	65.7
		MCWB	59.2	59.8	61.9	65.6	72.5	75.2	77.2	76.0	73.6	68.7	61.7	60.4
	5%	DB	61.5	64.3	72.2	79.0	84.1	91.1	93.5	94.7	90.0	80.8	69.9	62.6
		MCWB	53.7	55.9	59.9	64.2	71.2	74.9	76.9	75.8	72.5	66.1	61.1	56.2
	10%	DB	56.8	61.0	68.0	75.0	81.7	89.7	91.3	91.2	85.9	76.1	65.7	57.0
		MCWB	49.8	51.9	57.5	62.6	69.5	74.5	76.8	75.1	71.3	64.4	58.2	51.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.1	65.4	67.2	71.1	76.4	80.0	81.4	81.1	77.9	74.2	68.4	64.8
		MCDB	67.6	71.6	77.0	81.0	85.9	91.7	92.6	92.6	89.8	83.1	74.6	68.3
	2%	WB	61.6	62.2	64.5	68.9	74.5	77.9	79.9	79.3	76.2	71.4	65.2	61.6
		MCDB	64.9	66.6	73.0	77.9	83.6	89.3	91.7	91.3	87.7	79.1	70.5	64.9
	5%	WB	56.4	58.3	62.1	67.1	72.8	76.7	78.6	78.0	74.8	68.9	62.2	57.0
		MCDB	60.2	63.9	69.8	75.3	81.9	87.9	90.5	90.1	85.4	76.3	67.8	61.3
	10%	WB	50.6	53.2	59.3	65.2	71.2	75.5	77.8	76.9	73.2	66.5	58.7	52.6
		MCDB	56.2	58.8	66.4	72.7	79.8	86.3	89.5	88.4	82.5	74.3	64.9	56.5
Mean Daily Temperature Range	5% DB	MDBR	17.4	18.2	19.6	20.9	19.6	19.9	19.8	21.0	22.2	21.9	19.0	16.6
		MCDBR	22.3	23.4	23.1	23.5	21.4	22.3	21.8	24.2	25.6	25.6	22.7	20.6
		MCWBR	16.7	16.5	13.8	12.7	10.4	9.0	8.0	8.1	10.1	13.1	14.8	15.4
	5% WB	MCDBR	18.6	20.2	20.0	18.4	18.2	18.9	19.7	20.3	21.6	20.7	19.1	18.4
		MCWBR	17.0	16.8	14.0	11.9	10.0	8.8	8.2	8.4	9.5	12.1	15.1	15.9
Clear-Sky Solar Irradiance	taub	0.315	0.322	0.357	0.391	0.431	0.455	0.486	0.474	0.410	0.355	0.324	0.308	
	taud	2.485	2.463	2.398	2.299	2.249	2.197	2.159	2.168	2.339	2.473	2.511	2.520	
	Ebn at Noon	281	292	289	283	272	264	255	256	268	276	275	277	
	Edh at Noon	26	30	35	41	44	46	48	46	37	30	26	24	
All-Sky Solar Radiation	RadAvg	771	945	1302	1643	1807	2068	1976	1817	1546	1182	836	664	
	RadStd	66	123	99	119	143	139	99	116	118	147	90	74	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (24 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A