

MONETT, MO, USA

WMO: 723490

Lat: 36.910N

Lon: 94.015W

Elev: 1434

StdP: 13.95

Time Zone: -6.00 (NAC)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.7	13.6	0.0	5.8	10.6	4.6	7.4	17.1	28.1	53.1	25.5	48.4	6.4	0	0.479

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.3	96.8	75.7	91.4	75.9	90.1	75.3	79.6	92.0	78.2	89.4	76.8	86.8	7.5	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.4	140.6	87.0	74.8	137.3	85.7	73.2	130.0	82.6	44.3	92.8	42.7	89.5	41.2	86.6	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.9	20.3	18.1	1.0	96.4	5.0	1.7	-2.6	97.7	-5.5	98.7	-8.3	99.7	-11.9	100.9		
			-0.6	81.2	5.3	1.2	-4.5	82.1	-7.5	82.8	-10.5	83.5	-14.3	84.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	57.2	34.6	38.1	48.0	56.7	64.8	75.2	78.2	76.6	70.2	57.8	47.1	38.3
	DBStd	17.69	11.58	12.11	10.97	8.66	8.36	5.36	5.47	5.92	7.06	9.39	9.70	10.06
	HDD50	1637	490	365	167	37	6	0	0	0	0	33	160	379
	HDD65	4275	944	754	533	268	110	3	1	1	31	263	540	827
	CDD50	4275	11	31	106	237	466	755	874	825	606	274	73	17
	CDD65	1437	0	1	7	18	104	308	410	361	187	39	2	0
	CDH74	13174	0	6	40	134	728	2783	4207	3504	1517	244	11	0
	CDH80	5318	0	0	2	9	138	1059	1942	1590	543	35	0	0
Wind	WSAvg	7.8	8.8	9.3	9.6	9.7	7.6	6.8	5.8	6.1	6.1	7.4	8.3	8.0
Precipitation	PrecAvg	47.8	2.7	2.4	3.7	4.6	6.4	5.4	4.3	3.0	5.6	3.5	3.4	2.8
	PrecMax	63.4	7.9	5.5	8.6	9.8	13.1	9.9	8.7	6.6	13.7	10.9	8.5	6.8
	PrecMin	36.9	0.4	0.4	0.8	1.4	1.6	2.2	1.4	0.2	0.9	0.7	0.0	0.2
	PrecStd	7.4	1.7	1.5	2.0	2.2	2.7	2.6	1.7	1.5	3.0	2.3	2.6	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	67.7	72.4	78.9	81.4	86.5	93.0	99.9	102.0	93.1	83.6	75.2	67.9
		MCWB	57.1	60.2	63.4	65.9	71.2	78.2	76.3	77.8	73.8	70.8	64.2	59.2
	2%	DB	62.6	66.1	72.9	78.6	82.5	90.8	97.0	96.9	89.8	80.8	70.0	62.9
		MCWB	52.3	57.0	61.2	64.2	70.9	77.1	75.2	76.5	73.7	67.7	59.6	55.0
	5%	DB	56.7	62.7	69.5	73.5	81.3	89.6	92.8	91.3	86.3	76.9	66.0	57.4
		MCWB	48.5	55.5	58.3	62.1	69.8	76.4	76.1	75.2	73.0	65.0	58.6	49.7
	10%	DB	51.7	57.1	64.1	71.8	78.9	86.4	90.2	88.5	82.1	72.4	62.8	54.0
		MCWB	45.2	50.8	55.4	61.6	68.3	74.7	75.7	74.1	71.1	64.2	54.8	48.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.0	62.7	65.6	69.4	75.2	80.0	81.2	81.2	76.8	72.7	65.9	61.1
		MCDB	65.7	69.2	76.7	78.5	82.5	91.4	91.7	98.3	88.2	81.0	72.2	65.4
	2%	WB	53.4	59.6	62.7	66.9	73.3	78.4	79.6	79.5	75.2	70.6	62.8	57.0
		MCDB	58.6	65.1	72.0	74.3	81.0	89.0	92.1	92.6	86.0	76.5	66.8	60.7
	5%	WB	49.6	56.5	59.9	64.6	71.4	77.2	78.3	77.8	74.0	68.4	59.2	52.5
		MCDB	56.4	61.3	66.5	71.7	79.2	86.9	89.8	88.6	84.0	73.5	64.5	55.6
	10%	WB	45.5	51.2	57.2	62.9	69.4	75.5	76.8	75.9	72.6	65.8	55.6	49.0
		MCDB	49.8	57.2	63.6	69.0	75.8	84.2	87.0	85.3	81.2	71.8	61.2	52.6
Mean Daily Temperature Range	5% DB	MDBR	17.8	18.3	19.2	20.3	18.1	18.1	19.3	19.3	19.0	19.3	19.6	16.2
		MCDBR	25.1	24.3	23.7	22.8	20.4	19.9	23.4	23.7	21.1	21.9	23.1	22.6
		MCWBR	16.8	16.8	14.0	13.8	10.9	9.2	8.1	9.0	8.6	11.5	16.1	15.4
	5% WB	MCDBR	22.1	21.5	20.8	20.3	18.7	19.1	20.0	20.8	19.4	17.9	21.1	19.6
		MCWBR	17.0	16.5	14.3	14.1	10.8	9.9	9.0	9.7	8.7	11.1	16.4	16.4
Clear-Sky Solar Irradiance	taub	0.298	0.305	0.337	0.373	0.415	0.415	0.436	0.436	0.379	0.338	0.306	0.288	
	taud	2.467	2.460	2.411	2.324	2.264	2.290	2.284	2.257	2.386	2.479	2.515	2.517	
	Ebn at Noon	285	297	295	288	276	275	268	266	277	280	279	282	
	Edh at Noon	26	30	35	40	43	42	42	42	35	29	25	23	
All-Sky Solar Radiation	RadAvg	765	945	1265	1604	1789	2051	2021	1827	1558	1148	818	648	
	RadStd	69	134	76	96	146	167	125	123	120	140	89	79	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page