

CLINTON SHERMAN, OK, USA

WMO: 723526

Lat: 35.357N

Lon: 99.204W

Elev: 586

StdP: 94.48

Time Zone: -6.00 (NAC)

Period: 96-19

WBAN: 03932

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.9	-7.4	-17.4	0.9	-6.5	-14.5	1.1	-3.4	15.1	6.0	14.1	6.1	5.6	10	0.657

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.7	38.8	21.5	37.5	21.8	36.2	21.8	24.4	32.3	23.7	31.9	23.1	31.6	6.3	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.4	18.4	27.7	21.7	17.6	26.9	21.1	16.9	26.4	76.7	32.1	73.9	32.0	71.6	31.7	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	13.6	12.2	11.2	DB	-13.9	40.7	2.3	1.8	-15.5	42.1	-16.8	43.2	-18.1	44.2	-19.8	45.5
(5)				WB	-14.6	25.7	2.1	1.3	-16.1	26.6	-17.3	27.3	-18.4	28.0	-19.9	28.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.3	4.2	5.8	10.5	15.2	21.1	26.2	28.7	28.0	23.8	16.7	9.9	4.6
	DBStd	10.02	5.54	5.87	5.61	4.87	4.60	3.32	2.94	3.15	3.95	5.06	5.32	5.24
	HDD10.0	658	190	140	62	12	1	0	0	0	0	9	66	179
	HDD18.3	1958	437	352	247	116	26	1	0	0	6	90	257	427
	CDD10.0	2949	11	21	78	169	344	485	579	559	413	217	62	11
	CDD18.3	1207	0	0	4	22	111	236	321	301	169	40	3	0
	CDH23.3	14191	2	11	57	236	1164	2707	4213	3699	1709	362	31	1
	CDH26.7	7450	0	2	11	66	511	1408	2453	2085	798	113	4	0
Wind	WSAvg	5.9	5.8	6.1	6.5	6.5	5.9	6.1	5.4	5.0	5.4	5.9	6.0	5.8
Precipitation	PrecAvg	698	24	27	51	72	105	97	55	78	64	70	39	30
	PrecMax	1146	72	76	140	199	334	228	131	217	176	153	146	71
	PrecMin	467	0	3	0	7	10	11	4	0	3	7	2	5
	PrecStd	177	18	21	41	48	72	57	37	51	39	39	35	21
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.5	25.1	27.8	31.6	37.0	39.4	41.1	41.0	37.9	32.5	27.0	20.9
		MCWB	11.2	12.3	14.5	17.3	20.2	21.1	21.3	21.6	20.8	18.6	16.1	11.2
	2%	DB	18.2	21.1	24.6	28.2	33.9	37.3	38.9	38.7	35.3	29.8	23.3	17.6
		MCWB	9.0	11.9	14.8	17.3	20.1	21.7	21.7	21.6	21.3	18.7	14.5	10.8
	5%	DB	15.8	17.7	22.3	26.2	32.1	35.4	37.6	37.4	33.1	27.4	21.0	15.1
		MCWB	8.0	10.4	14.3	16.4	19.9	21.7	22.0	22.0	20.9	17.6	13.6	9.0
	10%	DB	12.7	15.1	19.7	23.7	29.3	33.5	36.3	35.9	31.4	25.0	17.9	12.6
		MCWB	6.8	9.2	12.6	15.8	19.2	21.6	22.1	21.7	20.4	16.6	12.2	7.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.0	15.9	18.9	20.9	23.5	25.3	25.6	24.8	23.7	22.1	18.7	15.6
		MCDB	18.5	18.7	23.7	26.6	31.1	33.0	33.7	32.7	31.7	27.6	22.5	17.5
	2%	WB	10.8	13.4	17.2	19.7	22.4	24.2	24.4	24.0	22.8	20.8	16.2	12.3
		MCDB	16.0	18.3	21.4	24.8	29.9	31.7	32.8	31.9	30.6	25.6	20.7	15.3
	5%	WB	8.8	11.5	15.6	18.5	21.5	23.4	23.7	23.4	22.1	19.7	15.0	9.8
		MCDB	14.9	17.1	19.8	23.3	28.7	31.3	32.3	31.9	29.2	24.0	18.7	14.5
	10%	WB	7.1	9.4	13.6	17.1	20.6	22.7	23.0	22.8	21.5	18.5	13.4	7.6
		MCDB	12.4	14.9	19.1	21.7	27.4	30.6	32.0	31.5	28.5	23.2	17.6	12.1
Mean Daily Temperature Range	5% DB	MDBR	12.0	12.0	12.6	12.7	12.7	12.4	12.7	12.5	12.1	12.1	11.8	11.0
		MCDBR	16.5	16.6	15.9	15.6	15.4	14.4	14.5	14.5	14.1	14.8	15.1	14.8
		MCWBR	9.5	9.6	8.6	7.9	5.9	4.6	3.6	4.0	4.5	6.6	8.1	8.8
	5% WB	MCDBR	15.0	15.0	12.8	12.8	13.4	12.6	12.4	12.3	11.8	11.1	12.0	13.1
		MCWBR	9.3	9.7	8.0	7.7	6.1	5.2	4.1	4.2	4.4	6.4	7.9	9.0
Clear-Sky Solar Irradiance	taub	0.277	0.288	0.327	0.358	0.376	0.404	0.407	0.399	0.366	0.342	0.305	0.281	
	taud	2.537	2.514	2.419	2.362	2.382	2.342	2.362	2.335	2.404	2.456	2.497	2.525	
	Ebn at Noon	939	964	945	926	908	878	873	875	890	886	893	910	
	Edh at Noon	79	91	109	122	121	126	123	124	110	95	82	75	
All-Sky Solar Radiation	RadAvg	2.97	3.62	4.78	5.88	6.38	7.06	7.02	6.35	5.33	4.02	3.09	2.53	
	RadStd	0.28	0.46	0.32	0.44	0.66	0.59	0.37	0.37	0.34	0.53	0.39	0.24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	-0.76	N/A	N/A	N/A	N/A
(47)	Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page