

MUSKOGEE-DAVIS, OK, USA

WMO: 723556

Lat: 35.657N

Lon: 95.361W

Elev: 610

StdP: 14.37

Time Zone: -6.00 (NAC)

Period: 97-19

WBAN: 93953

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.6	19.2	4.7	7.2	19.7	9.3	9.0	24.0	26.6	47.3	24.7	47.4	8.7	350	0.492

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.2	99.6	75.8	96.6	76.1	93.1	76.1	80.3	90.1	79.1	89.7	78.1	89.0	8.8	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.8	147.8	85.8	76.1	139.4	84.6	75.0	134.2	83.5	44.2	89.7	43.0	89.9	41.9	89.5	88.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.1	20.7	18.8	6.7	102.5	5.5	4.7	2.7	105.8	-0.6	108.6	-3.7	111.2	-7.7	114.7
			6.6	81.8	5.9	2.2	2.3	83.4	-1.2	84.6	-4.5	85.9	-8.9	87.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.2	39.2	43.1	52.5	60.8	68.9	77.1	81.5	81.4	74.1	62.3	51.3	41.2
	DBStd	17.06	10.40	10.91	9.72	8.15	6.85	4.77	4.71	5.05	6.70	8.79	9.43	9.64
	HDD50	1114	359	243	85	13	1	0	0	0	0	11	98	304
	HDD65	3353	799	614	400	172	42	1	0	0	9	158	418	740
	CDD50	5208	26	50	164	336	588	813	977	972	724	391	137	30
	CDD65	1970	0	2	13	46	163	363	512	507	283	74	6	1
	CDH74	20428	2	14	107	394	1334	3584	5870	5697	2708	657	60	1
	CDH80	9454	0	2	15	74	366	1532	3035	3015	1210	199	6	0
Wind	WSAvg	8.8	9.6	10.0	10.6	10.6	9.0	8.0	6.8	6.7	7.2	8.3	9.3	9.1
Precipitation	PrecAvg	43.5	2.3	2.0	3.7	4.6	5.6	4.9	3.4	2.8	4.8	3.5	3.5	2.8
	PrecMax	59.2	6.0	7.1	9.4	8.8	12.1	12.0	12.8	6.4	11.6	10.7	7.9	6.9
	PrecMin	27.2	0.2	0.0	0.8	1.7	1.4	1.3	0.2	0.0	0.6	0.6	0.2	0.3
	PrecStd	7.4	1.5	1.5	2.0	2.0	2.5	2.8	2.7	1.5	2.7	2.4	2.6	1.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.3	75.4	81.4	86.0	90.3	96.9	103.5	105.5	100.2	90.1	80.6	72.3
		MCWB	57.6	60.4	63.4	66.7	74.6	74.4	74.6	75.2	74.8	72.2	64.6	63.1
	2%	DB	66.5	70.8	76.9	81.6	86.9	92.7	99.2	100.1	93.5	85.6	74.8	66.5
		MCWB	55.7	58.7	62.6	66.9	73.3	76.2	75.9	76.0	74.2	70.1	62.0	58.1
	5%	DB	62.5	65.8	72.8	78.8	84.0	90.5	96.0	97.2	90.6	81.3	71.4	62.2
		MCWB	53.3	56.6	59.8	64.5	71.9	75.9	76.5	76.2	74.0	66.7	61.2	53.9
	10%	DB	56.8	61.5	69.1	75.1	81.4	88.4	92.7	93.3	87.6	77.0	66.8	56.8
		MCWB	48.1	52.7	58.3	63.3	70.8	75.5	77.2	75.8	73.0	65.4	57.7	49.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.0	65.2	67.2	72.3	77.6	81.3	82.3	81.1	79.0	75.1	68.5	65.1
		MCDB	67.3	72.3	77.7	80.4	86.1	89.8	91.2	90.9	91.3	84.5	75.3	70.7
	2%	WB	59.0	62.1	64.9	69.5	75.4	79.2	80.8	79.5	77.2	72.9	65.2	60.6
		MCDB	64.3	67.5	74.0	77.7	83.7	88.8	90.1	91.0	89.2	81.4	71.6	65.4
	5%	WB	53.8	58.3	62.6	67.8	73.9	77.8	79.5	78.3	75.8	70.7	62.8	55.5
		MCDB	60.5	64.6	70.2	75.0	81.7	87.3	89.6	90.6	86.4	77.0	68.7	59.5
	10%	WB	48.8	53.3	60.0	65.7	72.2	76.5	78.4	77.3	74.4	68.2	59.7	50.8
		MCDB	56.1	61.1	67.4	72.9	79.4	85.4	88.8	89.9	83.8	74.6	65.8	55.7
Mean Daily Temperature Range	5% DB	MDBR	20.8	20.6	21.4	21.5	19.4	18.9	20.2	21.4	21.8	22.5	21.8	19.6
		MCDBR	29.1	26.8	26.5	25.5	21.6	21.7	24.6	26.5	25.0	25.9	26.2	27.2
		MCWBR	18.4	17.4	15.0	13.7	10.6	8.7	7.1	7.8	8.9	12.2	15.9	17.9
	5% WB	MCDBR	23.8	24.1	22.0	20.0	18.7	18.8	19.6	21.5	21.0	19.9	22.5	21.1
		MCWBR	17.6	17.7	14.0	13.2	10.5	9.3	8.3	8.4	8.4	10.8	16.0	17.2
Clear-Sky Solar Irradiance	taub	0.307	0.314	0.354	0.389	0.425	0.429	0.447	0.448	0.396	0.352	0.322	0.301	
	taud	2.485	2.483	2.401	2.315	2.275	2.292	2.287	2.255	2.364	2.472	2.505	2.515	
	Ebn at Noon	284	295	291	284	274	272	266	263	273	277	276	279	
	Edh at Noon	26	30	35	40	43	42	42	43	36	30	26	24	
All-Sky Solar Radiation	RadAvg	811	976	1302	1620	1787	2042	2071	1882	1575	1181	867	690	
	RadStd	83	142	83	97	163	214	126	121	128	160	105	89	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Regional (36 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page