

GOODWELL 2 E, OK, USA

WMO: 723580

Lat: 36.5993N

Lon: 101.5950W

Elev: 996

StdP: 89.92

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 03055

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-13.9	-11.2	-19.2	0.8	-7.7	-17.0	0.9	-2.3	11.5	2.9	10.2	3.9	3.0	N/A	0.542

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.2	37.9	18.7	36.5	18.9	35.1	18.7	21.7	30.9	21.0	30.4	20.5	29.9	5.3	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.3	15.9	23.8	18.7	15.3	23.4	18.0	14.6	23.2	68.2	30.9	65.8	30.0	63.8	29.9	24.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.1	9.0	7.9	-19.2	40.4	2.8	1.3	-21.2	41.3	-22.8	42.1	-24.4	42.8	-26.4	43.7		
(5)			-19.8	22.5	3.1	0.9	-22.0	23.2	-23.8	23.7	-25.5	24.3	-27.7	24.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.8	2.0	2.9	8.7	12.7	18.1	24.3	26.2	25.0	21.4	14.1	7.7	1.8		
	DBStd	10.07	5.74	6.14	5.54	5.08	4.87	3.40	2.89	2.99	3.93	5.16	5.34	5.71		
	HDD10.0	967	253	209	89	29	4	0	0	0	0	21	103	258		
	HDD18.3	2484	507	433	301	179	64	2	1	1	17	149	319	513		
	CDD10.0	2347	4	9	48	109	254	429	503	464	343	147	34	3		
	CDD18.3	824	0	0	1	8	56	181	245	207	110	17	0	0		
	CDH23.3	10684	2	12	91	273	896	2311	3109	2356	1276	321	39	0		
	CDH26.7	5565	0	2	19	89	398	1261	1801	1273	603	113	4	0		
(14) Wind	WSAvg	3.7	3.4	3.7	4.0	4.5	4.1	4.2	3.6	3.2	3.6	3.5	3.5	3.3		
(15) Precipitation	PrecAvg	425	7	10	24	31	70	68	66	57	40	29	16	8		
	PrecMax	650	24	40	123	123	159	222	181	138	185	148	83	48		
	PrecMin	293	0	0	0	0	0	0	3	0	0	0	0	0		
	PrecStd	81	7	11	27	29	42	42	42	37	38	33	21	9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.1	25.0	29.1	32.3	35.8	39.9	39.7	38.4	36.3	32.8	27.1	21.3		
		MCWB	8.8	9.3	11.9	12.8	14.2	17.0	19.3	19.0	18.2	14.6	11.2	8.4		
	2%	DB	19.0	20.8	26.1	29.2	33.5	37.4	38.0	36.8	34.6	29.9	24.0	17.4		
		MCWB	7.5	8.3	11.3	12.3	14.9	17.7	19.2	19.3	17.6	14.7	10.7	7.3		
	5%	DB	15.2	17.8	22.7	26.8	31.1	35.4	36.7	35.3	32.6	27.2	20.7	14.5		
		MCWB	6.0	7.0	10.0	12.3	15.0	18.5	19.4	19.4	17.7	14.2	9.6	6.0		
	10%	DB	11.9	13.9	19.7	23.6	28.7	33.6	35.1	33.5	30.5	24.1	17.4	11.5		
		MCWB	4.5	5.4	9.3	12.0	15.4	18.6	19.4	19.3	17.7	13.1	8.4	4.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	10.5	14.9	16.7	20.1	21.8	22.5	22.6	20.9	19.0	13.6	10.2		
		MCDB	20.5	21.3	22.9	23.2	27.0	32.0	32.2	30.5	29.8	24.7	19.5	15.9		
	2%	WB	7.7	8.9	13.2	15.1	18.8	21.1	21.6	21.8	20.1	17.4	11.8	7.9		
		MCDB	17.4	21.1	21.8	22.1	25.9	30.8	31.4	30.2	28.9	23.2	20.2	16.0		
	5%	WB	6.1	7.5	11.4	13.9	17.8	20.5	20.9	21.1	19.4	15.8	10.4	6.2		
		MCDB	14.0	17.8	20.5	21.5	25.4	30.0	30.6	30.0	28.1	23.4	19.6	12.6		
	10%	WB	4.6	5.4	9.8	12.7	16.6	19.9	20.5	20.4	18.8	14.3	8.9	4.9		
		MCDB	11.2	13.3	19.8	20.8	24.6	29.4	30.3	29.5	27.3	21.9	17.1	10.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	15.4	15.6	16.5	16.0	15.7	15.7	15.2	14.4	15.0	15.6	16.0	14.3		
		MCDBR	20.6	22.1	21.0	21.3	19.4	18.5	17.6	17.3	17.9	19.8	20.5	18.8		
		MCWBR	11.3	11.7	10.0	9.3	7.4	5.5	4.4	4.4	5.5	8.0	9.7	10.6		
		MCDBR	19.2	21.5	19.2	16.0	15.9	15.4	15.2	14.9	14.3	15.9	17.8	17.3		
	5% WB	MCWBR	10.8	11.4	9.8	8.2	6.9	5.3	4.4	4.7	4.9	7.3	9.2	10.3		
(40) Clear-Sky Solar Irradiance	taub		0.255	0.263	0.291	0.320	0.338	0.372	0.376	0.362	0.336	0.299	0.270	0.255		
	taud		2.581	2.571	2.497	2.432	2.441	2.386	2.416	2.424	2.480	2.555	2.563	2.585		
	Ebn at Noon		963	990	982	962	942	906	900	908	919	933	933	941		
	Edh at Noon		73	84	99	113	114	120	116	112	101	85	74	69		
(44) All-Sky Solar Radiation	RadAvg		2.89	3.71	4.97	6.20	7.07	7.57	7.37	6.49	5.53	4.14	3.15	2.54		
	RadStd		0.26	0.35	0.41	0.34	0.42	0.37	0.32	0.33	0.26	0.44	0.28	0.18		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (18 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+75	N/A

Nomenclature: See separate page