

GALLUP, NM, USA

WMO: 723627

Lat: 35.514N

Lon: 108.794W

Elev: 1972

StdP: 79.77

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 23081

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(1) 12	-16.6	-14.1	-22.5	0.6	-5.4	-20.3	0.8	-4.4	12.5	5.2	11.1	5.0	0.6	60	0.600 (1)

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(2) 7	17.8	33.4	14.1	32.2	13.8	30.9	13.5	16.9	25.5	16.4	25.3	15.8	24.8	4.8	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(3) 14.9	13.5	18.3	14.1	12.8	17.9	13.3	12.1	18.1	54.9	25.4	53.2	25.0	51.5	24.9	26.7 (3)

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.0	10.5	8.7	DB	-21.3	35.7	3.0	1.2	-23.4	36.6	-25.1	37.3	-26.8	38.0	-28.9	38.9	(4)
(5)			WB	-21.7	18.6	2.9	1.8	-23.8	19.9	-25.4	21.0	-27.0	22.0	-29.1	23.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.8	-1.0	1.3	4.9	8.3	13.2	18.9	22.0	20.7	16.7	9.8	3.5	-1.1	(6)
(7)		DBStd	8.81	4.14	3.95	3.59	3.68	3.58	3.02	1.89	1.90	2.98	3.77	4.01	4.19	(7)
(8)		HDD10.0	1423	340	244	160	73	14	0	0	0	1	49	196	346	(8)
(9)		HDD18.3	3364	598	477	416	301	163	28	1	3	63	266	444	604	(9)
(10)		CDD10.0	1353	0	0	2	23	112	268	371	332	202	42	1	0	(10)
(11)		CDD18.3	253	0	0	0	0	2	46	114	77	14	0	0	0	(11)
(12)		CDH23.3	5070	0	0	1	19	307	1432	1634	1136	497	44	0	0	(12)
(13)		CDH26.7	1987	0	0	0	1	65	616	751	433	118	3	0	0	(13)
(14)	Wind	WSAvg	3.1	2.4	3.0	3.5	4.3	4.0	3.7	2.9	2.6	2.7	2.6	2.4	(14)	
(15)	Precipitation	PrecAvg	291	22	17	23	12	14	10	43	53	27	27	24	18	(15)
(16)		PrecMax	402	66	56	52	51	56	45	91	155	73	94	68	57	(16)
(17)		PrecMin	138	0	2	0	0	0	0	1	17	1	0	0	1	(17)
(18)		PrecStd	60	19	12	16	11	15	12	25	31	18	22	18	17	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.2	18.2	22.7	25.7	31.1	34.9	35.2	33.9	31.4	26.8	21.2	15.3	(19)
(20)			MCWB	5.1	6.3	7.8	9.3	12.4	14.0	14.6	15.0	14.2	11.2	8.1	5.3	(20)
(21)		2%	DB	12.5	16.1	20.4	23.4	28.3	33.2	33.7	32.2	29.4	24.5	18.9	12.7	(21)
(22)			MCWB	3.9	5.3	6.9	8.3	10.9	13.2	14.5	14.5	13.2	10.2	6.8	4.0	(22)
(23)		5%	DB	10.3	13.6	18.4	21.8	26.6	31.8	32.4	30.8	28.0	22.7	16.9	10.4	(23)
(24)			MCWB	3.0	4.2	6.1	7.6	9.9	12.6	14.3	14.3	12.9	9.4	6.1	3.0	(24)
(25)		10%	DB	8.0	10.8	16.2	20.0	24.9	30.4	31.0	29.3	26.5	20.8	14.1	7.9	(25)
(26)			MCWB	2.1	3.0	5.2	6.9	9.4	12.0	14.2	14.4	12.4	8.7	5.0	2.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.7	7.3	8.8	10.2	13.1	15.8	17.8	17.8	16.3	13.6	9.1	6.7	(27)
(28)			MCDB	12.2	15.4	20.4	22.6	28.3	27.9	25.2	25.9	25.4	20.2	17.9	12.1	(28)
(29)		2%	WB	5.0	5.9	7.5	9.1	11.8	14.9	16.9	17.0	15.4	11.8	7.8	5.1	(29)
(30)			MCDB	10.6	14.0	18.9	21.7	25.2	27.8	25.5	25.5	24.3	20.1	16.3	10.3	(30)
(31)		5%	WB	3.6	4.8	6.5	8.1	10.8	14.0	16.5	16.5	14.7	10.7	6.7	3.8	(31)
(32)			MCDB	9.0	12.5	16.8	20.4	23.6	27.4	25.6	25.1	23.3	19.2	15.2	9.3	(32)
(33)		10%	WB	2.3	3.6	5.5	7.2	10.1	13.1	15.9	16.0	14.0	9.6	5.6	2.4	(33)
(34)			MCDB	7.3	9.9	14.9	19.0	22.8	27.5	25.2	24.4	22.3	19.0	13.3	7.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	16.5	16.5	19.0	19.3	20.0	21.5	17.8	17.1	18.4	19.4	18.9	16.5	(35)
(36)			MCDBR	20.9	22.6	24.3	23.6	23.6	23.1	20.7	20.1	20.9	23.4	23.9	20.7	(36)
(37)			MCWBR	13.3	13.1	12.9	12.0	10.9	10.0	7.5	7.0	8.7	11.8	13.9	13.1	(37)
(38)		5% WB	MCDBR	17.6	19.8	21.6	21.7	21.4	20.6	15.8	15.6	16.1	18.3	20.7	18.0	(38)
(39)			MCWBR	11.5	11.8	11.7	11.1	9.9	8.9	5.2	5.3	6.6	9.3	12.3	11.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.235	0.243	0.264	0.282	0.293	0.305	0.349	0.339	0.299	0.278	0.246	0.239	(40)	
(41)		taud	2.651	2.634	2.564	2.500	2.514	2.464	2.433	2.425	2.541	2.566	2.622	2.638	(41)	
(42)		Ebn at Noon	1000	1023	1016	1003	989	971	926	932	962	962	976	975	(42)	
(43)		Edh at Noon	69	79	94	105	106	111	114	113	95	84	71	66	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.15	4.09	5.56	6.86	7.70	8.21	6.95	6.38	5.74	4.65	3.53	2.77	(44)	
(45)		RadStd	0.28	0.34	0.35	0.36	0.55	0.39	0.37	0.25	0.21	0.36	0.22	0.19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.46	N/A	N/A	N/A	N/A	N/A	-82	-128	+77	+42
(47) Regional (8 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page