

CURTIS FIELD, TX, USA

WMO: 723628

Lat: 31.178N

Lon: 99.324W

Elev: 1827

StdP: 13.75

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 93942

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.4	26.6	7.4	8.6	34.4	10.4	10.0	39.6	26.9	53.2	24.3	53.6	7.4	340	0.471

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.9	100.2	71.1	99.2	71.2	97.1	71.0	75.9	88.4	75.0	87.3	74.2	86.6	8.8	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.0	131.3	77.8	72.4	128.4	77.5	72.0	126.6	77.3	40.6	88.6	39.8	86.7	39.0	85.1	79.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
22.6	19.5	17.6	16.1	102.7	3.4	3.4	13.7	105.2	11.7	107.2	9.8	109.1	7.3	111.6	
			DB												
			WB	14.4	77.7	3.3	1.0	12.0	78.4	10.0	79.0	8.2	79.5	5.8	80.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.5	47.4	50.7	59.6	66.8	73.6	81.1	82.9	84.1	77.1	67.4	56.6	49.1
	DBStd	15.35	10.37	11.54	9.99	8.60	6.95	4.11	4.06	4.00	5.69	8.83	9.80	9.68
	HDD50	530	174	121	34	5	0	0	0	0	6	49	141	
	HDD65	2131	550	410	218	79	15	0	0	2	81	278	498	
	CDD50	6541	95	140	333	511	732	934	1021	1058	813	544	248	112
	CDD65	2666	5	9	52	134	282	484	556	593	365	155	26	5
	CDH74	30829	88	160	530	1429	2875	5684	6883	7721	3656	1465	249	89
	CDH80	15651	16	44	163	569	1294	2970	3826	4445	1734	528	44	18
Wind	WSAvg	8.6	8.7	9.4	9.9	10.3	9.5	9.1	7.7	7.0	6.8	7.9	8.3	8.3
Precipitation	PrecAvg	25.8	1.5	1.7	2.0	2.6	3.3	2.8	2.0	1.9	3.3	2.2	1.7	1.2
	PrecMax	35.7	3.5	5.5	4.4	5.9	6.9	8.0	5.8	4.7	7.8	7.3	9.3	7.5
	PrecMin	16.3	0.2	0.0	0.1	0.6	0.9	0.0	0.0	0.7	0.0	0.0	0.0	0.0
	PrecStd	5.0	0.9	1.5	1.2	1.3	1.3	2.2	1.9	1.6	1.9	1.7	2.1	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.9	84.5	90.0	97.2	99.1	102.0	102.0	103.9	100.0	92.8	84.2	81.9
		MCWB	57.1	58.4	62.3	63.4	69.4	70.6	70.1	71.6	69.1	67.4	64.2	57.6
	2%	DB	75.3	79.0	84.1	91.0	93.5	99.0	99.6	100.4	95.4	89.6	81.0	75.2
		MCWB	55.6	57.2	60.7	65.3	70.5	71.5	71.1	71.8	70.0	68.2	62.6	56.6
	5%	DB	70.3	73.4	80.8	86.4	90.5	96.6	98.7	99.3	91.4	85.9	76.6	70.4
		MCWB	54.2	55.9	60.8	65.0	69.6	71.1	71.3	71.8	69.6	67.2	60.9	56.2
	10%	DB	64.2	69.7	75.0	81.8	87.8	92.8	95.3	97.1	90.0	82.1	72.5	65.5
		MCWB	51.2	54.3	59.1	63.8	69.3	71.3	70.7	71.7	69.5	65.1	59.5	55.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.6	65.2	68.0	71.7	75.9	77.5	76.8	76.4	75.9	74.3	70.1	66.1
		MCDB	69.2	75.2	78.6	83.1	90.1	90.9	89.5	89.2	86.9	81.3	73.3	71.8
	2%	WB	59.7	63.1	66.2	70.2	74.0	75.5	75.4	75.3	74.5	72.1	66.8	62.9
		MCDB	68.9	68.2	75.5	80.7	85.6	87.9	87.1	89.1	84.8	80.0	74.1	67.9
	5%	WB	56.8	60.7	64.5	68.7	72.8	74.5	74.5	74.4	73.4	70.7	64.6	59.4
		MCDB	65.8	69.2	72.3	78.6	83.4	86.6	86.6	88.6	83.0	78.8	71.8	65.7
	10%	WB	53.3	57.5	63.2	67.3	71.5	73.4	73.6	73.6	72.5	69.2	62.7	56.1
		MCDB	64.0	66.8	70.3	76.9	81.2	85.3	86.0	88.2	81.9	77.2	70.0	64.5
Mean Daily Temperature Range	5% DB	MDBR	23.8	24.3	24.2	24.5	22.0	21.9	22.1	22.9	21.1	23.8	24.3	23.9
		MCDBR	30.5	30.6	29.4	30.1	26.9	26.4	25.6	25.7	24.4	26.3	27.0	29.9
		MCWBR	16.5	16.6	13.1	13.2	9.5	7.3	6.8	6.9	7.9	10.7	13.9	16.3
	5% WB	MCDBR	26.1	25.1	21.8	22.2	21.5	21.1	21.4	22.5	19.3	20.6	22.9	23.8
		MCWBR	16.7	16.6	11.0	11.8	9.2	7.6	6.5	6.6	6.8	10.4	14.9	15.7
Clear-Sky Solar Irradiance	taub	0.298	0.304	0.328	0.369	0.403	0.403	0.415	0.407	0.380	0.346	0.316	0.299	
	taud	2.535	2.527	2.471	2.377	2.336	2.379	2.393	2.400	2.418	2.504	2.519	2.538	
	Ebn at Noon	297	305	303	293	281	280	276	278	282	286	288	291	
	Edh at Noon	27	30	34	39	41	39	38	37	35	30	27	26	
All-Sky Solar Radiation	RadAvg	1013	1226	1557	1872	1948	2196	2167	2009	1676	1360	1061	908	
	RadStd	107	169	134	157	196	168	171	130	142	200	136	117	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (33 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+122

Nomenclature: See separate page