

ALBUQUERQUE INTL, NM, USA

WMO: 723650

Lat: 35.038N

Lon: 106.622W

Elev: 1619

StdP: 83.33

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 23050

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) -7.2	(c) -5.3	(d) -20.5	(e) 0.7	(f) 6.3	(g) -18.3	(h) 0.9	(i) 6.4	(j) 14.2	(k) 3.4	(l) 11.9	(m) 4.2	(n) 2.9	(o) 10	(p) 0.515

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.7	35.3	15.4	34.1	15.3	32.9	15.2	18.5	27.4	18.0	26.9	17.6	26.6	4.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.4	14.2	20.1	15.6	13.5	20.6	14.8	12.8	21.1	58.8	26.9	57.1	26.9	55.6	26.4	20.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.7	11.1	9.3	-11.3	37.7	2.7	1.3	-13.3	38.6	-14.9	39.3	-16.4	40.0	-18.4	40.9		
			-12.5	19.6	2.4	0.5	-14.3	20.0	-15.7	20.3	-17.1	20.6	-18.9	21.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.7	3.4	5.8	10.0	13.9	19.1	24.9	26.2	25.0	21.5	14.8	8.1	3.1	(6)
(7)		DBStd	8.94	3.54	3.89	3.92	3.95	3.77	2.69	2.13	2.06	2.96	3.90	3.92	3.72	(7)
(8)		HDD10.0	696	207	122	49	13	1	0	0	0	9	81	214		(8)
(9)		HDD18.3	2152	464	349	258	138	36	1	0	9	118	307	471		(9)
(10)		CDD10.0	2411	1	6	50	129	283	446	503	466	345	157	24	1	(10)
(11)		CDD18.3	827	0	0	0	4	60	197	245	208	104	9	0	0	(11)
(12)		CDH23.3	8738	0	0	11	102	766	2366	2548	1944	897	104	0	0	(12)
(13)		CDH26.7	3842	0	0	0	9	249	1179	1254	854	287	9	0	0	(13)
(14)	Wind	WSAvg	3.6	3.2	3.6	4.0	4.5	4.3	4.1	3.6	3.3	3.4	3.1	3.0		(14)
(15)	Precipitation	PrecAvg	226	10	11	13	13	12	15	38	38	28	24	12	13	(15)
(16)		PrecMax	333	35	45	59	76	63	79	90	95	101	78	49	38	(16)
(17)		PrecMin	123	0	0	0	0	0	0	2	0	2	0	0	0	(17)
(18)		PrecStd	57	9	9	13	15	15	16	23	24	19	21	11	11	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.0	20.2	24.9	28.0	33.3	37.4	36.9	35.4	32.9	27.8	21.4	16.2	(19)
(20)			MCWB	6.1	7.5	9.1	10.6	13.9	15.3	16.3	16.1	15.2	12.6	8.8	6.3	(20)
(21)		2%	DB	13.7	18.0	22.5	26.0	31.1	35.4	35.4	34.0	31.2	26.0	19.5	13.7	(21)
(22)			MCWB	4.8	6.5	8.2	9.9	12.5	14.6	15.9	16.1	14.8	12.0	8.0	5.3	(22)
(23)		5%	DB	11.9	15.8	20.5	24.3	29.5	34.0	34.1	32.7	29.9	24.3	17.5	11.7	(23)
(24)			MCWB	3.9	5.6	7.4	9.3	11.8	14.1	16.0	16.2	14.5	11.4	7.3	4.4	(24)
(25)		10%	DB	10.0	13.5	18.5	22.6	27.7	32.7	32.8	31.3	28.3	22.4	15.3	9.7	(25)
(26)			MCWB	3.0	4.6	6.4	8.5	11.3	13.9	16.1	16.2	14.2	10.7	6.3	3.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.3	8.6	10.3	12.3	15.4	17.9	19.1	19.1	17.9	16.1	10.6	7.9	(27)
(28)			MCD B	13.8	17.6	20.8	23.7	28.8	27.2	28.1	27.1	25.2	21.1	16.6	12.7	(28)
(29)		2%	WB	5.7	7.2	9.0	11.0	14.1	16.9	18.5	18.5	17.0	14.2	9.2	6.3	(29)
(30)			MCD B	11.6	15.5	19.8	22.6	26.6	28.3	27.7	27.4	24.6	22.0	16.3	12.2	(30)
(31)		5%	WB	4.6	6.2	8.0	10.1	13.1	16.2	18.0	18.0	16.4	13.0	8.2	5.0	(31)
(32)			MCD B	10.5	14.3	18.5	21.7	24.6	28.1	27.3	26.7	24.2	20.4	15.6	10.6	(32)
(33)		10%	WB	3.5	5.1	7.0	9.1	12.3	15.5	17.7	17.6	15.8	11.9	7.1	3.7	(33)
(34)			MCD B	9.3	12.5	17.3	20.8	24.0	27.9	27.1	26.2	24.2	19.4	14.6	9.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.6	12.6	13.8	14.0	14.2	14.6	12.7	12.3	12.4	12.5	11.9	10.8	(35)
(36)			MCD BR	14.1	16.0	16.4	16.0	15.9	15.9	14.2	13.8	13.9	14.5	14.3	13.2	(36)
(37)			MCWBR	7.7	8.0	7.4	7.0	6.6	5.9	4.1	3.8	4.7	6.1	6.8	7.3	(37)
(38)		5% WB	MCD BR	12.4	14.4	15.1	14.9	14.3	13.6	12.1	11.8	11.3	11.7	12.5	11.9	(38)
(39)			MCWBR	7.1	7.5	7.0	6.6	5.7	4.8	3.3	3.3	3.9	5.3	6.5	7.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.242	0.250	0.275	0.291	0.310	0.332	0.368	0.350	0.311	0.283	0.257	0.245	(40)	
(41)		taud	2.622	2.606	2.526	2.471	2.462	2.391	2.396	2.400	2.519	2.561	2.584	2.614	(41)	
(42)		Ebn at Noon	993	1015	1005	994	971	945	908	922	951	959	962	968	(42)	
(43)		Edh at Noon	72	82	98	109	112	120	119	116	97	85	74	68	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.25	4.21	5.60	6.86	7.71	8.02	7.14	6.58	5.81	4.68	3.57	2.86	(44)	
(45)		RadStd	0.27	0.35	0.35	0.32	0.39	0.38	0.34	0.24	0.24	0.37	0.21	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+64	N/A

Nomenclature: See separate page