

LOS ALAMOS, NM, USA

WMO: 723654

Lat: 35.879N

Lon: 106.269W

Elev: 7171

StdP: 11.27

Time Zone: -7.00 (NAM)

Period: 95-19

WBAN: 93091

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.5	17.8	-13.0	3.5	43.8	-7.1	4.9	38.5	26.4	37.4	21.6	36.1	4.7	180	0.505

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	21.2	87.6	55.5	84.7	55.1	82.3	55.0	63.2	75.7	61.7	73.5	60.4	72.5	9.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.3	99.0	66.5	57.6	92.9	66.0	56.1	87.9	65.7	32.7	76.3	31.5	72.0	30.3	72.5	68.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.3	19.0	16.7	7.6	91.7	5.2	1.8	3.9	92.9	0.8	94.0	-2.1	95.0	-5.9	96.3		
			6.1	63.5	4.5	2.4	2.9	65.2	0.2	66.6	-2.3	68.0	-5.6	69.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.7	32.6	37.4	45.3	51.2	58.8	71.0	71.7	69.8	64.7	53.2	42.7	33.4	
	DBStd	15.55	6.87	8.33	7.74	7.52	7.74	5.21	4.22	4.07	5.76	7.58	7.78	7.47	
	HDD50	1989	541	356	185	77	20	0	0	0	1	55	238	516	
	HDD65	5131	1006	774	611	413	213	13	4	9	72	367	668	981	
	CDD50	2982	0	2	40	114	294	630	671	612	443	156	20	0	
	CDD65	647	0	0	0	1	22	193	210	156	63	2	0	0	
	CDH74	4684	0	0	0	2	167	1674	1502	961	371	7	0	0	
	CDH80	1155	0	0	0	0	10	495	406	199	45	0	0	0	
Wind	WSAvg	6.2	4.3	5.7	7.3	8.2	8.2	7.9	6.1	5.7	6.2	5.7	4.9	4.4	
Precipitation	PrecAvg	15.9	0.9	0.8	0.9	0.9	1.0	1.0	2.4	2.9	1.7	1.5	0.8	1.1	
	PrecMax	22.2	2.8	1.9	1.8	3.0	3.1	2.8	4.2	5.5	3.2	3.7	2.6	3.7	
	PrecMin	9.8	0.0	0.1	0.0	0.0	0.0	0.2	0.5	1.2	0.4	0.1	0.0	0.1	
	PrecStd	2.9	0.7	0.6	0.5	0.8	0.8	0.7	1.0	1.1	0.8	1.1	0.7	0.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.0	60.3	69.4	73.0	81.4	90.7	90.1	88.2	83.8	74.8	64.3	54.1	
		MCWB	36.7	40.4	43.5	46.1	50.7	54.7	58.3	58.9	54.2	50.1	43.8	38.6	
	2%	DB	48.3	56.3	64.5	70.3	78.6	88.0	86.5	84.3	81.3	71.5	61.1	50.3	
		MCWB	34.8	38.9	41.7	45.0	48.5	53.8	56.4	57.3	54.0	49.4	42.2	36.7	
	5%	DB	45.7	53.6	62.1	67.6	75.4	85.6	84.3	81.9	78.7	68.2	58.1	47.8	
		MCWB	33.3	37.6	40.5	44.1	47.9	53.2	56.3	57.1	53.9	47.4	41.0	35.6	
	10%	DB	43.2	50.0	58.6	64.1	72.6	82.4	81.9	79.5	75.4	65.1	54.7	45.2	
		MCWB	32.5	36.0	39.3	42.6	47.0	52.5	57.1	57.0	53.3	46.4	39.3	34.1	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.7	42.4	45.7	50.9	56.2	60.4	64.5	65.5	62.1	57.2	46.4	43.3
			MCDB	45.2	56.4	60.3	62.1	67.1	78.4	78.1	77.1	71.5	64.6	57.8	48.4
2%		WB	37.9	40.3	43.6	47.6	53.6	58.6	63.0	63.7	60.0	54.1	44.3	39.2	
		MCDB	44.4	53.3	58.9	63.4	68.4	76.0	76.1	75.8	69.2	62.9	56.5	46.6	
5%		WB	35.4	38.6	42.1	46.0	51.6	57.2	61.7	62.2	58.2	51.3	42.5	37.0	
		MCDB	42.9	50.7	57.8	63.0	67.2	74.9	74.0	73.7	68.2	60.9	54.7	44.6	
10%		WB	33.5	36.8	40.5	44.2	49.9	55.9	60.5	60.7	56.7	49.1	40.9	35.0	
		MCDB	41.8	48.2	56.2	61.0	65.0	73.5	73.4	72.1	67.8	61.3	53.0	42.8	
Mean Daily Temperature Range	5% DB	MDBR	15.1	16.3	18.7	19.9	19.6	21.2	19.7	19.0	18.5	17.8	16.6	13.9	
		MCDBR	17.1	19.5	21.3	21.8	21.7	23.2	21.7	21.4	20.3	19.2	18.2	16.3	
		MCWBR	9.8	10.3	9.7	9.5	8.7	8.8	6.8	7.7	7.5	9.2	9.6	8.9	
	5% WB	MCDBR	15.3	18.0	19.8	21.1	19.9	21.6	19.0	18.0	16.9	16.1	16.6	13.8	
		MCWBR	9.8	10.3	9.7	9.7	8.8	8.3	7.1	7.5	7.5	9.1	9.5	8.7	
Clear-Sky Solar Irradiance	taub	0.226	0.229	0.249	0.267	0.287	0.295	0.334	0.323	0.294	0.254	0.238	0.230		
	taud	2.693	2.718	2.648	2.593	2.569	2.538	2.510	2.495	2.586	2.703	2.671	2.674		
	Ebn at Noon	321	331	328	324	315	311	298	301	307	316	313	313		
	Edh at Noon	21	23	27	30	32	33	34	33	29	23	21	20		
All-Sky Solar Radiation	RadAvg	995	1288	1716	2099	2363	2494	2175	2014	1796	1442	1089	868		
	RadStd	76	104	122	107	140	128	110	89	85	111	70	53		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+40

Nomenclature: See separate page