

LOS ALAMOS, NM, USA

WMO: 723654

Lat: 35.879N

Lon: 106.269W

Elev: 2186

StdP: 77.68

Time Zone: -7.00 (NAM)

Period: 95-19

WBAN: 93091

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.3	-7.9	-25.0	0.5	6.6	-21.7	0.7	3.6	11.8	3.0	9.7	2.3	2.1	180	0.505

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	11.8	30.9	13.1	29.3	12.8	28.0	12.8	17.3	24.3	16.5	23.0	15.8	22.5	4.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.2	14.1	19.2	14.2	13.3	18.9	13.4	12.6	18.7	58.3	24.6	55.3	22.2	52.7	22.5	20.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.4	8.5	7.5	-13.5	33.1	2.9	1.0	-15.6	33.9	-17.3	34.4	-19.0	35.0	-21.1	35.7		
(5)			-14.4	17.5	2.5	1.3	-16.2	18.5	-17.6	19.2	-19.1	20.0	-20.9	21.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.5	0.3	3.0	7.4	10.7	14.9	21.7	22.0	21.0	18.2	11.8	6.0	0.8
	DBStd	8.64	3.82	4.63	4.30	4.18	4.30	2.89	2.34	2.26	3.20	4.21	4.32	4.15
	HDD10.0	1105	301	198	103	43	11	0	0	0	1	31	132	287
	HDD18.3	2851	559	430	339	229	118	7	2	5	40	204	371	545
	CDD10.0	1657	0	1	22	63	163	350	373	340	246	87	11	0
	CDD18.3	359	0	0	0	1	12	107	117	87	35	1	0	0
	CDH23.3	2602	0	0	0	1	93	930	834	534	206	4	0	0
	CDH26.7	642	0	0	0	0	6	275	226	111	25	0	0	0
Wind	WSAvg	2.8	1.9	2.5	3.3	3.7	3.6	3.6	2.7	2.6	2.8	2.6	2.2	2.0
Precipitation	PrecAvg	404	23	20	23	22	25	26	60	73	42	37	21	28
	PrecMax	564	71	49	46	76	78	70	107	139	82	94	66	95
	PrecMin	249	1	2	1	0	0	6	12	31	9	2	0	3
	PrecStd	74	19	15	13	20	21	17	25	28	20	27	17	23
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.1	15.7	20.8	22.8	27.4	32.6	32.3	31.2	28.8	23.8	17.9	12.3
		MCWB	2.6	4.7	6.4	7.8	10.4	12.6	14.6	14.9	12.3	10.0	6.6	3.6
	2%	DB	9.0	13.5	18.0	21.3	25.9	31.1	30.3	29.1	27.4	21.9	16.2	10.2
		MCWB	1.5	3.9	5.4	7.2	9.2	12.1	13.6	14.1	12.2	9.7	5.7	2.6
	5%	DB	7.6	12.0	16.7	19.8	24.1	29.8	29.0	27.7	26.0	20.1	14.5	8.8
		MCWB	0.7	3.1	4.7	6.7	8.8	11.8	13.5	13.9	12.2	8.6	5.0	2.0
	10%	DB	6.2	10.0	14.8	17.9	22.5	28.0	27.7	26.4	24.1	18.4	12.6	7.3
		MCWB	0.3	2.2	4.0	5.9	8.3	11.4	14.0	13.9	11.8	8.0	4.1	1.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.9	5.8	7.6	10.5	13.4	15.8	18.1	18.6	16.7	14.0	8.0	6.3
		MCDB	7.4	13.5	15.7	16.7	19.5	25.8	25.6	25.1	21.9	18.1	14.3	9.1
	2%	WB	3.3	4.6	6.5	8.7	12.0	14.8	17.2	17.6	15.6	12.3	6.8	4.0
		MCDB	6.9	11.9	14.9	17.4	20.2	24.4	24.5	24.3	20.7	17.2	13.6	8.1
	5%	WB	1.9	3.6	5.6	7.8	10.9	14.0	16.5	16.8	14.6	10.7	5.8	2.8
		MCDB	6.0	10.4	14.3	17.2	19.5	23.8	23.3	23.2	20.1	16.0	12.6	7.0
	10%	WB	0.8	2.6	4.7	6.8	9.9	13.3	15.8	15.9	13.7	9.5	5.0	1.7
		MCDB	5.5	9.0	13.4	16.1	18.3	23.1	23.0	22.3	19.9	16.3	11.7	6.0
Mean Daily Temperature Range	5% DB	MDBR	8.4	9.1	10.4	11.1	10.9	11.8	10.9	10.5	10.3	9.9	9.2	7.7
		MCDBR	9.5	10.8	11.9	12.1	12.0	12.9	12.1	11.9	11.3	10.7	10.1	9.0
		MCWBR	5.4	5.7	5.4	5.3	4.8	4.9	3.8	4.3	4.2	5.1	5.3	4.9
	5% WB	MCDBR	8.5	10.0	11.0	11.7	11.0	12.0	10.5	10.0	9.4	8.9	9.2	7.7
		MCWBR	5.4	5.7	5.4	5.4	4.9	4.6	4.0	4.1	4.2	5.1	5.3	4.8
Clear-Sky Solar Irradiance	taub	0.226	0.229	0.249	0.267	0.287	0.295	0.334	0.323	0.294	0.254	0.238	0.230	
	taud	2.693	2.718	2.648	2.593	2.569	2.538	2.510	2.495	2.586	2.703	2.671	2.674	
	Ebn at Noon	1013	1042	1035	1020	994	980	940	948	968	995	986	987	
	Edh at Noon	66	73	86	96	100	103	106	105	91	73	67	63	
All-Sky Solar Radiation	RadAvg	3.14	4.06	5.41	6.62	7.45	7.86	6.86	6.35	5.66	4.55	3.43	2.74	
	RadStd	0.24	0.33	0.38	0.34	0.44	0.40	0.35	0.28	0.27	0.35	0.22	0.17	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+22

Nomenclature: See separate page