

SANTA FE, NM, USA

WMO: 723656

Lat: 35.617N

Lon: 106.089W

Elev: 6344

StdP: 11.63

Time Zone: -7.00 (NAM)

Period: 97-19

WBAN: 23049

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	10.2	14.7	-5.7	5.1	35.4	-2.0	6.2	34.1	26.2	38.4	23.7	35.2	9.1	10	0.600

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.0	92.5	57.9	90.3	57.8	88.1	57.6	63.3	79.3	62.3	78.5	61.4	77.8	11.8	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.4	96.2	65.8	58.0	91.2	65.4	56.6	86.8	65.6	31.9	79.0	31.1	77.9	30.3	77.5	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	22.2	19.5	1.9	97.1	6.1	2.1	-2.5	98.6	-6.1	99.8	-9.5	101.0	-13.9	102.5
			1.0	67.5	5.9	5.2	-3.2	71.3	-6.6	74.3	-9.9	77.3	-14.2	81.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	52.5	32.8	36.5	43.9	50.6	59.7	70.3	73.5	71.1	65.0	52.9	40.9	31.8	(6)
(7)		DBStd	16.01	6.89	7.40	7.07	6.79	6.81	5.05	3.64	3.56	5.04	6.85	7.37	7.23	(7)
(8)		HDD50	2105	535	380	210	75	12	0	0	0	49	281	563		(8)
(9)		HDD65	5275	1000	799	655	431	187	14	0	2	59	376	724	1028	(9)
(10)		CDD50	3015	0	1	20	94	311	609	728	655	451	139	7	0	(10)
(11)		CDD65	710	0	0	0	0	22	173	263	192	59	1	0	0	(11)
(12)		CDH74	9539	0	0	4	43	693	2719	2936	2099	978	67	0	0	(12)
(13)		CDH80	3764	0	0	0	1	170	1221	1315	799	254	4	0	0	(13)
(14)	Wind	WSAvg	9.1	8.8	9.1	9.5	10.6	10.3	9.8	8.5	8.1	8.3	8.6	8.4	8.6	(14)
(15)	Precipitation	PrecAvg	13.7	0.5	0.5	0.7	0.6	0.9	0.7	2.2	2.4	1.7	1.4	0.9	1.1	(15)
(16)		PrecMax	22.7	1.9	1.5	1.9	2.4	3.3	2.8	4.6	4.9	5.0	3.5	2.4	3.9	(16)
(17)		PrecMin	8.3	0.0	0.1	0.0	0.0	0.1	0.1	0.3	1.0	0.4	0.0	0.0	0.2	(17)
(18)		PrecStd	3.3	0.4	0.4	0.5	0.5	0.8	0.6	1.2	1.0	0.9	1.0	0.7	0.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.9	64.2	73.4	78.4	88.6	96.1	95.3	93.0	88.6	79.6	68.3	56.6	(19)
(20)		MCWB	41.0	43.0	47.0	48.6	54.6	57.0	59.5	58.7	57.7	52.2	45.2	40.7		(20)
(21)		2%	DB	53.2	59.7	69.1	74.6	84.3	92.8	92.6	90.3	85.7	75.5	64.3	52.8	(21)
(22)		MCWB	38.2	40.6	44.8	47.1	52.0	56.2	59.0	58.9	56.5	51.1	44.6	38.5		(22)
(23)		5%	DB	49.6	55.4	64.8	72.0	81.3	90.1	90.3	87.8	82.7	72.5	60.6	48.8	(23)
(24)		MCWB	36.3	38.8	43.0	46.2	51.4	55.6	59.2	59.2	56.0	50.3	42.8	36.9		(24)
(25)		10%	DB	45.8	51.2	61.0	68.6	77.9	87.7	87.9	84.5	80.4	68.9	55.5	45.0	(25)
(26)		MCWB	34.5	37.2	41.1	44.9	49.8	54.9	59.4	59.1	55.6	49.0	40.6	34.7		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.5	44.7	48.7	51.5	58.3	62.5	65.0	64.6	61.6	58.6	48.4	43.3	(27)
(28)		MADB	52.9	59.4	67.6	70.0	79.0	82.0	79.7	78.6	74.8	67.6	61.0	51.7		(28)
(29)		2%	WB	39.5	42.0	45.9	49.7	55.3	60.3	63.6	63.2	60.1	55.2	46.1	40.3	(29)
(30)		MADB	49.5	55.7	65.2	68.8	75.6	80.9	79.9	78.4	74.8	68.6	59.9	50.0		(30)
(31)		5%	WB	37.4	40.1	43.9	47.6	53.5	59.1	62.5	62.2	59.0	53.0	44.0	37.6	(31)
(32)		MADB	47.0	53.2	62.2	67.2	73.3	80.0	79.2	77.7	74.3	65.7	57.9	47.1		(32)
(33)		10%	WB	35.4	38.0	42.1	46.0	51.8	57.8	61.7	61.3	57.8	50.9	41.9	35.2	(33)
(34)		MADB	44.8	49.7	58.5	65.4	71.7	78.5	78.7	76.9	73.0	64.3	54.3	44.2		(34)
(35)	Mean Daily Temperature Range	MDBR	23.1	25.0	28.7	29.8	30.7	32.3	28.0	27.3	28.5	27.1	25.7	22.3	(35)	
(36)		5% DB	MCDBR	27.8	31.6	35.0	35.0	35.3	35.5	32.0	31.4	32.1	31.6	31.3	26.7	(36)
(37)		MCWBR	16.1	17.1	17.3	16.2	15.2	13.7	9.9	10.0	11.9	14.5	16.4	15.7	(37)	
(38)		5% WB	MCDBR	24.7	28.1	32.1	31.8	30.8	30.4	26.7	25.6	26.6	26.0	27.8	24.2	(38)
(39)		MCWBR	15.0	15.7	16.2	14.8	13.2	11.4	8.3	8.1	9.8	12.4	15.2	14.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.235	0.239	0.261	0.279	0.301	0.315	0.355	0.341	0.307	0.269	0.250	0.240	(40)	
(41)		taud	2.655	2.666	2.593	2.540	2.518	2.469	2.449	2.441	2.536	2.632	2.621	2.637	(41)	
(42)		Ebn at Noon	317	326	324	319	311	305	292	295	302	310	308	308	(42)	
(43)		Edh at Noon	22	24	29	32	33	35	36	35	30	25	23	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1012	1307	1737	2122	2380	2492	2188	2037	1807	1453	1105	884	(44)	
(45)		RadStd	75	105	121	109	133	124	104	91	85	115	69	51	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.70	N/A	N/A	+1.28	N/A	N/A	N/A	N/A	+166	+117	(46)
(47)	Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+115	N/A	(47)

Nomenclature: See separate page