

SANTA FE, NM, USA

WMO: 723656

Lat: 35.617N

Lon: 106.089W

Elev: 1934

StdP: 80.15

Time Zone: -7.00 (NAM)

Period: 97-19

WBAN: 23049

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-12.1	-9.6	-20.9	0.7	1.9	-18.9	0.9	1.2	11.7	3.6	10.6	1.8	4.1	10	0.600

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.6	33.6	14.4	32.4	14.3	31.2	14.2	17.4	26.3	16.8	25.8	16.3	25.4	5.3	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.2	13.7	18.8	14.4	13.0	18.6	13.7	12.4	18.7	56.4	26.1	54.4	25.5	52.7	25.3	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.3	9.9	8.7	-16.7	36.2	3.4	1.2	-19.2	37.0	-21.2	37.7	-23.1	38.3	-25.5	39.2		
			-17.2	19.7	3.3	2.9	-19.6	21.8	-21.5	23.5	-23.3	25.1	-25.6	27.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.4	0.4	2.5	6.6	10.4	15.4	21.3	23.0	21.7	18.3	11.6	4.9	-0.1	(6)
(7)		DBStd	8.90	3.83	4.11	3.93	3.77	3.79	2.80	2.02	1.98	2.80	3.80	4.09	4.02	(7)
(8)		HDD10.0	1169	297	211	117	42	7	0	0	0	0	27	156	313	(8)
(9)		HDD18.3	2931	556	444	364	239	104	8	0	1	33	209	402	571	(9)
(10)		CDD10.0	1675	0	1	11	52	173	338	404	364	251	77	4	0	(10)
(11)		CDD18.3	394	0	0	0	0	12	96	146	107	33	1	0	0	(11)
(12)		CDH23.3	5299	0	0	2	24	385	1511	1631	1166	543	37	0	0	(12)
(13)		CDH26.7	2091	0	0	0	1	94	678	731	444	141	2	0	0	(13)
(14)	Wind	WSAvg	4.0	3.9	4.1	4.2	4.7	4.6	4.4	3.8	3.6	3.7	3.8	3.8	3.8	(14)
(15)	Precipitation	PrecAvg	348	13	13	19	16	24	19	57	60	43	35	22	27	(15)
(16)		PrecMax	577	48	38	47	60	85	71	118	125	127	90	61	100	(16)
(17)		PrecMin	212	0	2	0	0	2	3	7	25	9	0	0	4	(17)
(18)		PrecStd	83	11	10	12	13	20	14	31	26	24	25	17	21	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.8	17.9	23.0	25.8	31.4	35.6	35.2	33.9	31.5	26.5	20.2	13.6	(19)
(20)			MCWB	5.0	6.1	8.3	9.2	12.6	13.9	15.3	14.9	14.3	11.2	7.3	4.8	(20)
(21)		2%	DB	11.8	15.4	20.6	23.7	29.1	33.8	33.6	32.4	29.8	24.2	17.9	11.6	(21)
(22)			MCWB	3.4	4.8	7.1	8.4	11.1	13.4	15.0	14.9	13.6	10.6	7.0	3.6	(22)
(23)		5%	DB	9.8	13.0	18.2	22.2	27.4	32.3	32.4	31.0	28.2	22.5	15.9	9.3	(23)
(24)			MCWB	2.4	3.8	6.1	7.9	10.8	13.1	15.1	15.1	13.3	10.1	6.0	2.7	(24)
(25)		10%	DB	7.6	10.7	16.1	20.3	25.5	30.9	31.1	29.2	26.9	20.5	13.1	7.2	(25)
(26)			MCWB	1.4	2.9	5.1	7.2	9.9	12.7	15.2	15.1	13.1	9.4	4.8	1.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.8	7.0	9.3	10.8	14.6	16.9	18.3	18.1	16.5	14.8	9.1	6.3	(27)
(28)			MCDWB	11.6	15.2	19.8	21.1	26.1	27.8	26.5	25.9	23.8	19.8	16.1	11.0	(28)
(29)		2%	WB	4.2	5.5	7.7	9.8	13.0	15.7	17.6	17.3	15.6	12.9	7.8	4.6	(29)
(30)			MCDWB	9.7	13.2	18.4	20.5	24.2	27.2	26.6	25.8	23.8	20.4	15.5	10.0	(30)
(31)		5%	WB	3.0	4.5	6.6	8.6	11.9	15.0	16.9	16.8	15.0	11.6	6.7	3.1	(31)
(32)			MCDWB	8.3	11.8	16.8	19.6	23.0	26.7	26.2	25.4	23.5	18.7	14.4	8.4	(32)
(33)		10%	WB	1.9	3.3	5.6	7.8	11.0	14.3	16.5	16.3	14.4	10.5	5.5	1.8	(33)
(34)			MCDWB	7.1	9.8	14.7	18.6	22.1	25.8	25.9	25.0	22.8	17.9	12.4	6.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.8	13.9	16.0	16.6	17.1	18.0	15.6	15.2	15.8	15.1	14.3	12.4	(35)
(36)			MCDBR	15.4	17.5	19.5	19.5	19.6	19.7	17.8	17.4	17.8	17.6	17.4	14.8	(36)
(37)			MCWBR	9.0	9.5	9.6	9.0	8.4	7.6	5.5	5.6	6.6	8.0	9.1	8.7	(37)
(38)		5% WB	MCDWB	13.7	15.6	17.8	17.7	17.1	16.9	14.9	14.2	14.8	14.4	15.5	13.5	(38)
(39)			MCWBR	8.3	8.7	9.0	8.2	7.4	6.3	4.6	4.5	5.4	6.9	8.5	8.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.235	0.239	0.261	0.279	0.301	0.315	0.355	0.341	0.307	0.269	0.250	0.240	(40)	
(41)		taud	2.655	2.666	2.593	2.540	2.518	2.469	2.449	2.441	2.536	2.632	2.621	2.637	(41)	
(42)		Ebn at Noon	1000	1028	1020	1006	981	961	921	930	953	976	970	972	(42)	
(43)		Edh at Noon	69	77	91	101	105	111	112	111	95	79	71	66	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.19	4.12	5.47	6.69	7.50	7.86	6.90	6.42	5.70	4.58	3.48	2.79	(44)	
(45)		RadStd	0.23	0.33	0.38	0.34	0.42	0.39	0.33	0.29	0.27	0.36	0.22	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.39	N/A	N/A	+0.71	N/A	N/A	N/A	N/A	+92	+65
(47) Regional (11 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+64	N/A

Nomenclature: See separate page