

TAOS, NM, USA

WMO: 723663

Lat: 36.450N

Lon: 105.667W

Elev: 2161

StdP: 77.92

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 03012

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-17.9	-16.0	-23.0	0.6	-12.5	-21.2	0.7	-9.7	11.2	1.8	9.7	0.4	2.3	10	0.627

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.8	31.7	13.6	30.2	13.1	28.8	12.8	15.7	25.8	15.1	25.5	14.6	24.7	5.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.7	12.0	17.5	12.2	11.5	17.5	11.2	10.8	17.6	52.0	26.3	50.1	24.9	48.3	24.7	18.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.3	9.7	8.4	DB	-23.4	34.0	2.7	1.0	-25.3	34.7	-26.9	35.3	-28.4	35.9	-30.4	36.7	(4)
(5)			WB	-23.6	16.6	2.5	0.9	-25.4	17.3	-26.9	17.8	-28.3	18.2	-30.1	18.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.3	-3.2	-0.5	3.7	7.1	12.1	17.7	20.2	19.0	15.2	8.5	2.1	-3.2	(6)	
	DBStd	8.95	4.23	4.25	3.80	3.61	3.61	2.73	1.69	1.79	2.74	3.91	4.04	4.28	(7)	
	HDD10.0	1739	411	293	195	97	21	0	0	0	3	73	237	411	(8)	
	HDD18.3	3796	669	527	452	336	195	42	3	13	98	304	487	669	(9)	
	CDD10.0	1110	0	0	1	11	85	232	317	280	157	27	0	0	(10)	
	CDD18.3	124	0	0	0	0	1	24	62	35	3	0	0	0	(11)	
	CDH23.3	2916	0	0	0	3	149	858	984	673	236	11	0	0	(12)	
	CDH26.7	891	0	0	0	0	26	299	347	186	33	0	0	0	(13)	
(14) Wind	WSAvg	3.3	2.7	3.0	3.5	4.1	4.0	3.9	3.2	3.0	3.0	3.1	2.8	2.7	(14)	
(15) Precipitation	PrecAvg	310	16	14	20	20	24	27	41	48	37	27	19	18	(15)	
	PrecMax	430	44	39	69	53	54	91	80	131	71	72	52	46	(16)	
	PrecMin	198	2	1	0	0	0	0	12	6	5	0	0	0	(17)	
	PrecStd	64	12	9	15	15	17	22	18	29	21	19	13	12	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	15.1	21.1	23.2	29.1	33.0	32.9	32.2	29.0	24.9	18.5	12.6	(19)	
		MCWB	3.1	4.6	7.1	8.1	11.1	13.2	14.3	13.9	12.8	9.9	6.1	3.5	(20)	
	2%	DB	9.8	12.6	17.9	21.3	27.1	31.6	31.7	30.2	27.6	22.6	16.8	10.2	(21)	
		MCWB	1.9	3.4	5.7	7.4	10.3	12.9	14.0	13.6	12.0	9.4	5.9	2.2	(22)	
	5%	DB	7.5	10.8	16.2	19.2	24.9	30.0	30.2	28.7	26.3	21.0	14.0	7.7	(23)	
		MCWB	0.9	2.7	4.9	6.6	9.3	12.1	13.7	13.6	11.8	8.7	4.6	1.1	(24)	
	10%	DB	5.3	7.8	13.7	17.6	22.8	28.0	28.7	27.4	24.1	18.7	12.0	5.5	(25)	
		MCWB	-0.2	1.2	3.8	5.9	8.7	11.5	13.6	13.6	11.2	7.8	3.6	0.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.1	5.5	7.6	9.5	12.4	14.8	16.7	16.5	14.8	12.4	7.6	4.6	(27)	
		MCDB	10.1	13.1	19.0	20.4	25.2	27.9	26.1	26.0	23.9	19.8	16.3	10.4	(28)	
	2%	WB	2.6	4.0	6.3	8.2	11.2	13.9	15.8	15.7	13.8	10.6	6.2	3.0	(29)	
		MCDB	7.9	11.1	16.9	19.0	23.5	27.2	26.1	25.4	23.5	19.3	15.3	8.3	(30)	
	5%	WB	1.4	2.8	5.3	7.3	10.3	13.2	15.3	15.1	13.0	9.4	5.1	1.6	(31)	
		MCDB	6.7	9.3	15.3	17.9	22.5	26.4	26.0	24.9	22.6	18.7	13.3	6.9	(32)	
	10%	WB	0.2	1.7	4.2	6.3	9.4	12.5	14.8	14.5	12.3	8.3	3.9	0.3	(33)	
		MCDB	5.1	7.6	12.9	16.9	21.3	25.4	25.3	24.0	21.8	17.4	10.9	5.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	16.1	15.0	17.1	17.5	18.6	20.1	17.8	17.1	17.9	17.7	16.9	15.7	(35)	
		MCDBR	18.5	18.9	21.5	21.4	21.9	22.7	20.3	19.7	20.3	21.2	20.9	18.4	(36)	
	5% WB	MCWBR	12.2	11.2	11.6	11.0	10.4	10.2	7.9	7.7	9.2	11.1	12.3	12.1	(37)	
		MCWBR	16.8	16.3	19.8	19.6	19.8	19.6	17.0	16.1	16.8	18.0	19.0	16.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.233	0.239	0.272	0.287	0.306	0.316	0.362	0.340	0.301	0.270	0.248	0.240	(40)	
		taud	2.646	2.640	2.541	2.512	2.502	2.468	2.420	2.441	2.557	2.624	2.618	2.616	(41)	
	Ebn at Noon		999	1024	1005	996	974	959	913	930	958	971	967	965	(42)	
		Edh at Noon	68	78	95	104	107	111	115	110	93	79	70	66	(43)	
(44) All-Sky Solar Radiation	RadAvg		3.12	4.05	5.31	6.46	7.20	7.54	6.45	6.07	5.54	4.50	3.39	2.73	(44)	
	RadStd		0.19	0.30	0.41	0.36	0.50	0.43	0.35	0.30	0.31	0.31	0.21	0.15	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	+0.55	+0.72	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)		+0.31	N/A	N/A	+0.43	N/A	N/A	N/A	N/A	+62	+25

Nomenclature: See separate page