

LAS VEGAS, NM, USA

WMO: 723677

Lat: 35.654N

Lon: 105.142W

Elev: 6874

StdP: 11.39

Time Zone: -7.00 (NAM)

Period: 00-19

WBAN: 23054

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	7.5	12.1	-9.2	4.3	37.1	-5.2	5.4	38.7	34.7	42.7	32.2	41.9	8.4	180	0.673

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.2	88.8	56.1	86.5	56.2	84.1	56.1	62.1	77.0	61.0	76.0	60.1	75.0	14.1	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.9	93.0	64.2	56.8	89.1	63.8	55.6	85.1	63.5	31.2	76.7	30.4	75.8	29.6	74.7	66.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 32.2	27.6	24.6	DB	-3.2	93.0	5.9	1.8	-7.5	94.3	-11.0	95.4	-14.3	96.4	-18.6	97.7	(4)
(5)			WB	-4.0	64.5	5.7	1.3	-8.1	65.4	-11.5	66.1	-14.7	66.8	-18.9	67.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.7	33.3	35.1	42.2	48.8	56.6	66.7	69.3	67.3	61.7	51.5	41.2	33.4		
	DBStd	15.03	8.92	9.70	8.70	7.56	7.28	5.03	3.63	3.87	5.10	7.76	9.09	9.31		
	HDD50	2212	517	420	265	108	27	0	0	0	2	75	281	517		
	HDD65	5581	981	837	708	486	267	39	9	22	119	418	714	981		
	CDD50	2462	0	3	23	73	233	501	599	537	352	123	17	1		
	CDD65	354	0	0	0	0	8	90	142	94	19	1	0	0		
	CDH74	5472	0	0	1	16	329	1647	1719	1196	501	62	1	0		
	CDH80	1670	0	0	0	0	47	598	600	343	80	2	0	0		
(14) Wind	WSAvg	11.0	10.3	11.9	12.3	13.6	12.3	11.4	9.2	8.9	10.0	10.5	10.6	10.6		
(15) Precipitation	PrecAvg	16.0	0.3	0.3	0.5	0.5	1.4	1.9	3.5	3.6	1.9	1.0	0.6	0.4		
	PrecMax	23.2	0.6	1.5	2.3	2.1	3.7	4.8	8.0	8.3	4.3	4.1	3.9	1.1		
	PrecMin	9.0	0.0	0.0	0.0	0.0	0.2	0.4	0.7	1.2	0.0	0.0	0.0	0.0		
	PrecStd	3.9	0.2	0.3	0.5	0.5	0.9	1.1	1.9	1.9	1.1	1.2	0.9	0.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.9	67.0	72.7	76.3	84.3	92.2	91.3	89.9	85.2	79.4	70.9	63.4		
		MCWB	41.2	42.9	45.0	46.7	51.6	54.6	57.8	56.8	55.9	50.5	45.0	40.9		
	2%	DB	57.7	61.5	68.5	72.6	81.0	89.1	88.5	86.5	82.3	75.6	66.8	58.1		
		MCWB	38.8	40.4	43.3	45.3	50.4	54.1	57.8	57.6	54.7	49.4	43.5	39.1		
	5%	DB	53.3	57.0	64.6	69.7	77.8	86.4	86.3	83.9	80.0	72.0	62.9	53.7		
		MCWB	36.7	38.4	41.8	44.5	49.5	53.6	58.0	57.9	54.4	48.8	42.4	37.2		
	10%	DB	49.3	52.3	60.3	66.6	74.5	83.6	83.6	81.2	76.8	68.4	58.1	49.3		
		MCWB	34.9	36.4	40.2	43.6	48.4	53.5	58.1	58.1	54.3	47.7	40.5	35.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.7	44.0	46.9	50.8	57.0	61.6	63.5	63.6	61.0	57.1	47.5	43.0		
		MCDB	59.2	62.3	66.4	64.4	71.6	77.3	77.8	78.4	73.2	64.7	63.5	58.0		
	2%	WB	39.9	41.4	44.5	48.3	54.6	59.7	62.3	62.1	59.3	53.8	45.4	40.4		
		MCDB	54.7	57.8	64.3	64.7	70.2	76.2	77.3	76.8	71.5	64.4	62.8	55.0		
	5%	WB	37.6	39.4	42.6	46.4	52.6	58.3	61.3	61.0	57.9	51.3	43.5	38.2		
		MCDB	51.2	55.2	61.7	64.4	68.7	75.1	76.7	75.4	70.6	65.5	59.7	52.1		
	10%	WB	35.4	37.1	41.0	44.6	50.6	56.9	60.3	59.9	56.7	49.5	41.4	35.9		
		MCDB	48.0	51.0	58.9	63.3	67.5	74.0	75.9	74.0	69.7	64.2	56.1	48.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	25.1	25.2	27.9	28.4	28.3	30.4	27.2	26.4	27.2	27.4	26.9	24.0		
		MCDBR	31.1	31.4	33.4	32.0	33.1	34.1	31.8	30.7	31.8	32.1	32.3	30.0		
	5% WB	MCWBR	17.2	16.3	15.9	14.6	14.0	12.3	10.0	10.3	11.8	14.3	15.9	16.4		
		MCWBR	28.6	28.6	31.0	30.2	29.0	29.1	25.9	25.2	25.7	26.3	28.8	27.8		
(40) Clear-Sky Solar Irradiance	taub	taub	0.230	0.239	0.266	0.285	0.296	0.320	0.358	0.336	0.293	0.277	0.241	0.237		
		taud	2.659	2.645	2.557	2.504	2.532	2.455	2.426	2.464	2.585	2.586	2.642	2.629		
	Ebn at Noon	Ebn at Noon	319	326	322	317	313	303	291	297	308	306	312	309		
		Edh at Noon	22	25	30	33	33	36	36	34	29	26	22	21		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1024	1321	1730	2107	2346	2438	2184	2037	1797	1440	1104	894		
	RadStd	RadStd	66	102	126	124	134	116	98	95	92	113	69	45		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	+0.88	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)		+0.59	N/A	N/A	+0.79	N/A	N/A	N/A	N/A	+128	+86

Nomenclature: See separate page