

LAS VEGAS, NM, USA

WMO: 723677

Lat: 35.654N

Lon: 105.142W

Elev: 2095

StdP: 78.56

Time Zone: -7.00 (NAM)

Period: 00-19

WBAN: 23054

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(1) 12	-13.6	-11.1	-22.9	0.6	2.9	-20.7	0.8	3.7	15.5	5.9	14.4	5.5	3.7	180	0.673 (1)

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(2) 7	15.1	31.6	13.4	30.3	13.5	28.9	13.4	16.7	25.0	16.1	24.4	15.6	23.9	6.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(3) 14.4	13.3	17.9	13.8	12.7	17.6	13.1	12.2	17.5	54.7	24.9	52.8	24.3	50.9	23.7	19.1 (3)

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(4)	14.4	12.3	11.0	-19.6	33.9	3.3	1.0	-21.9	34.6	-23.9	35.2	-25.7	35.8	-28.1	36.5
(5)				-20.0	18.0	3.2	0.7	-22.3	18.5	-24.2	18.9	-26.0	19.3	-28.3	19.8
			DB												(4)
			WB												(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.4	0.7	1.7	5.6	9.3	13.7	19.3	20.7	19.6	16.5	10.9	5.1	0.8	(6)
(7)		DBStd	8.35	4.96	5.39	4.83	4.20	4.04	2.79	2.01	2.15	2.83	4.31	5.05	5.17	(7)
(8)		HDD10.0	1229	287	233	147	60	15	0	0	0	1	42	156	287	(8)
(9)		HDD18.3	3101	545	465	393	270	148	22	5	12	66	232	397	545	(9)
(10)		CDD10.0	1368	0	2	13	41	129	278	333	298	196	68	9	1	(10)
(11)		CDD18.3	197	0	0	0	0	4	50	79	52	11	1	0	0	(11)
(12)		CDH23.3	3040	0	0	1	9	183	915	955	664	278	34	1	0	(12)
(13)		CDH26.7	928	0	0	0	0	26	332	333	191	44	1	0	0	(13)
(14)	Wind	WSAvg	4.9	4.6	5.3	5.5	6.1	5.5	5.1	4.1	4.0	4.5	4.7	4.7	4.8	(14)
(15)	Precipitation	PrecAvg	406	7	8	12	13	35	47	89	92	47	26	16	11	(15)
(16)		PrecMax	589	14	37	59	53	94	122	202	211	110	103	98	28	(16)
(17)		PrecMin	228	0	0	0	0	4	9	19	31	0	0	0	0	(17)
(18)		PrecStd	98	5	8	12	12	24	28	48	49	27	31	23	9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.1	19.4	22.6	24.6	29.0	33.5	32.9	32.2	29.6	26.3	21.6	17.5	(19)
(20)			MCWB	5.1	6.1	7.2	8.2	10.9	12.6	14.3	13.8	13.3	10.3	7.2	4.9	(20)
(21)		2%	DB	14.3	16.4	20.3	22.6	27.2	31.7	31.4	30.3	27.9	24.2	19.4	14.5	(21)
(22)			MCWB	3.8	4.7	6.3	7.4	10.2	12.3	14.3	14.2	12.6	9.7	6.4	4.0	(22)
(23)		5%	DB	11.8	13.9	18.1	20.9	25.5	30.2	30.2	28.8	26.6	22.2	17.2	12.0	(23)
(24)			MCWB	2.6	3.5	5.4	6.9	9.7	12.0	14.4	14.4	12.5	9.3	5.8	2.9	(24)
(25)		10%	DB	9.6	11.3	15.7	19.2	23.6	28.6	28.6	27.3	24.9	20.2	14.5	9.6	(25)
(26)			MCWB	1.6	2.4	4.6	6.4	9.1	11.9	14.5	14.5	12.4	8.7	4.7	2.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.9	6.7	8.3	10.5	13.9	16.4	17.5	17.5	16.1	14.0	8.6	6.1	(27)
(28)			MCDB	15.1	16.9	19.1	18.0	22.0	25.1	25.5	25.8	22.9	18.2	17.5	14.4	(28)
(29)		2%	WB	4.4	5.2	6.9	9.1	12.6	15.4	16.8	16.7	15.2	12.1	7.4	4.7	(29)
(30)			MCDB	12.6	14.4	17.9	18.2	21.2	24.5	25.1	24.9	21.9	18.0	17.1	12.8	(30)
(31)		5%	WB	3.1	4.1	5.9	8.0	11.4	14.6	16.3	16.1	14.4	10.7	6.4	3.4	(31)
(32)			MCDB	10.7	12.9	16.5	18.0	20.4	24.0	24.8	24.1	21.5	18.6	15.4	11.2	(32)
(33)		10%	WB	1.9	2.9	5.0	7.0	10.3	13.9	15.7	15.5	13.7	9.7	5.2	2.2	(33)
(34)			MCDB	8.9	10.6	14.9	17.4	19.7	23.3	24.4	23.3	20.9	17.9	13.4	9.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.9	14.0	15.5	15.8	15.7	16.9	15.1	14.7	15.1	15.2	14.9	13.3	(35)
(36)			MCDBR	17.3	17.4	18.6	17.8	18.4	19.0	17.7	17.1	17.7	17.9	17.9	16.7	(36)
(37)			MCWBR	9.5	9.1	8.9	8.1	7.8	6.8	5.6	5.7	6.6	8.0	8.8	9.1	(37)
(38)		5% WB	MCDBR	15.9	15.9	17.2	16.8	16.1	16.2	14.4	14.0	14.3	14.6	16.0	15.4	(38)
(39)			MCWBR	9.2	8.6	8.6	8.1	7.5	6.6	5.2	5.3	5.8	7.3	8.3	8.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.230	0.239	0.266	0.285	0.296	0.320	0.358	0.336	0.293	0.277	0.241	0.237	(40)	
(41)		taud	2.659	2.645	2.557	2.504	2.532	2.455	2.426	2.464	2.585	2.586	2.642	2.629	(41)	
(42)		Ebn at Noon	1007	1028	1014	1000	986	956	918	935	970	965	982	975	(42)	
(43)		Edh at Noon	68	78	94	105	104	112	115	108	91	82	69	66	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.23	4.17	5.46	6.64	7.39	7.68	6.88	6.42	5.66	4.54	3.48	2.82	(44)	
(45)		RadStd	0.21	0.32	0.40	0.39	0.42	0.37	0.31	0.30	0.29	0.36	0.22	0.14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	N/A	N/A	N/A	N/A	+0.49	N/A	N/A	N/A	N/A	(46)
(47)	Regional (11 neighbors)	+0.33	N/A	N/A	+0.44	N/A	N/A	N/A	+71	+48	(47)

Nomenclature: See separate page