

KINGMAN, AZ, USA

WMO: 723700

Lat: 35.258N

Lon: 113.933W

Elev: 3420

StdP: 12.97

Time Zone: -7.00 (W07)

Period: 94-19

WBAN: 93167

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	24.2	27.0	-3.2	5.3	49.0	0.7	6.5	48.3	30.2	48.3	26.8	48.9	5.1	100	0.568

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.6	102.3	64.0	100.1	63.6	98.2	62.9	69.7	87.6	68.7	87.3	67.7	87.0	14.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.5	107.0	74.3	63.5	99.5	75.4	61.3	92.2	76.9	35.8	87.1	34.9	86.7	33.9	86.3	87.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	24.5	21.5	17.6	107.2	3.6	2.6	15.0	109.0	12.9	110.5	10.8	112.0	8.2	113.8
			14.5	73.1	3.2	3.9	12.2	75.9	10.3	78.2	8.5	80.3	6.1	83.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.9	44.5	47.1	53.4	59.1	68.6	79.2	84.3	82.9	75.8	63.3	52.0	43.3
	DBStd	15.86	6.08	6.67	6.86	7.74	7.70	6.27	4.24	3.98	5.59	7.24	7.36	6.29
	HDD50	658	184	123	46	15	0	0	0	0	5	63	222	
	HDD65	2948	635	502	362	206	55	2	0	0	5	117	390	674
	CDD50	5355	14	41	151	288	576	875	1062	1020	774	417	124	13
	CDD65	2170	0	0	2	29	166	427	597	555	329	64	1	0
	CDH74	31479	0	6	138	664	2626	6628	8654	7581	4083	1020	79	0
	CDH80	17461	0	0	20	185	1198	3967	5268	4424	2087	308	4	0
(14) Wind	WSAvg	9.4	7.7	8.7	9.7	10.9	11.2	11.6	10.5	9.9	8.9	8.5	7.8	7.5
(15) Precipitation	PrecAvg	9.9	1.2	1.1	1.3	0.6	0.3	0.2	0.9	1.3	0.8	0.7	0.8	1.0
	PrecMax	18.7	5.9	4.6	4.8	4.1	2.2	1.5	4.0	5.4	3.0	2.2	3.1	3.6
	PrecMin	3.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	3.3	1.2	1.1	1.2	0.9	0.5	0.4	1.0	1.3	0.8	0.7	0.8	0.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.8	74.6	82.4	89.6	98.0	105.8	106.6	103.0	98.8	90.4	80.5	68.4
		MCWB	47.6	49.2	52.5	55.7	60.1	63.9	65.2	64.9	62.9	60.8	53.1	48.0
	2%	DB	64.5	70.4	77.8	84.9	93.6	101.3	102.9	100.7	95.7	86.6	76.3	63.9
		MCWB	45.4	47.5	50.9	54.1	58.2	61.4	64.8	65.0	62.0	57.6	51.1	46.0
	5%	DB	61.4	66.1	74.0	81.4	90.6	98.9	100.5	98.8	93.3	83.5	72.6	60.3
		MCWB	44.6	45.8	49.6	52.7	57.0	60.5	64.4	64.9	61.5	55.8	50.2	44.4
	10%	DB	57.7	62.1	70.7	77.6	87.2	96.6	98.3	96.6	90.9	80.5	68.0	56.1
		MCWB	43.3	44.7	48.4	51.0	55.8	59.6	63.7	64.4	61.3	54.7	48.2	43.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.0	51.5	54.8	57.4	62.0	66.2	71.1	72.1	70.1	64.7	56.7	51.3
		MCDB	61.9	65.2	77.0	85.9	93.7	96.1	87.0	91.0	85.1	78.9	71.1	62.1
	2%	WB	48.7	49.7	52.3	55.2	59.6	64.2	69.6	69.8	68.0	60.6	53.4	49.0
		MCDB	57.9	64.5	73.4	81.8	89.7	94.4	87.0	88.9	84.1	79.3	70.4	59.3
	5%	WB	46.8	47.9	50.7	53.4	57.9	62.7	68.8	68.7	66.3	58.4	51.3	46.8
		MCDB	57.0	62.6	71.0	78.3	87.8	93.6	87.0	88.3	82.4	76.9	68.8	56.8
	10%	WB	44.7	45.9	49.1	51.7	56.3	61.1	67.9	67.7	64.9	56.3	49.4	44.3
		MCDB	55.6	59.2	68.4	75.2	85.0	92.6	87.0	87.7	81.3	75.2	66.9	54.1
(35) Mean Daily Temperature Range	5% DB	MDBR	23.8	24.3	27.2	28.3	28.6	29.5	25.6	25.2	27.0	27.7	26.5	22.9
		MCDBR	29.3	31.3	32.9	33.3	32.5	32.1	29.3	28.2	29.8	31.4	31.9	28.3
	5% WB	MCWBR	16.1	15.8	15.5	15.0	14.3	13.4	11.2	10.5	11.3	14.1	16.2	15.5
		MCDWR	23.4	26.4	29.8	31.0	30.3	28.8	22.5	23.1	23.1	25.7	27.8	22.7
(40) Clear-Sky Solar Irradiance	taub		0.254	0.259	0.270	0.298	0.305	0.308	0.353	0.360	0.310	0.288	0.259	0.254
		taud	2.639	2.647	2.593	2.480	2.501	2.490	2.460	2.426	2.550	2.583	2.642	2.644
	Ebn at Noon		309	318	321	313	310	307	293	289	302	302	305	303
		Edh at Noon	23	25	29	34	34	34	35	36	30	26	22	21
(44) All-Sky Solar Radiation	RadAvg		1007	1306	1783	2234	2522	2704	2321	2150	1935	1496	1130	895
	RadStd		82	114	98	94	121	108	132	110	82	91	48	68

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	-3.76	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (12 neighbors)	N/A	N/A	-2.74	N/A	N/A	N/A	N/A	N/A	+187	+83

Nomenclature: See separate page