

PAGE, AZ, USA

WMO: 723710

Lat: 36.926N

Lon: 111.448W

Elev: 4310

StdP: 12.55

Time Zone: -7.00 (W07)

Period: 94-19

WBAN: 03162

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	22.9	25.5	-1.7	5.9	43.6	1.6	7.0	43.6	18.7	48.0	16.1	45.3	2.5	150	0.449

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.1	100.7	62.0	98.8	61.7	96.6	60.8	66.8	85.4	65.9	85.3	64.9	85.1	7.1	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.7	100.0	71.6	60.4	92.2	73.0	57.4	82.6	74.7	33.7	83.9	32.9	84.8	32.0	85.2	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.2	15.6	12.6	DB	17.6	104.9	4.8	2.0	14.2	106.4	11.3	107.5	8.6	108.7	5.1	110.1	(4)
			WB	14.6	69.0	3.1	3.3	12.4	71.3	10.5	73.2	8.8	75.0	6.5	77.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	60.5	37.9	42.9	51.6	58.5	68.6	79.7	84.9	81.6	74.2	60.2	47.0	37.5	(6)
(7)		DBStd	17.72	5.48	6.41	7.03	7.60	7.77	6.45	4.26	4.44	5.96	7.04	6.84	5.91	(7)
(8)		HDD50	1199	375	210	65	17	0	0	0	0	7	136	389	(8)	
(9)		HDD65	3729	839	618	416	215	56	3	0	9	180	541	852	(9)	
(10)		CDD50	5032	0	12	116	273	576	891	1082	981	727	325	46	3	(10)
(11)		CDD65	2084	0	0	2	21	167	443	617	516	286	32	0	0	(11)
(12)		CDH74	26043	0	0	29	272	1902	6085	8431	6277	2781	266	0	0	(12)
(13)		CDH80	13605	0	0	1	47	736	3406	4898	3314	1152	51	0	0	(13)
(14)	Wind	WSAvg	4.8	3.1	4.1	5.3	6.5	6.3	6.0	5.4	5.0	4.8	4.2	3.5	3.1	(14)
(15)	Precipitation	PrecAvg	7.0	0.6	0.6	0.5	0.4	0.4	0.2	0.8	1.1	0.8	0.9	0.4	0.5	(15)
(16)		PrecMax	11.3	3.0	2.3	1.4	1.5	1.7	1.4	1.9	2.8	3.1	3.9	1.9	1.4	(16)
(17)		PrecMin	3.3	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	2.2	0.7	0.6	0.5	0.4	0.5	0.3	0.5	0.6	0.7	1.0	0.5	0.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.2	66.3	78.2	84.7	95.4	103.2	104.5	101.0	96.3	84.8	69.4	59.6	(19)
(20)		0.4%	MCWB	42.5	45.0	50.2	52.9	58.7	60.3	63.0	61.9	60.9	55.5	49.5	44.4	(20)
(21)		2%	DB	52.4	61.5	72.5	80.7	90.7	99.7	101.7	98.7	92.5	80.8	65.6	53.9	(21)
(22)		2%	MCWB	40.1	44.1	47.8	51.3	56.5	60.0	62.7	62.2	59.6	54.9	47.0	41.7	(22)
(23)		5%	DB	49.7	57.4	68.9	76.9	87.7	97.3	99.4	96.5	89.9	76.6	62.5	49.7	(23)
(24)		5%	MCWB	38.7	42.0	46.3	49.6	55.0	59.1	62.8	61.8	58.7	53.0	45.7	40.1	(24)
(25)		10%	DB	46.9	54.0	65.1	73.4	84.0	94.6	97.1	93.5	86.9	72.9	58.6	46.4	(25)
(26)		10%	MCWB	37.5	40.6	44.9	48.4	53.8	57.9	61.8	61.5	58.0	51.5	43.9	37.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.6	47.9	51.2	54.5	60.9	64.0	68.7	68.3	66.3	61.3	51.0	46.5	(27)
(28)		0.4%	MCDWB	51.1	61.6	72.8	79.8	92.6	94.5	91.5	82.0	79.6	72.4	66.3	55.7	(28)
(29)		2%	WB	42.6	45.2	49.1	52.3	58.0	62.2	67.1	66.8	64.3	57.8	48.4	43.6	(29)
(30)		2%	MCDWB	49.1	57.4	69.6	76.8	84.7	93.3	87.5	83.5	78.1	72.2	62.3	51.7	(30)
(31)		5%	WB	40.5	43.4	47.3	50.7	56.3	60.8	66.1	65.8	62.9	55.4	46.5	41.1	(31)
(32)		5%	MCDWB	47.1	55.2	65.8	73.9	82.5	91.1	87.3	83.9	78.7	71.1	59.8	48.2	(32)
(33)		10%	WB	38.6	41.7	45.7	49.3	54.8	59.5	65.2	64.8	61.3	53.4	44.7	38.8	(33)
(34)		10%	MCDWB	45.4	51.7	63.0	71.3	80.6	89.4	87.0	83.9	79.3	68.9	57.2	45.6	(34)
(35)	Mean Daily Temperature Range		MDBR	15.2	17.5	20.9	22.2	23.3	24.9	23.1	22.2	22.3	20.7	17.8	14.2	(35)
(36)		5% DB	MCDBR	18.2	22.2	25.5	26.7	27.0	27.3	25.6	25.3	25.0	24.1	21.6	17.3	(36)
(37)			MCWBR	10.6	11.4	11.3	11.4	10.9	10.8	8.8	8.1	8.8	10.2	10.7	10.0	(37)
(38)			5% WB	MCDWB	15.0	19.9	23.5	25.0	25.5	25.1	21.6	20.9	19.6	20.1	19.8	15.8
(39)		MCWBR		9.3	10.6	10.7	10.7	10.2	10.5	6.8	6.5	7.1	8.7	10.3	9.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.259	0.265	0.286	0.309	0.321	0.319	0.368	0.372	0.322	0.297	0.262	0.257	(40)	
(41)		taud	2.534	2.531	2.463	2.384	2.395	2.393	2.337	2.321	2.455	2.491	2.548	2.555	(41)	
(42)		Ebn at Noon	302	313	313	308	304	303	287	285	296	295	298	296	(42)	
(43)		Edh at Noon	24	28	33	37	38	38	40	39	32	28	23	22	(43)	
(44)	All-Sky Solar Radiation	RadAvg	932	1222	1719	2143	2413	2656	2300	2055	1850	1417	1057	818	(44)	
(45)		RadStd	79	99	100	102	155	128	111	96	76	108	57	57	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.97	N/A	N/A	+1.01	N/A	N/A	N/A	N/A	+414	+245	(46)
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page