

PAGE, AZ, USA

WMO: 723710

Lat: 36.926N

Lon: 111.448W

Elev: 1314

StdP: 86.51

Time Zone: -7.00 (W07)

Period: 94-19

WBAN: 03162

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-5.1	-3.6	-18.7	0.8	6.5	-16.9	1.0	6.4	8.4	8.9	7.2	7.4	1.1	150	0.449

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.8	38.2	16.7	37.1	16.5	35.9	16.0	19.3	29.7	18.8	29.6	18.3	29.5	3.2	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.0	14.3	22.0	15.8	13.2	22.8	14.1	11.8	23.7	60.5	28.8	58.6	29.3	56.7	29.5	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	7.0	5.6	-8.0	40.5	2.7	1.1	-9.9	41.3	-11.5	42.0	-13.0	42.6	-14.9	43.4		
(5)			-9.7	20.5	1.7	1.8	-10.9	21.8	-11.9	22.9	-12.9	23.9	-14.2	25.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.8	3.3	6.1	10.9	14.7	20.3	26.5	29.4	27.6	23.5	15.7	8.3	3.1	(6)
(7)		DBStd	9.84	3.04	3.56	3.90	4.22	4.31	3.58	2.37	2.47	3.31	3.91	3.80	3.28	(7)
(8)		HDD10.0	666	208	117	36	9	0	0	0	0	0	4	76	216	(8)
(9)		HDD18.3	2072	466	343	231	119	31	2	0	5	100	301	473		(9)
(10)		CDD10.0	2796	0	7	64	152	320	495	601	545	404	181	26	2	(10)
(11)		CDD18.3	1158	0	0	1	12	93	246	343	287	159	18	0	0	(11)
(12)		CDH23.3	14468	0	0	16	151	1057	3381	4684	3487	1545	148	0	0	(12)
(13)		CDH26.7	7558	0	0	1	26	409	1892	2721	1841	640	28	0	0	(13)
(14)	Wind	WSAvg	2.1	1.4	1.8	2.4	2.9	2.8	2.7	2.4	2.2	2.2	1.9	1.6	1.4	(14)
(15)	Precipitation	PrecAvg	179	15	14	13	9	10	5	20	27	20	24	11	12	(15)
(16)		PrecMax	287	77	58	35	39	43	35	47	71	78	98	48	35	(16)
(17)		PrecMin	85	0	0	0	0	0	1	3	4	0	0	0	0	(17)
(18)		PrecStd	56	19	14	12	11	12	7	12	15	19	25	12	9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.5	19.0	25.7	29.3	35.2	39.5	40.3	38.3	35.7	29.3	20.8	15.3	(19)
(20)			MCWB	5.8	7.2	10.1	11.6	14.8	15.7	17.2	16.6	16.0	13.1	9.7	6.9	(20)
(21)		2%	DB	11.3	16.4	22.5	27.0	32.6	37.6	38.7	37.1	33.6	27.1	18.6	12.2	(21)
(22)			MCWB	4.5	6.7	8.8	10.7	13.6	15.5	17.0	16.8	15.3	12.7	8.4	5.4	(22)
(23)		5%	DB	9.8	14.1	20.5	24.9	30.9	36.3	37.5	35.8	32.2	24.8	17.0	9.8	(23)
(24)			MCWB	3.7	5.6	8.0	9.8	12.8	15.0	17.1	16.6	14.9	11.6	7.6	4.5	(24)
(25)		10%	DB	8.3	12.2	18.4	23.0	28.9	34.8	36.2	34.2	30.5	22.7	14.8	8.0	(25)
(26)			MCWB	3.0	4.8	7.2	9.1	12.1	14.4	16.6	16.4	14.4	10.8	6.6	3.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.6	8.8	10.7	12.5	16.1	17.8	20.4	20.2	19.1	16.3	10.6	8.0	(27)
(28)			MCDWB	10.6	16.4	22.7	26.6	33.7	34.7	33.0	27.8	26.4	22.4	19.1	13.2	(28)
(29)		2%	WB	5.9	7.3	9.5	11.3	14.4	16.8	19.5	19.3	18.0	14.3	9.1	6.4	(29)
(30)			MCDWB	9.5	14.1	20.9	24.9	29.3	34.1	30.8	28.6	25.6	22.3	16.8	10.9	(30)
(31)		5%	WB	4.7	6.4	8.5	10.4	13.5	16.0	19.0	18.8	17.1	13.0	8.0	5.1	(31)
(32)			MCDWB	8.4	12.9	18.8	23.3	28.1	32.8	30.7	28.8	25.9	21.7	15.4	9.0	(32)
(33)		10%	WB	3.7	5.4	7.6	9.6	12.7	15.3	18.5	18.2	16.3	11.9	7.0	3.8	(33)
(34)			MCDWB	7.4	10.9	17.2	21.8	27.0	31.9	30.6	28.8	26.3	20.5	14.0	7.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.4	9.7	11.6	12.3	12.9	13.9	12.8	12.4	11.5	9.9	7.9	(35)	
(36)			MCDBR	10.1	12.4	14.2	14.8	15.0	15.2	14.2	14.1	13.9	13.4	12.0	9.6	(36)
(37)			MCWBR	5.9	6.3	6.3	6.3	6.0	6.0	4.9	4.5	4.9	5.6	6.0	5.6	(37)
(38)		5% WB	MCDBR	8.4	11.0	13.1	13.9	14.2	14.0	12.0	11.6	10.9	11.2	11.0	8.8	(38)
(39)			MCWBR	5.2	5.9	5.9	5.9	5.7	5.9	3.8	3.6	4.0	4.9	5.7	5.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.259	0.265	0.286	0.309	0.321	0.319	0.368	0.372	0.322	0.297	0.262	0.257	(40)	
(41)		taud	2.534	2.531	2.463	2.384	2.395	2.393	2.337	2.321	2.455	2.491	2.548	2.555	(41)	
(42)		Ebn at Noon	952	986	986	972	959	955	906	897	932	931	940	933	(42)	
(43)		Edh at Noon	76	87	103	118	119	119	125	124	102	89	74	70	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.94	3.85	5.42	6.76	7.61	8.37	7.25	6.48	5.83	4.47	3.33	2.58	(44)	
(45)		RadStd	0.25	0.31	0.32	0.32	0.49	0.40	0.35	0.30	0.24	0.34	0.18	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.54	N/A	N/A	+0.56	N/A	N/A	N/A	N/A	+230	+136
(47) Regional (10 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page