

PRESCOTT, AZ, USA

WMO: 723723

Lat: 34.652N

Lon: 112.421W

Elev: 5042

StdP: 12.21

Time Zone: -7.00 (W07)

Period: 94-19

WBAN: 23184

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	18.2	21.2	-4.4	5.2	42.8	-0.4	6.5	44.6	24.5	42.7	20.6	44.0	4.4	200	0.508

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.1	94.7	60.3	92.4	60.0	90.3	59.6	66.8	80.4	65.6	79.1	64.5	78.5	10.7	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.3	105.4	70.5	61.9	100.0	70.1	60.5	95.0	70.0	34.3	79.5	33.2	78.1	32.2	78.3	72.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.8	18.8	16.9	11.5	99.2	4.4	2.7	8.3	101.1	5.7	102.7	3.2	104.1	0.0	106.1
			9.7	68.6	4.1	1.3	6.7	69.5	4.3	70.3	2.0	71.1	-1.0	72.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.9	39.8	42.2	48.1	53.4	62.0	72.2	76.6	74.6	68.7	57.5	47.3	39.1	(6)
	DBStd	14.58	6.20	6.72	6.54	6.99	6.87	5.65	3.84	3.79	4.78	6.64	6.88	6.30	(7)
	HDD50	1192	317	227	113	45	4	0	0	0	0	19	128	339	(8)
	HDD65	4032	781	638	523	349	137	11	0	0	21	239	531	802	(9)
	CDD50	3705	1	8	55	148	376	667	826	762	562	252	47	1	(10)
	CDD65	1073	0	0	0	2	44	228	361	298	133	7	0	0	(11)
	CDH74	13721	0	0	18	131	977	3567	4038	3072	1604	304	10	0	(12)
	CDH80	5930	0	0	0	14	279	1730	1985	1356	526	40	0	0	(13)
(14) Wind	WSAvg	7.2	6.1	7.0	7.9	8.9	8.7	8.7	7.1	6.5	6.7	6.7	6.2	5.9	(14)
(15) Precipitation	PrecAvg	14.4	1.0	1.1	1.2	0.5	0.5	0.4	2.3	2.7	1.6	1.1	0.9	1.0	(15)
	PrecMax	22.1	4.8	4.3	4.2	2.4	2.2	2.6	6.5	7.9	8.6	7.1	3.8	4.9	(16)
	PrecMin	7.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	(17)
	PrecStd	3.9	1.0	1.0	1.1	0.6	0.6	0.7	1.5	1.6	1.7	1.3	0.9	1.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.9	70.5	76.5	82.0	90.6	98.5	98.9	95.8	91.0	84.2	75.2	65.4	(19)
		MCWB	44.1	46.5	49.1	52.0	57.5	60.1	62.1	61.9	59.3	55.2	49.7	45.2	(20)
	2%	DB	61.3	66.0	72.0	77.8	86.3	94.3	95.0	92.7	88.2	80.5	71.4	61.1	(21)
		MCWB	42.5	44.7	47.3	50.1	54.8	58.2	61.2	61.8	58.7	54.2	47.7	43.0	(22)
	5%	DB	57.8	62.1	68.5	74.3	82.9	91.7	92.6	90.4	85.7	77.4	67.8	56.8	(23)
		MCWB	41.1	42.6	45.9	48.4	53.3	57.5	60.9	61.8	58.3	52.4	46.5	41.1	(24)
	10%	DB	53.8	57.5	65.0	71.0	79.9	89.6	90.1	87.8	83.0	74.3	63.3	52.4	(25)
		MCWB	39.8	41.2	44.4	47.1	51.9	57.0	60.8	61.6	58.0	51.4	45.0	39.5	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.9	48.5	50.6	53.3	58.9	64.3	68.6	68.6	66.3	60.8	51.4	47.8	(27)
		MCDB	56.4	61.7	71.9	78.4	87.1	84.8	83.8	83.5	77.4	75.0	67.1	59.6	(28)
	2%	WB	45.1	46.2	48.5	51.2	56.4	62.0	67.0	66.9	64.2	57.8	49.6	45.3	(29)
		MCDB	54.7	60.3	68.2	74.6	82.0	84.7	80.4	81.0	76.7	72.2	66.5	56.5	(30)
	5%	WB	43.0	44.4	46.9	49.5	54.6	60.1	65.9	65.6	62.6	55.5	47.9	43.0	(31)
		MCDB	54.1	58.5	65.7	71.7	79.1	84.9	79.1	79.6	75.8	71.2	63.7	52.9	(32)
	10%	WB	41.1	42.4	45.2	47.9	52.9	58.5	64.8	64.5	61.3	53.3	46.1	40.9	(33)
		MCDB	51.8	55.4	62.8	69.0	76.9	84.8	78.4	78.8	74.7	70.0	61.4	50.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	25.5	25.4	27.3	27.2	28.2	29.7	25.1	24.4	26.5	28.7	28.0	24.7	(35)
		MCDBR	32.6	33.6	33.8	33.4	33.0	32.7	29.6	28.8	30.3	33.5	34.2	31.4	(36)
		MCWBR	17.6	17.2	15.8	14.8	13.8	12.7	10.5	9.9	10.7	14.5	16.7	17.3	(37)
	5% WB	MCDBR	26.6	28.6	30.4	30.3	30.2	28.3	22.1	22.7	22.6	26.7	29.6	25.8	(38)
		MCWBR	15.2	15.0	14.7	13.8	13.0	11.7	7.6	8.4	9.1	12.5	15.2	14.8	(39)
(40) Clear-Sky Solar Irradiance	taub		0.248	0.251	0.271	0.289	0.301	0.305	0.354	0.354	0.305	0.285	0.254	0.247	(40)
	taud		2.655	2.669	2.587	2.514	2.522	2.501	2.461	2.451	2.585	2.593	2.649	2.658	(41)
	Ebn at Noon		313	323	321	317	311	308	292	292	305	305	308	308	(42)
	Edh at Noon		22	25	29	33	33	34	35	35	29	26	22	21	(43)
(44) All-Sky Solar Radiation	RadAvg		1026	1317	1790	2246	2522	2683	2206	2033	1885	1510	1153	918	(44)
	RadStd		92	120	120	102	150	122	148	110	76	111	53	64	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	+0.58	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+158	+59

Nomenclature: See separate page