

PRESCOTT, AZ, USA

WMO: 723723

Lat: 34.652N

Lon: 112.421W

Elev: 1537

StdP: 84.17

Time Zone: -7.00 (W07)

Period: 94-19

WBAN: 23184

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-7.6	-6.0	-20.2	0.7	6.0	-18.0	0.9	7.0	11.0	6.0	9.2	6.7	1.9	200	0.508

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.9	34.9	15.7	33.6	15.5	32.4	15.4	19.3	26.9	18.7	26.2	18.0	25.8	4.8	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.4	15.1	21.4	16.6	14.3	21.2	15.8	13.6	21.1	61.9	26.4	59.3	25.6	57.1	25.7	22.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.7	8.4	7.6	DB	-11.4	37.3	2.5	1.5	-13.1	38.4	-14.6	39.3	-16.0	40.1	-17.8	41.2	(4)
(5)			WB	-12.4	20.3	2.3	0.7	-14.0	20.9	-15.4	21.3	-16.7	21.7	-18.3	22.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.8	4.3	5.7	9.0	11.9	16.7	22.4	24.8	23.7	20.4	14.2	8.5	4.0	(6)	
	DBStd	8.10	3.44	3.73	3.63	3.88	3.82	3.14	2.14	2.11	2.65	3.69	3.82	3.50	(7)	
	HDD10.0	662	176	126	63	25	2	0	0	0	0	11	71	188	(8)	
	HDD18.3	2240	434	354	291	194	76	6	0	0	12	133	295	446	(9)	
	CDD10.0	2058	1	4	31	82	209	371	459	423	312	140	26	1	(10)	
	CDD18.3	596	0	0	0	1	24	127	201	166	74	4	0	0	(11)	
	CDH23.3	7623	0	0	10	73	543	1982	2243	1707	891	169	6	0	(12)	
	CDH26.7	3294	0	0	0	8	155	961	1103	753	292	22	0	0	(13)	
(14) Wind	WSAvg	3.2	2.7	3.1	3.5	4.0	3.9	3.9	3.2	2.9	3.0	3.0	2.8	2.7	(14)	
(15) Precipitation	PrecAvg	365	26	28	30	12	13	11	59	69	40	27	24	25	(15)	
	PrecMax	562	122	108	107	60	57	66	165	201	218	180	97	125	(16)	
	PrecMin	181	0	0	0	0	0	0	0	3	0	0	0	0	(17)	
	PrecStd	99	25	25	27	14	14	17	39	41	42	34	24	31	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.3	21.4	24.7	27.8	32.5	36.9	37.1	35.4	32.8	29.0	24.0	18.6	(19)	
		MCWB	6.7	8.0	9.5	11.1	14.2	15.6	16.7	16.6	15.1	12.9	9.8	7.3	(20)	
	2%	DB	16.3	18.9	22.2	25.4	30.2	34.6	35.0	33.7	31.2	26.9	21.9	16.2	(21)	
		MCWB	5.8	7.0	8.5	10.1	12.7	14.5	16.2	16.5	14.8	12.3	8.7	6.1	(22)	
	5%	DB	14.4	16.7	20.3	23.5	28.3	33.2	33.7	32.4	29.8	25.2	19.9	13.8	(23)	
		MCWB	5.1	5.9	7.7	9.1	11.8	14.1	16.1	16.6	14.6	11.3	8.1	5.1	(24)	
	10%	DB	12.1	14.2	18.3	21.7	26.6	32.0	32.3	31.0	28.3	23.5	17.4	11.4	(25)	
		MCWB	4.3	5.1	6.9	8.4	11.1	13.9	16.0	16.4	14.5	10.8	7.2	4.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.8	9.2	10.3	11.9	14.9	18.0	20.3	20.3	19.0	16.0	10.8	8.8	(27)	
		MCDB	13.6	16.5	22.2	25.8	30.6	29.3	28.8	28.6	25.2	23.9	19.5	15.3	(28)	
	2%	WB	7.3	7.9	9.2	10.7	13.6	16.7	19.4	19.4	17.9	14.3	9.8	7.4	(29)	
		MCDB	12.6	15.7	20.1	23.7	27.8	29.3	26.9	27.2	24.8	22.3	19.1	13.6	(30)	
	5%	WB	6.1	6.9	8.3	9.7	12.6	15.6	18.8	18.7	17.0	13.0	8.8	6.1	(31)	
		MCDB	12.3	14.7	18.7	22.0	26.2	29.4	26.2	26.4	24.3	21.8	17.6	11.6	(32)	
	10%	WB	5.0	5.8	7.4	8.8	11.6	14.7	18.2	18.0	16.3	11.8	7.8	5.0	(33)	
		MCDB	11.0	13.0	17.1	20.6	24.9	29.3	25.8	26.0	23.7	21.1	16.3	10.2	(34)	
(35) Mean Daily Temperature Range	MDBR		14.2	14.1	15.2	15.1	15.7	16.5	13.9	13.6	14.7	15.9	15.6	13.7	(35)	
	5% DB	MCDBR	18.1	18.7	18.8	18.5	18.3	18.2	16.5	16.0	16.9	18.6	19.0	17.4	(36)	
		MCWBR	9.8	9.6	8.8	8.2	7.7	7.1	5.8	5.5	6.0	8.1	9.3	9.6	(37)	
	5% WB	MCDBR	14.8	15.9	16.9	16.9	16.8	15.7	12.3	12.6	12.6	14.9	16.5	14.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.248	0.251	0.271	0.289	0.301	0.305	0.354	0.354	0.305	0.285	0.254	0.247	(40)	
	taud		2.655	2.669	2.587	2.514	2.522	2.501	2.461	2.451	2.585	2.593	2.649	2.658	(41)	
	Ebn at Noon		988	1018	1012	998	981	971	922	919	960	960	971	970	(42)	
	Edh at Noon		70	78	92	104	105	107	111	110	92	83	70	66	(43)	
(44) All-Sky Solar Radiation	RadAvg		3.23	4.15	5.64	7.08	7.95	8.46	6.95	6.41	5.94	4.76	3.64	2.89	(44)	
	RadStd		0.29	0.38	0.38	0.32	0.47	0.39	0.47	0.35	0.24	0.35	0.17	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)	
(47) Regional (14 neighbors)	+0.32	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+88	+33	(47)

Nomenclature: See separate page