

SEDONA, AZ, USA

WMO: 723756

Lat: 34.850N

Lon: 111.783W

Elev: 4827

StdP: 12.31

Time Zone: -7.00 (W07)

Period: 09-19

WBAN: 00375

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	27.2	29.8	-2.0	5.9	41.0	1.2	7.0	44.7	23.5	39.5	20.5	41.2	7.2	30	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.5	98.8	61.5	96.6	61.1	93.4	61.0	67.2	81.7	66.1	82.0	65.0	82.1	8.4	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
(p)															
63.4	104.8	70.9	62.5	101.5	71.1	60.6	94.6	72.0	34.6	81.8	33.7	80.8	32.7	82.2	71.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.1	19.0	17.0	DB	20.5	103.6	5.3	2.8	16.7	105.6	13.7	107.3	10.7	108.9	6.9	110.9	
			WB	17.3	69.0	4.8	1.5	13.8	70.1	11.0	70.9	8.3	71.8	4.7	72.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	63.1	45.8	47.5	54.8	60.1	67.6	79.8	81.2	79.7	75.1	64.8	54.5	45.3
	DBStd	14.78	6.92	8.50	7.17	7.62	7.76	5.98	4.37	4.82	5.36	7.04	8.01	7.31
	HDD50	582	159	135	38	13	2	0	0	0	0	5	48	182
	HDD65	2669	594	490	319	177	66	0	0	0	2	88	321	612
	CDD50	5364	29	65	187	317	549	893	968	922	754	462	183	35
	CDD65	1978	0	0	4	31	147	443	503	457	306	81	6	0
	CDH74	20705	0	1	46	333	1482	5520	5338	4705	2645	596	39	0
	CDH80	9787	0	0	1	59	502	2990	2710	2317	1092	115	1	0
Wind	WSAvg	7.5	7.2	7.3	7.6	8.7	8.7	8.0	6.4	6.6	7.4	7.7	7.8	6.9
Precipitation	PrecAvg	19.6	2.3	2.4	2.2	1.1	0.7	0.3	1.9	2.4	1.9	1.5	1.4	1.8
	PrecMax	30.2	9.8	5.9	6.0	2.6	3.7	1.6	5.6	5.4	4.8	5.9	4.1	5.8
	PrecMin	11.2	0.0	0.0	0.1	0.0	0.0	0.0	0.2	0.6	0.0	0.0	0.1	0.0
	PrecStd	5.2	2.5	1.6	1.7	0.9	0.8	0.4	1.4	1.1	1.6	1.5	1.0	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.6	72.6	79.0	86.0	91.5	103.8	99.9	99.3	95.4	88.1	78.9	67.5
		MCWB	46.4	48.4	51.7	54.0	56.8	61.9	63.1	63.5	61.4	57.3	51.1	46.6
	2%	DB	62.9	69.7	73.5	81.3	89.6	99.2	97.3	96.8	91.4	82.2	73.2	63.2
		MCWB	44.0	47.4	49.4	52.2	55.8	60.1	62.5	62.3	60.2	54.5	48.9	44.8
	5%	DB	59.3	64.0	71.9	78.6	85.9	96.8	95.1	94.5	90.0	80.8	70.3	59.3
		MCWB	42.5	45.2	48.6	50.7	54.8	59.3	62.4	62.4	59.9	53.8	48.6	43.1
	10%	DB	55.3	60.8	68.1	73.4	81.8	93.4	91.3	90.9	86.5	77.3	66.4	55.0
		MCWB	40.7	43.5	46.8	49.0	52.9	58.2	61.9	62.1	59.4	52.8	46.9	41.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.8	51.4	52.6	55.3	58.7	64.2	68.8	68.6	67.1	61.6	52.9	50.2
		MCDB	57.7	66.7	76.8	79.9	82.6	91.6	81.6	83.6	79.6	65.3	70.0	58.2
	2%	WB	46.5	48.3	50.7	53.0	57.2	62.4	67.4	67.1	64.9	58.3	51.3	47.8
		MCDB	55.7	64.3	72.2	78.9	83.1	91.7	81.8	81.8	80.2	74.3	69.8	58.4
	5%	WB	44.7	46.4	49.2	51.4	55.4	61.1	66.3	66.0	63.6	56.6	49.9	45.5
		MCDB	54.8	61.4	69.2	75.2	80.8	90.7	82.2	81.8	80.3	74.0	67.3	54.4
	10%	WB	43.0	44.7	47.7	50.2	53.9	59.7	65.4	65.0	62.2	54.9	48.2	43.8
		MCDB	53.2	58.0	65.9	72.9	79.4	88.9	82.4	81.9	78.8	72.1	63.6	52.1
Mean Daily Temperature Range	5% DB	MDBR	16.3	17.8	21.0	22.8	23.1	24.6	22.5	22.0	21.8	20.8	18.5	15.0
		MCDBR	19.4	22.6	24.0	25.7	27.0	27.3	25.1	25.0	24.6	23.3	21.3	17.7
		MCWBR	11.2	11.5	11.4	11.8	11.2	10.3	8.4	8.2	9.2	10.1	10.2	10.3
	5% WB	MCDBR	16.7	20.5	22.2	24.1	25.0	24.7	21.6	20.8	20.2	19.8	19.7	15.3
		MCWBR	10.2	10.7	11.0	11.2	10.4	9.3	7.2	7.2	8.1	9.1	9.8	9.0
Clear-Sky Solar Irradiance	taub	0.253	0.255	0.279	0.294	0.308	0.310	0.365	0.366	0.310	0.292	0.260	0.251	
	taud	2.639	2.653	2.568	2.515	2.518	2.506	2.449	2.430	2.591	2.582	2.638	2.649	
	Ebn at Noon	311	320	318	315	309	306	289	288	303	301	305	305	
	Edh at Noon	23	25	30	33	34	34	36	36	29	27	23	21	
All-Sky Solar Radiation	RadAvg	1014	1308	1785	2234	2506	2666	2155	1997	1868	1501	1147	905	
	RadStd	92	117	121	102	157	127	143	108	73	114	57	63	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (13 neighbors)	+0.59	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+153	+59

Nomenclature: See separate page